

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)

**WASTE WATER QUALITY STATUS OF DRAIN**

REPORT NO: DPCC/W/D/2024/ 1042  
Date of Sampling: - 03.06.2024

Dated 25/6/2024

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
<b>Standards</b>		<b>5.5- 9.0</b>	<b>100</b>	<b>250</b>	<b>30</b>
1.	Najafgarh Drain	8.26	130	216	50
2.	Metcalf House Drain	NO FLOW			
3.	Khyber Pass Drain				
4.	Sweeper Colony Drain				
5.	Magazine Road Drain				
6.	ISBT Drain				
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.61	148	268	46
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	7.30	132	220	60
12.	Indrapuri Drain	7.39	114	240	50
13.	Sonia Vihar Drain	7.62	142	280	40
14.	Kailash Nagar Drain	7.58	78	164	35
15.	Shastri Park Drain	7.46	69	164	40
16.	Barapulla Drain	7.30	50	260	52
17.	Maharani Bagh Drain	7.18	80	220	40
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	7.15	148	292	60
20.	Sarita Vihar Pool	7.27	78	212	34
21.	Tuglakabad Drain	7.22	112	248	70
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)				
24.	Shahdara Drain	6.99	180	400	120
25.	Sahibabad Drain	7.15	136	392	100
26.	Molarband Drain	NO FLOW			
27.	Abul Fazal Drain	7.47	90	280	50

*Maitra*

I/C WATER LAB

**Dr. Nandita Moitra**

Scientist 'D'

*Sharma*

SSA/Analyst/SLA