



DELHI POLLUTION CONTROL COMMITTEE  
WATER LABORATORY  
4<sup>th</sup>FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06  
visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2023/486  
Date of Sampling: -04.12.2023

Dated : 18.12.2023

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
Standards		5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.5	92	248	46
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	7.8	86	202	43
7.	Tonga Stand Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
8.	Civil Mill Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9.	SEN Nursing Home Drain	7.3	84	245	41
10.	Drain No. 14	NO FLOW	NO FLOW	NO FLOW	NO FLOW
11.	Power House Drain	7.1	82	197	42
12.	Indrapuri Drain	7.3	80	250	45
13.	Sonia Vihar Drain	7.2	76	176	36
14.	Kailash Nagar Drain	7.0	70	160	38
15.	Shastri Park Drain	6.8	58	148	27
16.	Barapulla Drain	7.6	74	184	40
17.	Maharani Bagh Drain	7.5	72	256	44
18.	Old Agra Canal Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
19.	Jaitpur Drain	7.4	82	218	35
20.	Sarita Vihar Pool	7.0	70	179	36
21.	Tuglakabad Drain	7.1	64	182	32
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	7.5	50	144	26
24.	Shahdara Drain	7.4	96	304	49
25.	Sahibabad Drain	7.3	90	280	45
26.	Molarband Drain	7.0	68	188	27
27.	Abul Fazal Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
28.	Supplementary Drain	7.6	72	213	39

I/C Water Lab

Dr. Nandita Moitra  
Scientist 'D'