



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/22-23/229 / 5369

Dated 10/2/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 09.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P(mg/l)
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II (20)	Inlet	6.5	324	125	248	25.6	26.61	16.5	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	32	16	72	4.4	4.3	3.2	
		OLMS	7.2	35.59	24.07	129.49	-	31.81	-	
2	Ph-III (70)	Inlet	6.8	224	115	288	11.6	30.1	28	Meeting the standards.
		Outlet	7.0	8	6	32	2.4	3.4	1.0	
		OLMS	7.6	8.83	11.19	24.82	-	1.10	-	
Total 90										

  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/230/5370

Date: 11/02/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P(mg/l) 2
1	Phase-I,II(15)	Inlet	7.6	212	103	204	24.8	28.4	10.2	Meeting the Standards.
		Outlet	7.3	8	6	36	1.2	2.5	1.3	
		OLMS	7.2	6.86	4.31	22.24	-	0.68	-	
Total 15										

*N. Mitra*  
I/C LABORATORY

**Dr. Nandita Moitra**  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/231 /5371

Dated 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
		6.5-9.0	10	10	50	10	5	2		
Phase-I,II(2.2)		Inlet	7.3	216	108	232	20.4	24.6	11.5	Meeting the Standard.
		Outlet	7.0	8	6	32	2.4	3.8	1.2	
		OLMS	7.8	5.87	3.96	16.50	-	1.30	-	
Total 2.2										

*Nandita*

I/C LABORATORY

**Dr. Nandita Moitra**

Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/232 | 5372

Dated: - 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P(mg/l)
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	Not Meeting the standards wrt TSS & BOD
		Outlet	7.3	220	55	256	14.4	32.3	22.2	
		OLMS	7.6	16	14	48	2.4	4.2	1.8	
Total 12			7.5	7.63	5.15	29.96	-	3.05	-	

*Nandita*

I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/233 /5373

Date: 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P(mg/l) 2
1	Phase-I,II (2.2)	Inlet	7.6	236	100	180	26.2	28.6	21.6	Meeting the Standards
		Outlet	7.2	8	4	16	2.4	2.4	1.4	
		OLMS	7.5	5.54	3.08	24.58	-	1.52	-	
Total 2.2										

*N. Moitra*  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/234 /S374

Dated 1-10/2/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.3	184	120	480	18.4	18.6	22.1	Meeting the standards
		Outlet	7.4	10	8	44	2.4	4.2	1.6	
		OLMS	7.6	5.96	4.27	27.69	-	2.27	-	
Total 20										

*N. Moitra*

I/C LABORATORY

Dr. Nandita Moitra

Scientist D



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/22-23/235/5375

Dated 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Nilothi  
2. Sampling location : Inlet and Outlet of STP  
3. Date of Inspection : 13.01.2023  
4. Samples collected by : DPCC Lab  
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	40	Inlet	7.4	364	148	480	22.4	44.38	10.3	Not meeting the standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.3	82	44	112	3.2	15.4	2.8	
		OLMS	7.8	107.57	57.13	272.68	-	35.47	-	
Total 40										

  
I/C LABORATORY  
**Dr. Nandita Moitra**  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/236/5376

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Dated - 10/2/23

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P(mg/l)
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD, COD, Dissolved Phosphate.
		Outlet	7.6	220	86	388	17.4	42.3	21	
		OLMS	7.4	28	18	80	1.2	4.6	4.8	
Total 5		7.5	19.60	14.80	78.0	-	10.15	-		

*Nandita*

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/237/5377


Dated 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	Phase-I(40)	Inlet	-	-	-	-	-	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.3	248	116	420	14.3	16.8	22.8	Not Meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.2	18	14	56	1.4	3.8	1.6	
		OLMS	7.8	13.19	9.31	21.36	-	7.30	-	
Total 80										

I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/238/5418

Date: 13.02.23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P(mg/l) 2
1	20	Inlet	7.5	140	70	192	17.2	14.4	28.2	Not meeting the Standards wrt TSS, BOD COD & Dissolved Phosphate.
		Outlet	7.4	32	20	69	3.2	3.6	2.5	
		OLMS	7.5	32.35	24.50	158.03	-	19.3p	-	
Total 20										

*Nandita*  
I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/239/5378

Dated 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P(mg/l) 2
20		Inlet	6.9	230	96	300	15.2	32.8	8.32	Meeting the Standards.
		Outlet	7.3	8	6	40	1.2	2.4	1.6	
		OLMS	7.5	32.35	24.50	158.03	-	19.3	-	
Total 20										

*Nandita*

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/240 / 5379

Dated 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	15	Inlet	7.5	338	142	480	16.2	34.2	26.6	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.6	20	18	80	2	5.6	3.1	
		OLMS	7.4	18.40	14.38	79.08	-	15.84	-	
Total 15										

*N. Nandita*  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006  
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/241 / 5380

Dated 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.6	284	92	176	5.2	26.8	22.5	
		OLMS	7.2	32	15	40	1.6	2.4	2.2	
Total 10			7.4	26.04	13.26	85.56	-	12.99	-	

*N. Moitra*  
I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/242 / 5381

Dated 10/2/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.8	176	102	216	16.4	24.6	18.5	
		OLMS	7.5	6	4	28	0.8	2.5	1.4	
Total 30			6.3	8.34	4.74	26.69	-	0.96	-	

*N. Moitra*

I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/243/5382

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Date - 10/2/23

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-I (10)	Inlet	7.6	232	120	288	26.4	40.5	31.8	Not meeting the standards wrt TSS.
		Outlet	7.2	14	10	48	1.2	2.8	1.5	
		OLMS	7.2	5.34	4.31	25.96	-	3.24	-	
2	Ph-III (10)	Outlet	7.4	16	12	40	1.2	2.5	1.3	Not meeting the standards wrt TSS & BOD.
		OLMS	-	-	-	-	-	-	-	OLMS was found locked
Total 20										

*Nandita*  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/244 / 5383

Date 10/2/2022

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	45	Inlet	7.4	324	185	336	24.8	38	34.8	Not Meeting the Standards wrt TSS, BOD, COD, Ammonical nitrogen & Dissolved Phosphate.
		Outlet	7.0	164	94	212	7.2	16.5	14.5	
		OLMS	-	-	-	-	-	-	-	
Total 45									OLMS was non functional	

*N. Mohita*  
I/C LABORATORY

Dr. Nandita Mohita  
Scientist 'D'





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006  
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/245 / 5384

Date: 10/2/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.0	108	78	356	5.4	24.3	18.2	Meeting the standards
		Outlet	7.2	10	8	48	1.2	3.2	1.4	
		OLMS	7.5	9.76	6.78	33.63	-	4.52	-	
Total 5										

*N. Nandita*  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/246 | 5385

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Date — 10/2/2023

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P(mg/l)
1	25	Inlet	7.6	342	148	356	21.2	23.4	27.7	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	22	16	56	1.4	4.2	3.5	
		OLMS	7.5	16.99	7.94	29.49	-	8.34	-	
Total 25										

*Nandita*  
I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/247 / 5386

Date - 10-2-2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	9	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.6	188	95	200	18	29.5	21.5	
		OLMS	7.1	10	8	30	2.8	3	1.2	
Total 9			7.2	6.3	4.3	30.2	-	0.71	-	

*N. Mohan*  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006  
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/248 | 5387

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Date - 10/2/2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	1	Inlet	7.5	188	94	170	23.2	20.6	18	Meeting the Standards.
		Outlet	7.1	2	4	10	0.4	1.6	0.8	
		OLMS	7.2	0.49	0.98	7.86	-	0.25	-	
Total 1										

*Nandita*  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist-IP



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/249 | 5388

Date - 10/02/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15	Inlet	7.3	220	78	348	16.2	18.8	32.7	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.1	36	22	72	2.8	3.4	1.6	
		OLMS	7.4	13.75	6.02	40.70	-	10.58	-	
Total 15										

*N. Moitra*  
I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/250 / 5389

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Date - 10/02/2023

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	2.2	Inlet	7.4	256	120	352	16.8	20.4	24.4	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.3	28	16	68	2.8	3.50	3.6	
		OLMS	7.5	5.43	7.61	36.19	-	11.49	-	
2	3	Inlet	7.1	248	122	428	8.8	22.3	32.8	
		Outlet	7.3	32	18	88	1.4	4.38	2.8	
		OLMS	7.3	5.35	4.25	24.80	-	8.91	-	
Total 5.2										

*Nandita*

I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/251 | 5390

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Date - 10/02/2023

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10 Ph-1	Inlet	7.3	180	84	388	13.6	13.2	34.2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.1	28	18	72	1.4	3.4	4.3	
		OLMS	7.8	6.14	4.98	29.88	-	6.47	-	
2	10 Ph-2	Inlet	7.3	270	130	338	13.6	24.7	23.8	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	26	16	64	1.2	3.0	3.8	
		OLMS	7.8	9.98	7.81	40.56	-	11.70	-	
Total 20										

*N. Moitra*  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/252 | 5391

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Date - 10/02/2023

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P (mg/l) 2
1	12	Inlet	7.6	212	90	280	15.6	26.5	17.8	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.4	18	14	52	2.8	2.5	1.6	
		OLMS	7.5	22.49	10.38	25.95	-	2.55	-	
	16	Outlet	7.4	16	12	36	3.2	4.2	2.4	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		OLMS	6.6	7.08	3.46	16.67	-	4.91	-	
	37	Outlet	7.3	18	14	40	2	4.2	2.4	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate.
		OLMS	-	-	-	-	-	-	-	
	45	Outlet	7.5	20	16	48	2.4	2.5	1.4	OLMS was non functional Not meeting the Standards wrt TSS & BOD.
		OLMS	6.9	7.61	13.52	35.49	-	3.78	-	
	Total 110									

*N. Moitra*

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/253 | 5392

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Date - 10/02/2023

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P(mg/l)
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.7	130	60	220	14.2	22.7	13.8	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.1	66	42	136	3.2	4.8	1.7	
		OLMS	7.4	90	64	265	-	25.67	-	
2	20	Inlet	7.6	130	64	218	16.8	20	14.6	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.4	62	38	112	4.8	4.2	1.6	
		OLMS	7.6	89	75.20	249.33	-	22.61	-	
Total 60										

*Maitra*  
I/C LABORATORY  
Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/254 | 5393

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

Date 10/02/2023

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.5	98	48	180	5.8	30.2	37.3	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	22	18	54	1.4	3.6	2.8	
		OLMS	7.5	17.30	13.30	47.62	-	10.01	-	
Total 5										

*N. Mehta*  
I/C LABORATORY  
Dr. Nandita Moura  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/10 / 5394

Detc - 10/04/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P(mg/l)
1	0.66	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate. OLMS was non functional
		Outlet	7.4	298	120	256	20.3	16.8	14.6	
		OLMS	7.4	26	14	72	3.4	2.2	3	
Total 0.66			-	-	-	-	-	-		

*N. Moitra*  
I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'