



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/176/4410

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2021

1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 08.10.2021
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Ph-I,II(20)	Inlet	7.4	336	160	368	24	32.33	14.08	Not meeting the Standards w.r.t BOD, TSS, COD, A.N & DP
		Outlet	7.6	48	22	56	3.2	11.31	3.9	
		OLMS*	-	-	-	-	-	-	-	
		% Variation								
2	Ph-III(10)	Inlet	7.0	248	100	224	15.2	53.13	41.64	Not meeting the standards w.r.t TSS, BOD, A.N. & DP.
		Outlet	7.4	46	21	80	4.8	14.20	4.89	
		OLMS*	7.3	12.84	19.55	79.13	-	4.62	-	
		% Variation	-1.35 (D)	-72.86 (D)	-6.90 (D)	-1.08 (D)	-	-67.46 (D)	-	
Total 30										

I-Increase & D-Decrease

Remarks: Ph-I & II OLMS had been stolen as reported by them, FIR had been filed in this regards.

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT

5999 h/11/2021
12/11/2021

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/177/4411

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind. /Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I,II(15)	Inlet	7.2	188	85	246	24.8	32.49	6.58	Meeting the Standards.
		Outlet	7.5	10	7	32	0.8	2.77	1.47	
		OLMS*	7.5	8.35	5.64	31.83	-	2.03	-	
		% Variation	0	-16.5 (D)	-19.42 (D)	-0.53 (D)	-	-26.71 (D)	-	
Total 15										


I-Increase & D-Decrease

N. Mitra

I/C LABORATORY

M. B. Srivastava

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/178/4412

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021


1. Name & Address of Ind./Unit : **DELHI GATE STP (OLD)**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of Inspection : **21.10.2021**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	6.9	208	85	336	22.8	37.38	14.40	Meeting the Standards.
		Outlet	7.1	8	6	32	1.2	2.36	1.30	
		OLMS*	6.8	11.01	13.90	42.60	-	2.54	-	
		% Variation	-4.22 (D)	37.62 (I)	131.66 (I)	33.12 (I)	-	7.62 (I)	-	
Total 2.2										

I-Increase & D-Decrease

Mitra
I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/179 /4413

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021


1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	12	Inlet	7.1	184	95	368	14.8	34.28	15.10	Not Meeting the Standards w.r.t. TSS, BOD, COD & D.P.
		Outlet	7.3	16	12	62	4	4.22	3.20	
		OLMS*	7.3	12.84	19.55	79.13	-	4.62	-	
		% Variation	0	-19.75 (D)	62.91 (I)	27.62 (I)	-	9.47 (I)	-	
Total 12										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
 Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/180 | 14414

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Sampling location : Inlet and Outlet of STP
2. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
3. Date of Inspection : 21.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.3	240	93	288	15.2	33.72	11.58	Meeting the Standards
		Outlet	7.4	8	10	38	1.2	3.34	1.52	
		OLMS*	7.3	6.01	8.14	40.01	-	2.45	-	
		% Variation	-1.35 (D)	-24.87 (D)	-18.6 (D)	5.28 (I)	-	-26.64 (D)	-	
Total 2.2										

I-Increase & D-Decrease

N. Mitra
 W/C LABORATORY

P.B. Anwar

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/181 14415

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.23	200	85	272	15.2	24.06	13.84	Meeting the Standards.
		Outlet	7.3	8	10	40	1.2	4.18	1.26	
		OLMS*	7.3	7.12	10.27	47.79	-	3.84	-	
		% Variation	0	-28.8 (D)	2.7 (I)	19.47 (I)	-	-8.13 (D)	-	
Total 20										

I-Increase & D-Decrease

Mitra
I/C LABORATORY

R.B. Sharma
SR. SCIENTIFIC ASSISTANT

Scientific



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/182/4416

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	40	Inlet	7.1	312	140	320	19.2	28.54	15.06	Not Meeting the Standards w.r.t TSS, BOD, COD & D.P.
		Outlet	7.3	42	22	80	4	3.08	2.24	
		OLMS*	7.2	42.23	22.21	89.17	-	3.97	-	
		% Variation	-1.36 (D)	0.54 (I)	0.95 (I)	11.46 (I)	-	28.89 (I)	-	
Total 40										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/183/4417

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	5	Inlet	7.4	216	70	304	20.8	58.01	24.86	Not meeting the standards w.r.t to TSS, BOD, COD, and A.N. & D.P.
		Outlet	7.5	28	20	56	2.4	5.80	5.43	
		OLMS*	7.5	32.68	23.85	95.77	-	6.83	-	
		% Variation	0	16.71 (I)	19.25 (I)	71.01 (I)	-	17.75 (I)	-	
Total 5										

I-Increase & D-Decrease

M. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT

Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/184/4418

Date: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

- 1.
2. Name & Address of Ind./Unit : Rithala STP
3. Sampling location : Inlet and Outlet of STP
4. Date of Inspection : 05.10.2021
5. Samples collected by : DPCC Lab
6. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Rithala Ph-I unit was closed.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
		% Variation								
2	Ph-II(40)	Inlet	7.2	220	135	293	16	21.63	18.80	Not meeting the standards w.r.t to TSS.
		Outlet	7.5	14	10	44	1.6	4.02	1.76	
		OLMS*	7.1	11.78	9.97	39.71	-	5.0	-	
		% Variation	-5.33 (D)	-15.85(D)	-0.3 (D)	-9.75 (D)	-	-16.94 (D)	-	
Total 80										

I-Increase & D-Decrease

Mitra
I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/185/4419

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.4	108	43	160	23.2	38.24	11.24	Not meeting the Standards w.r.t TSS, BOD, COD & A.N
		Outlet	7.3	32	24	88	4.8	5.80	1.28	
		OLMS*	7.4	37.35	24.5	104.03	-	5.1	-	
		% Variation	1.36 (I)	16.71 (I)	2.08 (I)	18.21 (I)	-	-12.06 (D)	-	
Total 20										

I-Increase & D-Decrease

Mukta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/186/4420

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2021

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	20	Inlet	7.2	144	110	208	20	28.72	12.04	Not meeting the Standards w.r.t BOD, & D.P.
		Outlet	7.4	10	13	40	4.4	4.49	2.30	
		OLMS*	-	-	-	-	-	-	-	
		% Variation								
Total 20										

I-Increase & D-Decrease

Remarks: OLMS had been stolen as reported by them, FIR had been filed in this regards.

Mitra
I/C LABORATORY

A.B. Sharma

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/21-22/187 14421

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021


1. Name & Address of Ind./Unit : Rohini STP
 2. Sampling location : Inlet and Outlet of STP
 3. Date of Inspection : 05.10.2021
 4. Samples collected by : DPCC Lab
 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	15	Inlet	7.6	304	125	448	24	38.27	22.16	Not meeting the Standards w.r.t TSS, BOD, COD, A.N. & D.P.
		Outlet	7.3	16	14	56	2.4	5.42	3.48	
		OLMS*	7.40	13.68	12.18	64.38	-	6.66	-	
		% Variation	1.36 (I)	-23.87 (D)	-13 (D)	14.96 (I)	-	22.87 (I)	-	
Total 15										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/188/4422

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	10	Inlet	7.4	216	95	208	14	32.21	17.28	Not Meeting the Standards w.r.t TSS, BOD, COD, A.N. & D.P.
		Outlet	7.51	26	17	60	2	5.02	2.80	
		OLMS*	-	-	-	-	-	-	-	
		% Variation								
Total 10										

I-Increase & D-Decrease

Remarks: OLMS was not functional due to power failure.

Mitra
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/189 *1423*

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	30	Inlet	7.2	256	110	336	15.2	24.32	21.69	Meeting the Standards
		Outlet	7.4	8	6	42	0.8	1.16	0.92	
		OLMS*	7.3	10.65	8.26	49.03	-	4.52	-	
		% Variation	-1.35 (D)	33.12 (I)	37.66 (I)	16.73 (I)		289.6 (I)		
Total 30										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT

Scientisi



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/190/4424

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.3	192	75	384	18.4	36.18	41.19	Not meeting the Standards w.r.t TSS, & BOD
		Outlet	7.4	12	14	60	1.2	3.83	1.62	
		OLMS*	7.1	10.55	11.88	86.51	-	4.52	-	
		% Variation	-4.05 (D)	-12.08 (D)	-15.14 (D)	44.18 (I)	-	18.01 (I)	-	
Total 25										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY

Scientist (I)

A. K. Sharma

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
 Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/191/4425

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	45	Inlet	7.1	192	85	320	8.4	34.24	43.24	Not Meeting the Standards w.r.t TSS, BOD & COD, A.N. & D.P.
		Outlet	7.3	48	30	98	3.6	6.12	4.18	
		OLMS*	-	-	-	-	-	-	-	
		% Variation								
Total 45										

I-Increase & D-Decrease

Remarks: OLMS was not there at the time of sampling.

M. Mitra
 I/C LABORATORY

[Signature]

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 12/11/2021

Report Number: DPCC/W/STP/21-22/192/4426

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021


1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.1	112	60	272	4	33.48	15.56	Meeting the Standards
		Outlet	7.28	8	10	48	1.6	4.82	1.60	
		OLMS*	7.3	16.35	13.72	55.48	-	4.42	-	
		% Variation	1.38 (I)	104.37 (I)	37.2 (I)	15.58 (I)	-	-8.29 (D)	-	
Total 5										

I-Increase & D-Decrease

M. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/193

14429

Dated : 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021


1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.2	312	175	384	26	29.06	31.58	Not meeting the Standards w.r.t TSS, BOD, COD & D.P
		Outlet	7	28	19	85	1.2	3.92	4.15	
		OLMS*	7.28	25.64	19.85	79.26	-	4.48	-	
		% Variation	2.85 (I)	-8.42 (D)	4.47 (I)	-6.75 (D)	-	14.28 (I)	-	
Total 25										

I-Increase & D-Decrease

N. Mishra
I/C LABORATORY

R. Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 12/11/2021

Report Number: DPCC/W/STP/21-22/194 *14428*

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021


1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	50	10	5	2	
1	9	Inlet	7.2	164	85	336	20.4	18.76	21.32	Meeting the Standards.
		Outlet	7	8	6	42	0.8	3.24	1.87	
		OLMS*	6.8	14.06	6.29	55.19	-	4.09	-	
		% Variation	-2.85 (D)	75.75 (I)	4.83 (I)	31.40 (I)	-	26.23 (I)	-	
Total 9										

I-Increase & D-Decrease

N. Mittal
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/195/4429

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021


1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	1	Inlet	7.5	156	72	288	22.4	38.01	19.92	Meeting the Standards.
		Outlet	7.1	4	6	32	0.4	0.88	1.12	
		OLMS*	7.1	0.45	3.36	36	-	1.50	-	
		% Variation	0	-88.75 (D)	-44 (D)	12.5 (I)	-	0.70 (I)	-	
Total 1										

I-Increase & D-Decrease

N. Mitra
I/C LABORATORY

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/21-22/196 | 4430

Dated : 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021


1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.31	168	70	240	15.2	13.13	34.62	Not meeting the standards w.r.t TSS, BOD COD & D.P
		Outlet	7.3	20	14	56	1.6	4.33	2.12	
		OLMS*	7.1	31.41	14.05	80.20	-	3.97	-	
		% Variation	-2.7 (D)	57.05 (I)	0.35 (I)	43.32 (I)	-	-8.31 (D)	-	
Total 15										

I-Increase & D-Decrease

N. Malhotra
I/C LABORATORY

A.B. Srivastava
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/197/4431

Date: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : VasantKunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	2.2	Inlet	7.1	220	95	384	21.6	18.28	32.46	Not meeting the Standards w.r.t TSS, BOD, COD, A.N. & D.P
		Outlet	7.4	32	20	69	3.2	11.64	8.16	
		OLMS*	7.5	20.32	14.17	41.29	-	4.04	-	
		% Variation	1.35 (I)	-36.5 (D)	-29.15 (D)	-4015 (D)	-	-65.29 (D)	-	
2	3	Inlet	7.6	236	85	288	9.6	21.64	31.16	Not Meeting the Standards w.r.t TSS, BOD & COD
		Outlet	7.2	18	16	72	2.4	4.32	1.92	
		OLMS*	7.4	24.05	22.23	47.60	-	4.96	-	
		% Variation	2.77 (I)	33.61 (I)	38.93 (I)	-33.88 (D)	-	14.81 (I)	-	
Total 5.2										

I-Increase & D-Decrease

Mishra

I/C LABORATORY

[Signature]

SR. SCIENTIFIC ASSISTANT

Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/198/4432

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l) ₂	
1	2.2	Inlet	7.4	176	95	432	15.2	31.08	38.54	Not Meeting the Standards w.r.t TSS, BOD COD & D.P
		Outlet	6.9	12	16	69	1.2	2.14	4.33	
		OLMS*	7.4 (I)	17.90 (I)	19.02 (I)	64.02 (I)	-	4.39 (I)	-	
		% Variation	7.24	49.16	18.87	-7.21		105.14		
2	3	Inlet	6.5	268	115	400	19.2	25.62	17.77	Not Meeting the Standards w.r.t TSS, BOD, COD & D.P
		Outlet	7.5	24	17	74	1.6	1.62	3.82	
		OLMS*	-	-	-	-	-	-	-	
		% Variation								
Total 5.2										

I-Increase & D-Decrease

Remarks: OLMS (3 MGD) was found non-operational.

I/C LABORATORY

SR SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/21-22/199

14433

Dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	12	Inlet	6.8	188	80	288	15.2	29.08	32.87	Under maintenance
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
		% Variation	-	-	-	-	-	-	-	
	16	Outlet	7.2	34	19	72	1.2	4.32	1.98	Not meeting the Standards w.r.t TSS, BOD, & COD.
		OLMS	7.3	34.32	26.40	92.40	-	3.96	-	
		% Variation	1.38 (I)	0.94 (I)	38.94 (I)	28.33 (I)	-	-8.51 (D)	-	
	37	Outlet	7.3	32	23	80	1.6	3.88	1.43	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.3	27.61	21.99	80.61	-	5.22	-	
		% Variation	0	-13.71 (D)	-4.39 (D)	0.76 (I)	-	34.53 (I)	-	
	45	Outlet	7.4	22	16	72	1.6	3.17	1.28	Not meeting the Standards w.r.t TSS, BOD & COD.
		OLMS	7.3	26.80	18.76	67	-	5.04	-	
% Variation		-1.35 (D)	21.81 (I)	17.25 (I)	-6.94 (D)	-	59.93 (I)	-		
Total 110										

I-Increase & D-Decrease

Remarks: 12 MGD plant was under shut down due to most urgent repairing work, hence no sample taken from this plant.

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/200/4434

Date: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	40	Inlet	7.2	208	85	432	16	31.62	18.89	Not meeting the Standards w.r.t TSS,BOD,COD D.P. & A.N.
		Outlet	7.4	64	32	96	4.8	16.29	5.20	
		OLMS*	7.5	102.25	61.94	281.78	-	21.02	-	
		% Variation	1.35 (I)	59.76 (I)	93.56 (I)	193.52 (I)	-	29.03 (I)	-	
2	20	Inlet	7.2	208	85	432	16	31.62	18.89	Not meeting the Standards w.r.t TSS,BOD,COD D.P. & A.N.
		Outlet	7.4	42	35	120	2.8	8.52	2.86	
		OLMS*	7.2	39.42	59.12	115.27	-	19.51	-	
		% Variation	-0.02(D)	0.06 (I)	68.91(I)	-3.94 (D)	-	128.99 (I)	-	
Total 60										


I-Increase & D-Decrease

N. Mitra

I/C WATER LABORATORY

AB Anam

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/21-22/8 / 4435

dated: 12/11/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER -2021

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.10.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	0.66	Inlet	7.3	276	120	400	22.4	23.34	17.27	Not meeting the Standards w.r.t TSS, BOD, COD & D.P
		Outlet	7.5	24	13	80	2	3.01	2.35	
		OLMS*	-	-	-	-	-	-	-	
		% Variation								
Total 0.66										

I-Increase & D-Decrease

Remarks: OLMS was non-functional due as electricity cut off at the time of sampling.

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT