

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/287

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


- | | | |
|---|---------------------------------|-------------------------|
| 1 | Name & Address of Ind./Unit | Coronation Pillar STP |
| 2 | Sampling location | Inlet and Outlet of STP |
| 3 | Date of Inspection | 05.03.2020 |
| 4 | Samples collected by | DPCC Lab |
| 5 | Parameters analyzed and results | |

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Ph-I,II(20)	Inlet	7.6	300	220	520	24.8	32.3	7.4	Not meeting the Standards w.r.t TSS, BOD,TSS,COD,A.N.
		Outlet	7.7	46	32	80	2.0	12.2	0.5	
		OLMS*	7.70	267.33	126.50	309.41	-	14.96	-	
	Ph-III(10)	Inlet	7.5	240	160	400	20.4	27.8	6.8	Not meeting the standards w.r.t TSS, BOD,COD &A.N.
		Outlet	7.6	44	28	64	2.0	12.4	0.7	
		OLMS*	7.27	275.02	46.91	172.63	-	15.81	-	
	Total 30									

I/C LABORATORY

N. Mittal

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/288

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **DELHI GATE STP NEW**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Remarks	
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.3	96	60	160	12.4	14.4	6.3	Meeting the Standards.
		Outlet	7.5	6	3	8	0.4	2.6	0.2	
		OLMS*	7.58	7.34	6.10	27.88	-	1.88	-	
	Total 15									

I/C LABORATORY

N. Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/289

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **DELHI GATE STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.2	120	65	164	14.4	21.6	6.6	Meeting the Standards.
		Outlet	7.4	10	6	16	0.4	2.8	0.1	
		OLMS*	OLMS was non-operational							
	Total 2.2									

I/C LABORATORY

Maitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/290

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit : **Keshopur STP new**
2. Sampling location : -
3. Date of Inspection : -
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	12	Inlet	-	-	-	-	-	-	-	Sampling was not conducted due to lockdown.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 12									

I/C LABORATORY

N. Mittal

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/291

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **Sen Nursing Home (SNH)**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.6	144	85	220	16.4	19.6	6.0	Meeting the standards.
		Outlet	7.7	8	4	12	0.8	3.2	0.3	
		OLMS*	6.53	11.5	5.34	11.32	-	16.29	-	
	Total 2.2									

I/C LABORATORY

Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/292

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **Nilothi STP-II**
2. Sampling location -
3. Date of Inspection -
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	-	-	-	-	-	-	-	Sampling was not conducted due to lockdown.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 20									

I/C LABORATORY

N. Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/293

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Nilothi STP**
2. Sampling location **-**
3. Date of Inspection **-**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	40	Inlet	-	-	-	-	-	-	-	Sampling was not conducted due to lockdown.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 40									

I/C LABORATORY

Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/294

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Najafgarh STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **19.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
5		Inlet	7.4	320	-	-	-	-	-	Not meeting the standards w.r.t TSS.
		Outlet	7.6	48	-	-	-	-	-	
		OLMS*	7.38	34.58	65.44	110.56	-	2.93	-	
	Total 5									

Remarks: Analysis was not completed due to lockdown.

I/C LABORATORY

N. Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/295

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Rithala STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **05.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	7.6	224	165	412	22.4	29.6	6.9	Not meeting the standards w.r.t TSS ,BOD,COD&A.N..
		Outlet	7.7	64	40	120	3.2	16.4	1.2	
		OLMS*	OLMS was found locked.							
2	Ph-II(40)	Inlet	7.7	228	170	424	21.6	28.4	7.3	Meeting the Standards.
		Outlet	7.8	8	6	16	0.4	4.8	0.2	
		OLMS*	8.71	13.74	11.73	49.65	-	7.30	-	
	Total 80									

Mukta

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/296

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Pappankalan STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **19.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.4	320	-	-	-	-	-	Not meeting the Standards w.r.t TSS.
		Outlet	7.7	24	-	-	-	-	-	
		OLMS*	9.3	49.78	32.37	80.10	-	6.95	9	
	Total 20									

Remarks: Analysis was not completed due to lockdown.

SR. SCIENTIFIC ASSISTANT

I/C LABORATORY

Maha



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/297

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Pappankalan STP-II**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **19.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.3	148	-	-	-	-	-	Not Meeting the Standards w.r.t TSS.
		Outlet	7.5	66	-	-	-	-	-	
		OLMS*	7.56	93.66	41.85	147.59	-	16.7	-	
	Total 20									

Remarks: Analysis was not completed due to lockdown.

N. Mittal

SR. SCIENTIFIC ASSISTANT

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/299

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Narela STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **18.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	10	Inlet	7.4	256	-	-	-	-	-	Not Meeting the Standards w.r.t TSS.
		Outlet	7.5	16	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 10									

Remarks: Analysis was not completed due to lockdown.

Maitra

SR. SCIENTIFIC ASSISTANT

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/300

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **Okhla STP New**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	30	Inlet	7.4	224	165	412	24.4	29.6	6.7	Meeting the Standards.
		Outlet	7.6	8	4	12	0.4	4.2	0.2	
		OLMS*	OLMS was non-operational							
	Total 30									

I/C LABORATORY

N. Mittal

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/301

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **Kondli STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **03.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.6	384	290	724	26.4	29.3	8.1	Not meeting the Standards w.r.t TSS & BOD.
		Outlet	7.7	24	16	40	1.2	4.2	0.5	
		OLMS*	7.80	12.58	9.93	27.20	-	5.52	-	
	Total 25									

I/C LABORATORY

Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/302

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **KONDLI STP New**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **03.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Remarks	
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
				10	10	50	10	5	2	
1	45	Inlet	7.6	286	220	540	19.2	24.1	7.6	Not Meeting the Standards w.r.t TSS,BOD
		Outlet	7.7	26	18	44	1.2	4.6	0.6	
		OLMS*	7.69	33.24	42.30	153.73	-	17.13	-	
	Total 45									

I/C LABORATORY

Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/303

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Kapashera STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **17.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5	Inlet	7.1	272	195	488	24.4	26.8	7.6	Meeting the Standards.
		Outlet	7.3	10	6	16	0.4	4.5	0.2	
		OLMS*	7.69	9.93	51.04	47.48	-	4.55	-	
Total 5										

I/C LABORATORY

Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/304

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Yamuna Vihar STP Ph-III**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **03.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.6	412	360	860	28.4	32.6	8.1	Not meeting the Standards w.r.t TSS,BOD,A.N.
		Outlet	7.7	28	16	40	1.6	5.4	0.8	
		OLMS*	OLMS found non-operational							
	Total 25									

I/C LABORATORY

Maita

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/305

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **Chilla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **03.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	9	Inlet	7.5	284	195	486	18.4	24.6	7.2	Meeting the Standards.
		Outlet	7.6	8	4	12	0.4	4.4	0.3	
		OLMS*	OLMS found non-operational							
	Total 9									

I/C LABORATORY

Maita

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/306

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit Akshardham STP
2. Sampling location -
3. Date of Inspection -
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	1	Inlet	-	-	-	-	-	-	-	
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 1									

I/C LABORATORY

Maitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/307

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Mehrauli STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **17.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Remarks	
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
				10	10	50	10	5	2	
15		Inlet	7.5	246	175	436	22.4	28.6	7.7	Not meeting the standards w.r.t TSS, BOD, COD, A.N.
		Outlet	7.7	38	26	64	3.2	6.6	0.9	
		OLMS*	7.7	172.42	52.18	312.33	-	11.1	-	
Total 15										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

Mishra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/308

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **Vasant Kunj STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **17.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	2.2	Inlet	7.4	284	210	540	32.8	35.6	8.4	Not meeting the Standards w.r.t TSS, BOD & A.N.
		Outlet	7.6	36	24	12	2.8	6.4	0.6	
		OLMS*	7.50	22.35	11.44	27.6	-	19.22	-	
	3	Inlet	7.7	160	110	320	18.4	32.0	4.2	Not Meeting the Standards w.r.t BOD, TSS.
		Outlet	7.4	28	16	48	1.2	4.8	0.9	
		OLMS*	7.57	18.62	6.02	47.58	-	7.19	-	
	Total 5.2									

I/C LABORATORY

Maitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/309

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit **Yamuna Vihar STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **03.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10	Inlet	7.6	340	260	640	24.4	29.6	7.5	Not Meeting the Standards w.r.t BOD, TSS & A.N.
		Outlet	7.6	20	12	32	0.8	10.4	0.5	
		OLMS*	OLMS found non-operational							
2	10	Inlet	7.5	412	360	860	26.5	32.6	8.1	Not Meeting the Standards w.r.t TSS, BOD & A.N.
		Outlet	7.7	28	16	40	1.6	5.4	0.8	
		OLMS*	OLMS found non-operational							
Total 20										

I/C LABORATORY

M. Malik

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/310

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **Molarband mini STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonica INitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	2	Inlet	7.5	228	160	380	20.4	24.4	6.7	Not meeting the Standards w.r.t BOD, TSS & A.N.
		Outlet	7.7	28	16	44	2.8	5.6	0.5	
		OLMS*	6.64	39.36	19.79	70.12	-	26.16	-	
	Total 2									

I/C LABORATORY

Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/311

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020


1. Name & Address of Ind./Unit **Okhla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.03.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks	
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
				10	10	50	10	5	2		
1	12	Inlet	7.4	292	210	580	26.4	32.4	7.6	Not meeting the Standards w.r.t TSS, BOD&COD.	
		Outlet	7.6	36	24	56	2.0	3.6	0.3		
			OLMS	8.21	31.96	27.61	80.51	-	0.09	-	
	16	Outlet	7.7	32	24	52	2.4	3.4	0.2	Not meeting the Standards w.r.t TSS, BOD&COD.	
		OLMS	6.66	30.63	24.07	53.96	-	0.55	-		
	37	Outlet	7.6	34	22	60	2.0	3.4	0.2	Not meeting the Standards w.r.t TSS, BOD&COD.	
		OLMS	7.91	74.28	53.53	111.75	-	4.28	-		
	45	Outlet	7.8	28	20	64	1.6	3.2	0.3	Not meeting the Standards w.r.t TSS, BOD&COD.	
OLMS		7.78	26.69	17.95	31.47	-	1.16	-			
	Total 110										

I/C LABORATORY

Mitra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/312

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit Keshopur STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection -
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	40	Inlet	-	-	-	-	-	-	-	Sampling was not conducted due to lockdown.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	-	-	-	-	-	-	-	Sampling was not conducted due to lockdown.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 60									

I/C LABORATORY

Mishra

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/313

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2020

1. Name & Address of Ind./Unit Oxidation pond STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection -
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
	6	Inlet	-	-	-	-	-	-	-	Non- operational (under rehabilitation)
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 6									

I/C LABORATORY

N. Mittal

SR. SCIENTIFIC ASSISTANT