



### DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <http://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/85/1174

Dated 13/8/24

#### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

- Name of STP : Coronation Pillar
- Sampling location : Inlet and outlet of STP
- Date of inspection : 12.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	70 MGD	Inlet	7.6	244	80	348	17.2	26.1	30.8	-	Meeting the standards.
		Outlet	7.2	8	7	32	0.8	2.4	1.8	93	
	OLMS		7.5	8.1	7.0	39.5	-	1.9	-		
Total 70											


*N Mishra*  
Scientist 'D'  
I/C Water Laboratory  
Mandita Moitra

*SSA/Analyst/SLA*



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpcccomms.nic.in>)



**LIFE**  
Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/86/1175

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

Dated 13/8/2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 12.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			PH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II (20)	Inlet	7.2	272	167	328	19.2	24.4	15.4	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	21	13	60	1.2	1.6	1.4	900	
		OLMS	7.5	14.9	9.9	49.8	-	3.9	-	-	
2	Ph-III (10)	Inlet	7.3	192	175	284	19.6	26.4	20.1	-	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.5	18	12	52	2.4	2.2	1.6	910	
		OLMS	-	-	-	-	-	-	-	-	
Total 30											OLMS was non-functional

*N. Moitra*

I/C Water Laboratory

**Dr. Nandita Moitra**  
Scientist 'D'

*S. Saha*

SSA/Analyst/SLA



### DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/87/1176

#### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

Dated 13/8/2024

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase- I & II (15)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Outlet	7.3	6	4	16	1.2	2.7	0.6	110	
		OLMS	7.3	7.2	4.3	23.6	-	9.8	-	-	
Total 15											

I/C Water Laboratory

*M. N. Mishra*  
**Dr. Nandita Mohita**  
Scientist 'D'

*S. S. Anand*  
SSA/Analyst/SLA



### DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/88/ 1177

#### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

Dated

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.4	152	100	212	21.2	23.2	12.6	-	Meeting the Standards.
		Outlet	7.1	7	5	28	0.8	2.1	1.4	84	
		OLMS	7.3	5.0	2.0	15.2	-	0.1	-	-	
Total 2.2											

I/C Water Laboratory

**Dr. Nandita Mohita**  
Scientist 'C'

SSA/Analyst/SLA



## DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/89/1178

### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

Dated 13/8/2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
			7.3	236	117	220	19.6	21.2	18.6	-	
			7.5	26	15	64	3.6	2.4	1.5	950	
		Outlet	7.5	26	15	64	3.6	2.4	1.5	950	
		OLMS	7.0	8.6	6.6	28.3	-	4.3	-	-	
Total 12											


I/C Water Laboratory

*MMishra*

**Dr. Nandita Mohita**  
Scientist 'D'

SSA/Analyst/SLA

*SSA*



## DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/90/1179

Dated 13/8/2024

### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

- Name of STP : SEN Nursing Home (SNH)
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 16.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	Phase-I,II (2.2)	Inlet	7.4	228	111	236	16.4	25.6	20.4	-	Meeting the Standards
		Outlet	7.1	8	5	24	2.4	2.6	1.1	150	
		OLMS	7.2	5.7	3.8	24.7	-	1.7	-	-	
Total 2.2											

I/C Water Laboratory

*M. Mohita*

Dr. Nandita Mohita

Scientist 'D'

SSA/Analyst/SLA

*Shankar*



## DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/91/1180

Dated 13/8/2024

### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	20	Inlet	7.8	188	100	288	20.4	13.6	12.7	-	Meeting the standards.
		Outlet	7.5	9	8	36	0.8	1.4	1.9	79	
		OLMS	7.9	5.6	3.2	35.1	-	2.4	-	-	
Total 20											

I/C Water Laboratory

Dr. Mandira Mohita  
Scientist 'D'

SSA/Analyst/SLA

*Handwritten Signature*



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



**LIFE**  
Lifestyle for  
Environment

Report Number: DPCC/W/STP/24-25/92/ 1181

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal coliform.
			7.1	264	133	316	18.8	19.7	21.5	-	
		Outlet	7.4	27	18	64	2.4	1.8	1.2	2800	
		OLMS	7.3	20.9	14.2	109.5	-	13.6	-		
Total 40											

*Mishra*

I/C Water Laboratory Mohira  
DR. HANUJ MOHRA  
Scientist (P)

SSA/Analyst/SLA

*Sharma*





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number DPCC/W/STP/24-25/93/1182

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

- Name of STP : Najafgarh
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 08.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	7.4	276	167	336	23.2	26.3	18.9	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	32	16	68	2.8	2.3	1.6	2200	
Total 5		OLMS	7.2	20.9	14.7	78.8	-	13.9	-	-	

*Mishra*

I/C Water Laboratory  
Dr. Manojita Mohita  
Scientist 'IV'

*Sharma*

SSA/Analyst/SLA



### DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/94/1183

Dated: 13/8/2024

#### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

- Name of STP : Rithala
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 10.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters										Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml			
1	Ph-I(40)	Inlet	7.6	254	150	340	18.8	23.5	13.9	-	-	-	Meeting the standards
		Outlet	7.4	8	6	36	1.2	1.4	1.6	81	-	-	
		OLMS	-	-	-	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.5	248	167	272	20	19.2	21.2	-	-	-	Meeting the standards
		Outlet	7.3	9	7	20	2.8	1.2	1.2	110	-	-	
		OLMS	7.8	8.3	7.3	82.5	-	4.9	-	-	-	-	
Total 80													

*Mishra*  
I/C Water Laboratory  
Dr. Vandana Mishra  
Scientist 'D'

*Sharma*  
SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/95/1184

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

- Name of STP : Pappankalan (Old)
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 08.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	20	Inlet	7.6	192	140	284	18.4	19.6	23.4	-	Not meeting the Standards wrt TSS, BOD COD & Fecal Coliform.	
		Outlet	7.1	22	14	52	2.4	1.1	1.7	2500		
		OLMS	7.6	19.0	15.0	107.0	-	9.6	-	-		
Total 20												

*N. M. M. M. M.*

I/C Water Laboratory Moitra

Scientist-D

*SSA/Analyst/SLA*

SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccomms.nic.in>)



**LIFE**  
Lifestyle for  
Environment

Report Number: DPCC/W/STP/24-25/96/ 1185

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

Dated 13/8/2024

- Name of STP : Pappankalan Ph-II (New)
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 08.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters										Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml			
20		Inlet	7.6	192	140	284	18.4	19.6	23.4	-			Meeting the Standards.
		Outlet	7.3	8	6	32	0.8	1.3	1.7	180			
		OLMS	7.1	6.5	5.0	20.2	-	1.7	-	-			
Total 20													

*M. Mittal*

I/C Water Laboratory  
**Dr. Nandini Mohita**  
Scientist 'D'

*SSA Analyst/SLA*



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocemms.nic.in>)



Report Number DPCC/W/STP/24-25/97/ 1186

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.7	252	150	320	14.8	22.6	22.5	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
			7.6	22	15	64	2.4	3.6	1.4	2500	
			8.1	25.1	12.9	81.6	-	15.2	-	-	
Total 15											

I/C Water Laboratory

*M. Mittal*  
**Dr. Namita Mohita**  
Scientist 'D'

*S. S. Anand*  
SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/98/1187

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	10	Inlet	7.5	176	100	268	19.2	17.6	20.2	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	29	13	68	2.4	2.1	1.9	2800	
Total 10		OLMS	8.0	9.1	7.2	37.6	-	9.0	-		

*Mishra*

I/C Water Laboratory

**Dr. Nandita Moitra**

Scientist 'D'

*SSA*

SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/99/1188

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

- Name of STP : Okhla New
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 09.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	30	Inlet	7.6	246	129	304	16.8	18.9	24.7	-	Meeting the Standards.
		Outlet	7.3	8	5	24	1.2	2.3	1.4	140	
		OLMS	7.0	7.3	7.3	27.1	-	0.9	-	-	
Total 30											

*Mishra*

I/C Water Laboratory  
**D. Nandita Mishra**  
Scientist 'D'

*Sharma*

SSA/Analyst/SLA



**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/100/ 1189

Dated 13/8/2024

**ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024**

- Name of STP : Kondli
- Sampling location : Inlet and Outlet of STP
- Date of inspection : 16.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I (10)	Inlet	7.5	336	117	380	26.4	32.4	31.9	-	Meeting the standards.
		Outlet	7.3	7	6	28	0.8	3.5	1.4	110	
		OLMS	7.2	8.0	3.8	21.9	-	4.48	-	-	
2	Ph-II & III (25+10)	Outlet	7.4	9	8	36	1.6	4.2	1.6	64	Meeting the standards
		OLMS	7.2	7.6	8.5	43.1	-	15.3	-	-	
Total 45											

*M. Mishra*

I/C Water Laboratory

Dr. Nandita Moitra

SSA/Analyst/SLA

*S. Hender*





## DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/101/190

### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

Dated 13/8/2024

- Name of STP : Kondli New
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 16.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	Ph-IV (45)	Inlet	7.5	296	160	244	19.6	23.4	23.8	-	Meeting the Standards.
		Outlet	7.3	9	8	32	1.6	2.7	1.7	130	
Total 45		OLMS	7.3	42.9	13.7	52.0	-	10.5	-	-	

I/C Water Laboratory

D: Nandita Moitra

SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/24-25/102/ 1191

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Kapsahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.4	196	100	248	16.8	25.4	14.8	-	Meeting the standards.
		Outlet	7.3	9	8	32	1.6	2.7	1.5	140	
Total 5		OLMS	7.6	9.2	5.6	44.6	-	4.7	-	-	

*M. Mohan*

I/C Water Laboratory

**D. Nandita Moitra**

Scientist 'D'

*S. S. Analyst/SLA*

SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/103/ 1192

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	25	Inlet	7.6	208	140	196	12.8	27.4	21.7	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.1	25	18	56	2.4	1.9	1.3	1600	
		OLMS	7.4	23.0	14.6	57.6	-	20.1	-	-	
Total 25											

I/C Water Laboratory

D. Nandini Mohita

Scientist D

SSA/Analyst/SLA



## DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccoccmms.nic.in>)



Report Number: DPCC/W/STP/24-25/104/1193

Dated 13/8/2024

### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	9	Inlet	7.2	292	80	228	18.4	22.9	12.3	-	Meeting the Standards.
		Outlet	7.4	5	3	28	1.2	2.1	1.5	76	
		OLMS	7.1	8.1	4.2	34.3	-	2.2	-	-	
Total 9											

*Mishra*


I/C Water Laboratory

**Dr. Nandana Mohita**

Scientist 'D'

*A. K. Sharma*

SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



**LIFE**  
Lifestyle for  
Environment

Report Number: DPCC/W/STP/24-25/105/1194

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters										Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml			
1	1	Inlet	7.3	208	114	172	16.8	17.4	19.6	-	-	-	Meeting the Standards.
		Outlet	7.1	2	3	20	0.8	1.2	0.9	58	-	-	
Total 1		OLMS	7.7	0.8	1.7	6.9	-	0.08	-	-	-		

*N. Mita*

I/C Water Laboratory  
**D: Nandita Moitra**  
Scientist 'D'

*SSA/Analyst/SLA*



## DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/106/1195

Dated 13/8/2024

### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		Fecal Coliform MPN/100ml
1	15	Inlet	7.6	212	125	144	23.6	14.5	22.4	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	28	17	76	6.4	2.3	1.4	1800	
		OLMS	7.7	16.7	9.1	60.6	-	13.1	-	-	
Total 15											

*M. Mittal*

I/C Water Laboratory  
M. Mittal  
Scientist 'D'

*S. S. Anand*

SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/107/1196

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

Dated 13/8/2024

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	AmmonicalN (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	2.2	Inlet	7.6	264	167	328	12.8	22.3	25.6	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	70	38	96	4.4	2.7	1.4	1800	
		OLMS	7.7	7.3	4.8	32.9	-	7.9	-	-	
2	3	Inlet	7.4	318	175	420	15.6	20.4	24.7	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	68	43	92	3.6	3.1	1.7	640	
		OLMS	7.6	7.2	5.7	33.3	-	9.3	-	-	
Total 5.2											

*M. Mittal*  
I/C Water Laboratory  
Scientist ID

*S. S. Saha*  
SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/108/1197

Dated 13/8/2024

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

- Name of STP : Yamuna Vihar
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 03.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters										Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml			
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	11.2	16.1	23.7	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.2	192	83	268	1.6	2.1	1.6	-			
		OLMS	7.4	-	9.2	38.0	-	21.4	-	-			
2	10 Ph-2	Inlet	7.3	188	80	252	8.4	16.9	25.6	-	TSS reading not shown in OLMS		
		Outlet	7.6	17	12	52	1.2	1.5	1.2	620			
		OLMS	7.6	8.9	5.9	30.6	-	5.0	-	-			
Total 20													

*M. Mishra*  
 I/C Water Laboratory  
 D. Nandita Yadava  
 Scientist 'D'

*S. Saha*  
 SSA/Analyst/SLA





## DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



**LIFE**  
Lifestyle for  
Environment

Report Number: DPCC/W/STP/24-25/109/ 1198

Dated

13/8/2024

### ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
1	0.66	Inlet	7.5	224	160	296	15.6	17.5	21.9	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.7	33	16	68	1.6	2.4	1.3	1700	
		OLMS	7.0	27.5	18.8	119.4	-	14.4	-		
Total		0.66									

I/C Water Laboratory

*Mishra*  
Dr. Nandita Mohita

Scientist 'D'

*Sharma*  
SSA/Analyst/SLA



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/24-25/110/1199

## ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024

Dated 13/8/2024

- Name of STP : Okhla
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 09.07.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
12		Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	198	114	304	24.8	23.2	20.1	-	
		OLMS	7.6	26	15	80	3.2	3.1	1.6	2200	
16		Outlet	6.6	18.4	8.1	24.6	-	25.4	-	-	Meeting the Standards.
		Outlet	7.3	6	4	36	1.6	2.3	1.8	81	
		OLMS	7.8	9.7	7.5	33.3	-	3.6	-	-	
37		Outlet	7.4	27	12	72	2.5	2.8	1.2	1800	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	7.6	31.9	22.3	79.7	-	19.1	-	-	
		Outlet	7.2	30	13	68	2.4	3.2	1.1	2500	
45		Outlet	7.2	30	13	68	2.4	3.2	1.1	2500	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	6.7	20.7	11.8	59.2	-	-	-	-	
Total 110											

*M. Mohan*

I/C Water Laboratory, Mohira

Scientist 'D'

*S. S. Anand*

SSA/Analyst/SLA



**DELHI POLLUTION CONTROL COMMITTEE**  
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/111/1200

Dated 13/8/2024

**ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024**

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters										Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml			
1	40	Inlet	7.1	252	171	316	18.4	23.1	19.8	-	-		
		Outlet	7.3	24	15	56	3.2	3.4	1.8	420	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.		
		OLMS	9.4	58	32	198	-	59.0	-	-	-		
2	20	Outlet	7.2	18	13	60	3.6	3.0	1.7	1700	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.		
		OLMS	7.6	27.6	18.6	101.1	-	12.7	-	-	-		
Total 60													

I/C Water Laboratory

**D. Nandita Moitra**

Scientist 'D'

SSA/Analyst/SLA

*(Signature)*



**DELHI POLLUTION CONTROL COMMITTEE**  
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/112/1201

**ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2024**

Dated

13/8/2024

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.07.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	5	Inlet	7.7	324	133	432	22.4	22.5	32.3	-	Not meeting the Standards wrt TSS, BOD, COD & fecal coliform.	
		Outlet	7.3	66	40	100	4.8	2.4	1.7	810		
		OLMS	7.6	20.2	13.8	78.1	-	15.9	-	-		
Total 5												

I/C Water Laboratory

**Dr. Nandini Moirva**

Scientist 'D'

SSA/Analyst/SLA

*[Signature]*