



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY

4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/20-21/25-48/3045

Date of Sampling- 03/02/2021

Dated 04/03/2021

S. No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.4	60	88	35
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	7.5	24	80	16
4.	Sweeper Colony Drain	7.2	50	144	36
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	7.1	76	272	59
7.	Tonga Stand Drain	7.3	38	84	17
8.	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9.	Civil Mill Drain	7.2	60	172	45
10.	Power House Drain	7.4	136	260	65
11.	Sen Nursing Home Drain	7.2	102	316	72
12.	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13.	Drain No. 14	7.5	52	116	31
14.	Barapulla Drain	7.2	68	204	42
15.	Maharani Bagh Drain	7.2	88	184	46
16.	Kalkaji Drain	7.0	208	212	74
17.	Sarita Vihar Drain (Mathura Road)	7.1	280	272	112
18.	Tekhhand Drain	7.2	308	376	190
19.	Tuglakabad Drain	7.1	192	360	85
20.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21.	Drain Near Sarita Vihar Bridge	6.4	480	712	250
22.	Shahdara Drain	6.9	340	440	105
23.	Sahibabad Drain	6.9	408	624	285
24.	Indrapuri Drain	7.1	356	560	200

N. Moitra

I/C Water Lab

Dr. NANDITA MOITRA
Scientist 'C'

P. K. Sharma

Scientist 'C'

Suley
08/03/2021

ASL-IT