



DELHI POLLUTION CONTROL COMMITTEE  
WATER LABORATORY  
4<sup>th</sup> FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06  
visit us at : <http://dpcc.delhigovt.nic.in>  
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/21-22/4090

Date of Sampling: - 01/07/2021  
11.08.2021

S. No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	Flow (m <sup>3</sup> /sec)
	Standards	5.5- 9.0	100	250	30	
1.	Najafgarh Drain	7.50	196	384	70	22.27
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	7.44	44	64	20	0.033
4.	Sweeper Colony Drain	7.55	448	544	140	0.019
5.	Magazine Road Drain	7.45	248	416	90	0.12
6.	ISBT Drain	7.23	312	464	100	0.38
7.	Tonga Stand Drain	7.52	32	56	16	0.10
8.	Civil Mill Drain	7.32	192	160	70	0.0616
9.	Sen Nursing Home Drain	7.25	216	432	86	0.437
10.	Drain No. 14	7.47	66	88	31	0.075
11.	Power House Drain	7.45	212	336	90	0.874
12.	Indrapuri Drain	7.21	96	176	42	0.16
13.	Sonia Vihar Drain	8.50	40	104	24	2.63
14.	Kailash Nagar Drain	7.74	260	320	93	0.036
15.	Shastri Park Drain	7.68	128	208	54	0.2
16.	Barapulla Drain	7.35	18	160	28	0.93
17.	Maharani Bagh Drain	7.50	144	240	72	0.048
18.	Old Agra Canal Drain	7.57	192	336	88	1.776
19.	Jaitpur Drain	7.54	106	160	41	0.81
20.	Sarita Vihar Pool	7.49	38	136	29	1.57
21.	Tuglakabad Drain	7.53	60	120	26	1.98
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
24.	Shahdara Drain	7.55	192	446	100	1.78
25.	Sahibabad Drain	7.25	332	592	150	0.37
26.	Molarband Drain	7.57	104	240	52	0.26
27.	Abul Fazal Drain	7.50	140	232	42	0.19

*Maitra*  
Dr. W/C Water Lab  
MANDITA MOITRA  
Scientist 'C'