



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4th FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/21-22/4381

Date of Sampling: - 03.09.2021

Date: 14/10/2021

S. No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	Flow (m ³ /sec)
	Standards	5.5-9.0	100	250	30	
1.	Najafgarh Drain	7.06	248	496	100	39.6
2.	Metcalf House Drain	7.36	44	88	24	0.47
3.	Khyber Pass Drain	6.84	64	120	30	0.11
4.	Sweeper Colony Drain	7.48	52	96	26	0.06
5.	Magazine Road Drain	6.75	76	128	40	0.17
6.	ISBT Drain	7.40	56	104	24	0.58
7.	Tonga Stand Drain	7.38	96	208	42	0.11
8.	Civil Mill Drain	7.24	80	120	30	0.08
9.	Sen Nursing Home Drain	7.27	68	264	58	0.25
10.	Drain No. 14	7.46	84	152	36	0.06
11.	Power House Drain	7.28	116	384	90	1.25
12.	Indrapuri Drain	7.30	108	280	70	0.19
13.	Sonia Vihar Drain	OVERFLOW	OVERFLOW	OVERFLOW	OVERFLOW	OVERFLOW
14.	Kailash Nagar Drain	7.33	92	304	60	0.01
15.	Shastri Park Drain	6.84	56	128	27	0.1
16.	Barapulla Drain	7.04	40	96	26	0.8
17.	Maharani Bagh Drain	7.48	88	232	64	0.3
18.	Old Agra Canal Drain	7.49	96	240	66	0.19
19.	Jaitpur Drain	7.59	100	280	56	0.64
20.	Sarita Vihar Pool	7.14	64	232	48	3.03
21.	Tuglakabad Drain	7.43	88	208	43	0.73
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge	7.55	136	320	70	OVERFLOW
24.	Shahdara Drain	7.57	104	240	60	5.06
25.	Sahibabad Drain	7.46	152	224	56	0.59
26.	Molarband Drain	7.40	176	432	120	0.32
27.	Abul Fazal Drain	7.50	100	160	44	0.17

Mitra
I/C Water Lab

Dr. SANDRA MITRA
Scientist 'C'