



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

## ANALYSIS REPORT OF GTK CETP (2.5 MLD)

Report Number: DPCC/W/CETP/19-20/88/999

9/10/19

- |                                   |                    |
|-----------------------------------|--------------------|
| 1. Name & Address of Ind. / Unit  | GTK CETP (2.5 MLD) |
| 2. Sampling location              | Outlet of CETP     |
| 3. Date of Sampling               | 03.09.19           |
| 4. Sample analyzed and results    | DPCC LAB           |
| 5. Parameters analyzed and result |                    |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.5	5.5-9.0	7.47
2	TSS	624	250	60	100	36.1
3	COD	560	...	120	250	158
4	BOD (3 days at 27° C)	185	...	28	30	17.65
5	Ni	6.0	3	5.0	3	-
6	Cu	ND	3	ND	3	-
7	Zn	8.00	15	0.51	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	0.18	1	0.11	0.1	-
10	Cl	450	...	400	1000	-
11	SO <sub>4</sub>	28.01	...	23.29	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	6.4	20	1.2	10	-
14	TDS	1510	...	1360	2100	-
15	Ammonical Nitrogen as N	54.81	50	12.45	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	5.6	...	2.5	2.8	-

All values are in mg/l except Ph

No Standards


ND- Not Detectable

Flow: 2.5 MLD

*N. Moitra*

SR. SCIENTIST  
Dr. NANDITA MOITRA  
Scientist 'C'

*[Signature]*  
SCIENTIFIC ASSISTANT

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T of Delhi)

4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6visit us at : <http://dpcc.delhigovt.nic.in>**ANALYSIS REPORT OF BAWANA CETP (35 MLD)**

Report Number: DPCC/W/CETP/19-20/89/1000

9/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

BAWANA CETP (35 MLD)

Outlet of CETP

03.09.19

DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	8.0	5.5-9.0	7.3
2	TSS	328	250	42	100	38
3	COD	115	...	92	250	89.2
4	BOD (3 days at 27° C)	310	...	27	30	16.5
5	Ni	5.5	3	6.0	3	-
6	Cu	ND	3	ND	3	-
7	Zn	3.43	15	0.40	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	0.50	1	0.31	0.1	-
10	Cl	1890	...	1750	1000	-
11	SO <sub>4</sub>	53.10	...	48.68	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	12.4	20	2.4	10	-
14	TDS	3750	...	3390	2100	-
15	Ammonical Nitrogen as N	48.71	50	19.84	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	3.8	...	1.8	2.8	-

All values are in mg/l except Ph

No Standards

ND- Not Detectable

Flow: 22.0 MLD

SR. SCIENTIST

Dr. NANDITA MOITRA  
Scientist 'C'

SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE  
(Government of N.C.T of Delhi)  
4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6  
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF NARAYANA CETP (21.6 MLD)

Report Number: DPCC/W/CETP/19-20/90/1000

9/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

NARAYANA CETP (21.6 MLD)

Inlet and Outlet of CETP

18.09.19

DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.9	5.5-9.0	7.8	5.5-9.0	7.13
2	TSS	252	250	38	100	65.2
3	COD	420	...	84	250	71.5
4	BOD (3 days at 27° C)	140	...	28	30	12.9
5	Ni	8.50	3	7.5	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.42	15	0.36	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	520	...	480	1000	-
11	SO <sub>4</sub>	628.51	...	548.73	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	7.2	20	0.8	10	-
14	TDS	1060	...	1050	2100	-
15	Ammonical Nitrogen as N	72.94	50	37.84	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	1.6	...	0.8	2.8	-

All values are in mg/l except pH-


... No Standards

ND- Not Detectable

Flow: 5.28 MLD

*N. Mitra*  
SR. SCIENTIST  
Dr. NANDITA MOITRA  
Scientist 'C'

*[Signature]*  
SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

## ANALYSIS REPORT OF JHILMIL CETP (5.735 MLD)

Report Number: DPCC/W/CETP/19-20/91 | 1002

9/10/19

1. Name & Address of Ind. / Unit **JHILMIL CETP (5.735 MLD)**
2. Sampling location **Outlet of CETP**
3. Date of Sampling **04.09.19**
4. Sample analyzed and results **DPCC LAB**
5. Parameters analyzed and result

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	8.1	5.5-9.0	8.3	5.5-9.0	8.04
2	TSS	188	250	80	100	70.4
3	COD	320	...	112	250	113.8
4	BOD (3 days at 27° C)	110	...	28	30	21.0
5	Ni	7.0	3	5.0	3	-
6	Cu	ND	3	ND	3	-
7	Zn	7.52	15	1.91	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	0.05	1	ND	0.1	-
10	Cl	680	...	550	1000	-
11	SO <sub>4</sub>	490.50	...	180.40	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	7.2	20	3.2	10	-
14	TDS	2010	...	1970	2100	-
15	Ammonical Nitrogen as N	72.84	50	29.83	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	2.4	...	2.0	2.8	-

-All values are in mg/l except Ph

No Standards

ND- Not Detectable

Flow: 16.8 MLD

*Nandita*  
SR. SCIENTIST  
Dr. NANDITA MOITRA  
Scientist 'C'

*[Signature]*  
SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

## ANALYSIS REPORT OF BADLI CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/92 / 1003

9/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

BADLI CETP (12 MLD)

Outlet of CETP

05.09.19

DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	-	5.5-9.0	-	5.5-9.0	-
2	TSS	-	250	-	100	-
3	COD	-	...	-	250	-
4	BOD (3 days at 27° C)	-	...	-	30	-
5	Ni	-	3	-	3	-
6	Cu	-	3	-	3	-
7	Zn	-	15	-	5	-
8	Cr (Total)	-	2	-	2	-
9	Pb	-	1	-	0.1	-
10	Cl	-	...	-	1000	-
11	SO <sub>4</sub>	-	...	-	1000	-
12	Cd	-	1	-	1	-
13	Oil & Grease	-	20	-	10	-
14	TDS	-	...	-	2100	-
15	Ammonical Nitrogen as N	-	50	-	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	-	...	-	2.8	-

All values are in mg/l except Ph

No Standards

ND- Not Detectable

Flow: No Flow


Remarks : CETP plant was found non-operational.

*Nandita*

SR. SCIENTIST

Dr. NANDITA MOITRA  
Scientist 'C'

*[Signature]*  
SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

## ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD)

Report Number: DPCC/W/CETP/19-20/93/1504

9/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MANGOLPURI CETP (2.4 MLD)

Outlet of CETP

11.09.19

DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.8	5.5-9.0	7.9
2	TSS	88	250	44	100	34.4
3	COD	216	...	96	250	71.0
4	BOD (3 days at 27° C)	72	...	28	30	22.4
5	Ni	ND	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	1.93	15	1.09	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	2860	...	2720	1000	-
11	SO <sub>4</sub>	98.75	...	39.42	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	20.8	20	3.2	10	-
14	TDS	3330	...	2860	2100	-
15	Ammonical Nitrogen as N	32.41	50	19.71	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.8	...	2.4	2.8	-

All values are in mg/l except Ph

No Standards

ND- Not Detectable

Flow: 1.78 MLD

*N. Moitra*

SR. SCIENTIST

Dr. NANDITA MOITRA

Scientist 'C'

*[Signature]*  
SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE  
(Government of N.C.T of Delhi)  
4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6  
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF SMA CETP (1.6 MLD)

Report Number: DPCC/W/CETP/19-20/94/1005

9/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

SMA CETP (1.6 MLD)  
Outlet of CETP  
11.09.19  
DPCC LAB


S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.7	5.5-9.0	7.45
2	TSS	164	250	54	100	25.30
3	COD	360	...	72	250	128
4	BOD (3 days at 27° C)	120	...	22	30	10.51
5	Ni	0.5	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	2.72	15	0.73	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	850	...	720	1000	-
11	SO <sub>4</sub>	397.12	...	92.14	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	12.4	20	3.2	10	-
14	TDS	2490	...	2440	2100	-
15	Ammonical Nitrogen as N	48.51	50	38.57	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	2.5	...	2.2	2.8	-

All values are in mg/l except Ph

No Standards

ND- Not Detectable

Flow: 1.5 MLD

  
SR. SCIENTIST  
Dr. NANDITA MOITRA  
Scientist 'C'

  
SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE  
(Government of N.C.T of Delhi)  
4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6  
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD)

Report Number: DPCC/W/CETP/19-20/95/1006

9/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

LAWRENCE ROAD (12MLD)

Inlet and Outlet of CETP

11.09.19

DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.1	5.5-9.0	7.6	5.5-9.0	7.5
2	TSS	220	250	96	100	5.42
3	COD	360	...	160	250	31.41
4	BOD (3 days at 27° C)	120	...	45	30	12.59
5	Ni	ND	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	2.97	15	0.615	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	0.24	1	0.11	0.1	-
10	Cl	1980	...	1720	1000	-
11	SO <sub>4</sub>	120.81	...	94.58	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	7.2	20	1.2	10	-
14	TDS	2690	...	1630	2100	-
15	Ammonical Nitrogen as N	64.89	50	32.73	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	3.2	...	1.2	2.8	-

All values are in mg/l except Ph

No Standards

ND- Not Detectable

Flow: 1.2 MLD

*N. Moha*


SR. SCIENTIST

Dr. NANDITA MOITRA

Scientist 'C'

SCIENTIFIC ASSISTANT





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

## ANALYSIS REPORT OF NARELA CETP (22.5 MLD)

Report Number: DPCC/W/CETP/19-20/97/028

9/10/19

1. Name & Address of Ind. / Unit  
NARELA CETP (22.5 MLD)
2. Sampling location  
Inlet and Outlet of CETP
3. Date of Sampling  
03.09.19
4. Sample analyzed and results  
DPCC LAB
5. Parameters analyzed and result

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	8.2	5.5-9.0	8.2	5.5-9.0	7.75
2	TSS	300	250	46	100	25.6
3	COD	460	...	92	250	51.2
4	BOD (3 days at 27° C)	160	...	26	30	13.3
5	Ni	6.0	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	1.98	15	0.71	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	0.31	1	0.11	0.1	-
10	Cl	915	...	790	1000	-
11	SO <sub>4</sub>	43.62	...	41.73	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	8.4	20	1.2	10	-
14	TDS	2510	...	2400	2100	-
15	Ammonical Nitrogen as N	69.71	50	39.45	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	4.0	...	2.4	2.8	-

All values are in mg/l except Ph

No Standards

ND- Not Detectable

Flow: 7.4 MLD

*N. Moitra*

SR. SCIENTIST

Dr. NANDITA MOITRA  
Scientist 'C'

*[Signature]*  
SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

## ANALYSIS REPORT OF WAZIRPUR CETP (1.5 MLD)

Report Number: DPCC/W/CETP/19-20/96/1007

9/10/19

1. Name & Address of Ind. / Unit WAZIRPUR CETP (1.5 MLD)
2. Sampling location Inlet and Outlet of CETP
3. Date of Sampling 11.09.19
4. Sample analyzed and results DPCC LAB
5. Parameters analyzed and result

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	3.9	5.5-9.0	6.5	5.5-9.0	7.54
2	TSS	532	250	46	100	1.3
3	COD	364	...	72	250	54.7
4	BOD (3 days at 27° C)	116	...	22	30	13.6
5	Ni	8.50	3	ND	3	-
6	Cu	1.53	3	ND	3	-
7	Zn	6.20	15	0.38	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	0.18	1	0.11	0.1	-
10	Cl	540	...	620	1000	-
11	SO <sub>4</sub>	139.85	...	120.75	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	12.4	20	3.2	10	-
14	TDS	2760	...	2440	2100	-
15	Ammonical Nitrogen as N	46.57	50	19.47	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	2.8	...	1.4	2.8	-

All values are in mg/l except Ph

No Standards


ND- Not Detectable

Flow:2.36 MLD

*N. Moitra*  
SR. SCIENTIST

Dr. NANDITA MOITRA  
Scientist 'C'

SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE  
(Government of N.C.T of Delhi)  
4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6  
visit us at : <http://dpcc.delhigovt.nic.in>

ANALYSIS REPORT OF MAYAPURI CETP (3.5 MLD)

Report Number: DPCC/W/CETP/19-20/98 | 1009

09/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MAYAPURI CETP (3.5 MLD)  
Inlet and Outlet of CETP  
18.09.19  
DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	8.0	5.5-9.0	8.1	5.5-9.0	6.9
2	TSS	128	250	52	100	54.8
3	COD	216	...	126	250	114
4	BOD (3 days at 27° C)	72	...	42	30	27.5
5	Ni	ND	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.34	15	0.28	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	720	...	640	1000	-
11	SO <sub>4</sub>	208.75	...	161.34	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	3.2	20	1.2	10	-
14	TDS	2390	...	2130	2100	-
15	Ammonical Nitrogen as N	49.51	50	13.73	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	2.8	...	2.4	2.8	-

All values are in mg/l except Ph

No Standards

ND- Not Detectable

Flow: 3.8 MLD

*N. Moitra*  
SR. SCIENTIST

Dr. NANDITA MOITRA  
Scientist 'C'

*[Signature]*  
SCIENTIFIC ASSISTANT



**DELHI POLLUTION CONTROL COMMITTEE**  
(Government of N.C.T of Delhi)  
4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6  
visit us at : <http://dpcc.delhigovt.nic.in>

**ANALYSIS REPORT OF NANGLOI CETP (12 MLD)**

Report Number: DPCC/W/CETP/19-20/99/10/0

09/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

NANGLOI CETP (12 MLD)

Outlet of CETP

18.09.19

DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	8.2	5.5-9.0	7.8	5.5-9.0	7.17
2	TSS	732	250	114	100	56.6
3	COD	840	...	216	250	46.4
4	BOD (3 days at 27° C)	320	...	72	30	13.2
5	Ni	ND	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	0.75	15	0.67	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	2590	...	2380	1000	-
11	SO <sub>4</sub>	321.57	...	247.59	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	7.2	20	2.4	10	-
14	TDS	4350	...	3210	2100	-
15	Ammonical Nitrogen as N	47.85	50	19.37	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	3.8	...	2.4	2.8	-

All values are in mg/l except Ph

No Standards


ND- Not Detectable

Flow: 2.68 MLD

SR. SCIENTIST

Dr. NANDITA MOITRA  
Scientist 'C'

SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4<sup>th</sup> Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

## ANALYSIS REPORT OF OKHLA CETP (24 MLD)

Report Number: DPCC/W/CETP/19-20/100 | 1011

09/10/19

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

OKHLA CETP (24 MLD)

Inlet and Outlet of CETP

20.09.19

DPCC LAB

S.No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	8.0	5.5-9.0	-
2	TSS	852	250	38	100	-
3	COD	360	...	132	250	-
4	BOD (3 days at 27° C)	120	...	34	30	-
5	Ni	7.0	3	ND	3	-
6	Cu	ND	3	ND	3	-
7	Zn	1.73	15	0.90	5	-
8	Cr (Total)	ND	2	ND	2	-
9	Pb	ND	1	ND	0.1	-
10	Cl	760	...	720	1000	-
11	SO <sub>4</sub>	124.75	...	98.75	1000	-
12	Cd	ND	1	ND	1	-
13	Oil & Grease	12.4	20	3.4	10	-
14	TDS	1320	...	732	2100	-
15	Ammonical Nitrogen as N	52.47	50	32.51	50	-
16	Fluoride	-	15	-	2	-
17	Sulphide	3.4	...	1.9	2.8	-

All values are in mg/l except pH

... No Standards

ND- Not Detectable

Flow: 24 MLD

REMARKD: OLMS was found non-operational.

*Nandita*  
SR. SCIENTIST

Dr. NANDITA MOITRA  
Scientist 'C'

*[Signature]*  
SCIENTIFIC ASSISTANT