


4401/wmc-II  
18/10/2023



**DELHI POLLUTION CONTROL COMMITTEE**  
**WATER LABORATORY**  
 4<sup>th</sup>FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06  
 visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

Dated 18/10/2023

REPORT NO: DPCC/W/D/22-23/342  
 Date of Sampling: -04.10.2023

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.2	90	240	48
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	7.3	82	213	44
7.	Tonga Stand Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
8.	Civil Mill Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9.	SEN Nursing Home Drain	7.4	90	234	42
10.	Drain No. 14	NO FLOW	NO FLOW	NO FLOW	NO FLOW
11.	Power House Drain	7.0	82	186	40
12.	Indrapuri Drain	6.9	96	256	47
13.	Sonia Vihar Drain	7.1	88	192	42
14.	Kailash Nagar Drain	7.4	72	160	35
15.	Shastri Park Drain	7.0	60	154	31
16.	Barapulla Drain	7.3	78	170	38
17.	Maharani Bagh Drain	7.7	86	266	46
18.	Old Agra Canal Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
19.	Jaitpur Drain	7.1	70	208	41
20.	Sarita Vihar Pool	7.5	64	179	37
21.	Tuglakabad Drain	7.2	74	182	39
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	7.4	62	156	32
24.	Shahdara Drain	7.3	100	336	52
25.	Sahibabad Drain	7.2	92	304	47
26.	Molarband Drain	7.6	66	174	36
27.	Abul Fazal Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
28.	Supplementary Drain	7.5	80	208	43

*Nandita*

I/C Water Lab

**Dr. Nandita Moitra**  
 Scientist 'D'