



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/09

1579

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Molarband mini STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **10.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
1	2	Inlet	7.9	328	260	620	32.8	33.6	8.2	Not meeting the Standards w.r.t BOD.
		Outlet	8.0	46	34	92	3.6	11.4	2.6	
		OLMS*	7.42	18.07	26.41	75.57	-	7.42	-	
	Total 2									

I/C LABORATORY


Dr. NANDITA MOITRA

Scientist 'C'

For

*Risha Sharma*

SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/213 1586

21/1/20


## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2019

- 1 Name & Address of Ind./Unit **Coronation Pillar STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **04.12.2019**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-I,II(20)	Inlet	7.4	232	145	396	22.4	26.4	7.2	Not meeting the Standards w.r.t BOD.
		Outlet	7.6	44	36	96	3.2	9.4	2.3	
		OLMS*	-	-	-	-	-	-	-	
	Ph-III(10)	Inlet	7.4	232	145	396	22.4	26.4	7.2	Not meeting the standards w.r.t TSS and BOD.
		Outlet	7.9	64	42	124	3.6	8.9	2.0	
		OLMS*	7.75	51.96	39.04	105.71	-	3.82	-	
Total 30										

*N. Moitra*  
 I/C LABORATORY  
**Dr. NANDITA MOITRA**  
 Scientist 'C'

*Richa Sharma*  
 SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/217 / 1590

21/1/20


## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **DELHI GATE STP NEW**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **10.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I,II(15)	Inlet	7.4	116	65	180	20.4	24.6	6.1	Meeting the Standards.
		Outlet	7.3	4	2	8	0.4	5.6	0.2	
		OLMS*	6.10	6.69	4.74	17.24	-	1.99	-	
Total 15										

*Nandita*  
I/C LABORATORY  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Faz* *Richa Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/226

1599

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER -2019

- Name & Address of Ind./Unit **Keshopur STP new**
- Sampling location **Inlet and Outlet of STP**
- Date of Inspection **12.12.19**
- Samples collected by **DPCC Lab**
- Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				30	20	250	10	50	5	
1	12	Inlet	7.1	196	110	320	22.4	26.4	6.3	Not Meeting the Standards w.r.t TSS & BOD.
		Outlet	7.3	38	26	72	2.0	9.2	0.5	
		OLMS*	7.13	4.29	5.94	3.19	-	1.08	-	
	Total 12									

*Nandita*  
I/C LABORATORY  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Richa Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/225 | 1598

21/12

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Keshpur STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **12.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				50	30	250	10	50	5	
1	40	Inlet	7.4	230	165	496	28.4	31.6	7.8	Not meeting the Standards w.r.t TSS and BOD .
		Outlet	7.6	78	46	124	4.8	14.2	2.9	
		OLMS*	7.56	150.40	66.11	210.56	-	15.0	-	
2	20	Inlet	7.6	280	170	480	36.0	55.7	6.4	Not meeting the Standards w.r.t BOD & TSS.
		Outlet	7.7	56	38	112	5.2	13.6	2.4	
		OLMS*	7.63	120.56	75.27	207.91	-	20.1	-	
	Total 60									

Remarks: OLMS (40 MGD) was found non operational

*N. Moha*  
I/C LABORATORY

*Ficha Sharma*  
SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA  
Scientist 'C'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/219/1592

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Sen Nursing Home (SNH)**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **10.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	250	10	50	5	
1	Phase-I,II(2.2)	Inlet	7.8	204	125	320	22.4	23.8	5.9	Meeting the Standards.
		Outlet	7.6	8	6	24	0.4	4.9	0.2	
		OLMS*	7.55	7.77	5.33	23.81	-	1.58	-	
	Total 2.2									

*Mitra*  
I/C LABORATORY

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA  
Scientist 'C'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006  
 Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/228/1601

21/1/20


## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER - 2019

1. Name & Address of Ind./Unit **Nilothi STP-II**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **12.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Dissolved Phosphate as P (mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
				10	10	250	10	50	5	
1	20	Inlet	7.6	268	175	520	30.4	32.6	6.5	Meeting the Standards.
		Outlet	7.5	8	6	18	0.4	3.6	0.3	
		OLMS*	7.17	7.64	1.47	25.25	-	1.97	-	
	Total 20									

*Nandita*  
 I/C LABORATORY  
**Dr. NANDITA MOITRA**  
 Scientist 'C'

*Pooja Sharma*  
 SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/227

1600

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2019

1. Name & Address of Ind./Unit **Nilothi STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **12.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				10	10	250	10	50	5	
1	40	Inlet	-	-	-	-	-	-	-	STP was found non-opreartional at the time of pmonitoring.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
	Total 40									

*Nandita*  
I/C LABORATORY

*Fari Fida Sharma*  
SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA  
Scientist 'C'





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/229

1602

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2019

1. Name & Address of Ind./Unit **Najafgarh STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **13.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				50	30	250	10	50	5	
	5	Inlet	7.4	344	230	680	32.8	34.6	8.1	Not meeting the standards w.r.t to TSS & BOD.
		Outlet	7.7	78	46	128	4.4	16.4	2.8	
		OLMS*	7.46	39.71	44.03	123.48	-	3.13	-	
	Total 5									

*N. Moitra*  
I/C LABORATORY  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Fizza Shereem*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/214

11587/

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2019

1. Name & Address of Ind./Unit **Rithala STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **04.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				50	30	250	10	50	5	
1	Phase-I(40)	Inlet	8.0	116	60	184	14.4	20.2	5.8	Not meeting the standards w.r.t to TSS and BOD.
		Outlet	8.0	52	36	96	4.4	9.2	2.6	
		OLMS*	7.67	40.52	33.10	103.50	-	11.37	-	
2	Ph-II(40)	Inlet	8.0	116	60	184	14.4	20.2	5.8	Meeting the standards.
		Outlet	7.6	26	14	44	1.6	7.2	0.8	
		OLMS*	6.44	14.09	10.57	45.03	-	13.34	-	
	Total 80									

*Nandita*

I/C LABORATORY

Dr. NANDITA MOITRA  
Scientist 'C'

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/231/1604

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER - 2019

1. Name & Address of Ind./Unit **Pappankalan STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **13.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
1	20	Inlet	7.2	240	160	400	28.4	32.6	7.6	Not meeting the Standards w.r.t TSS & BOD.
		Outlet	7.6	74	46	124	4.0	17.6	1.6	
		OLMS*	6.29	55.33	27.74	78.99	-	5.8	-	
	Total 20									

*Maitra*  
I/C LABORATORY

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA  
Scientist 'C'



**DELHI POLLUTION CONTROL COMMITTEE**  
(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/232 / 1605

21/1/20

**ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2019**

1. Name & Address of Ind./Unit Pappankalan STP-II
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 13.12.19
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	20	Inlet	7.4	168	90	280	20.4	26.4	6.1	Not Meeting the Standards w.r.t TSS.
		Outlet	7.8	12	8	28	0.8	7.2	0.4	
		OLMS*	7.7	5.63	6.05	35.69	-	0.45	-	
Total 20										

*Nandita*  
I/C LABORATORY

Dr. NANDITA MOITRA  
Scientist 'C'

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/215 | 1588

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Rohini STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **04.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	15	Inlet	7.9	308	225	624	30.4	33.2	7.2	Not meeting the Standards w.r.t TSS .
		Outlet	8.0	16	10	32	0.8	7.2	0.4	
		OLMS*	-	-	-	-	-	-	-	
	Total 15									

REMARKS: OLMS was found locked.

I/C LABORATORY

*Nandita*  
**Dr. NANDITA MOITRA**  
Scientist 'C'

For

*Richa Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/216 | 1589

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2019

1. Name & Address of Ind./Unit                      Narela STP
2. Sampling location                                      Inlet and Outlet of STP
3. Date of Inspection                                      09.12.19
4. Samples collected by                                  DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				50	30	250	10	50	5	
1	10	Inlet	7.6	232	165	440	24.4	26.6	6.8	Not Meeting the Standards w.r.t BOD.
		Outlet	7.4	42	34	96	2.4	11.6	2.4	
		OLMS*	7.51	29.71	21.84	88.66	-	4.11	-	
	Total 10									

*N. Moitra*  
I/C LABORATORY

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA  
Scientist 'C'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006  
 Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/221 | 1594

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER - 2019

1. Name & Address of Ind./Unit **Okhla STP New**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **10.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				<b>10</b>	<b>10</b>	<b>250</b>	<b>10</b>	<b>50</b>	<b>5</b>	
1	30	Inlet	8.1	244	165	484	22.4	26.4	7.3	Meeting the Standards.
		Outlet	8.0	4	2	8	0.4	5.2	1.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 30									

REMARKS:  
 OLMS was  
 not working.

*Nandita*  
 I/C LABORATORY

*Pooja Sharma*  
 SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA  
 Scientist 'C'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006  
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/209/1582

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Kondli STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **02.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	25	Inlet	7.3	288	176	520	28.0	32.2	7.3	Not meeting the Standards w.r.t TSS & BOD.
		Outlet	7.4	18	16	44	2.4	9.0	1.1	
		OLMS*	7.55	23.44	10.64	31.94	-	2.28	-	
	Total 25									

*N. Moitra*  
I/C LABORATORY  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Richa Sharma*  
For SR. SCIENTIFIC ASSISTANT





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/210/1583

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER - 2019

1. Name & Address of Ind./Unit **KONDLI STP New**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **02.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
				<b>10</b>	<b>10</b>	<b>250</b>	<b>10</b>	<b>50</b>	<b>5</b>	
1	45	Inlet	7.3	288	176	520	28.0	32.2	7.3	Not Meeting the Standards w.r.t TSS & BOD.
		Outlet	7.4	16	12	44	2.4	8.4	1.2	
		OLMS*	7.65	18.38	9.25	36.70	-	4.49	-	
	Total 45									


*Nandita*

I/C LABORATORY

Dr. NANDITA MOITRA

Scientist 'C'

*Richa Sharma*  
For SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/222 /1595

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Kapashera STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5	Inlet	7.8	420	320	864	34.4	36.8	8.2	Not meeting the Standards w.r.t TSS.
		Outlet	8.0	14	8	24	0.8	7.2	2.8	
		OLMS*	7.79	-	-	-	-	3.69	-	
Total 5										

REMARKS: OLMS was under maintenance\*

I/C LABORATORY

*Nandita*  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Pooja Sharma*  
**SR. SCIENTIFIC ASSISTANT**



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/212 | 1585

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER - 2019


1. Name & Address of Ind./Unit **Yamuna Vihar STP Ph-III**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **02.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				30	20	250	10	50	5	
1	25	Inlet	7.4	480	265	680	32.8	35.6	8.1	Not meeting the Standards w.r.t BOD.
		Outlet	7.5	28	22	68	3.2	12.6	2.8	
		OLMS*	6.77	44.92	39.14	93.68	-	4.37	-	
	Total 25									

*N. Mitra*  
I/C LABORATORY

Dr. NANDITA MOITRA  
Scientist 'C'

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/208 /1581

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Chilla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **02.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	250	10	50	5	
1	9	Inlet	7.2	308	210	552	28.8	32.4	7.4	Meeting the Standards.
		Outlet	7.0	8	6	20	0.8	7.6	0.6	
		OLMS*	7.24	12.13	8.67	33.88	-	3.05	-	
Total 9										

*N. Mitra*  
I/C LABORATORY  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Pooja Sharma*  
Sr. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/207 /1580

21/1/20


## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Akshardham STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **02.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Remarks	
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
				<b>10</b>	<b>10</b>	<b>250</b>	<b>10</b>	<b>50</b>	<b>5</b>	
1	1	Inlet	7.2	244	165	386	22.4	24.6	6.9	Meeting the Standards.
		Outlet	7.5	6	4	16	0.4	6.2	0.3	
		OLMS*	7.24	1.74	1.18	3.72	-	0.56	-	
Total 1										

*N. Moitra*  
I/C LABORATORY  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/224/1597

21/1/20


## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Mehrauli STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				<b>50</b>	<b>30</b>	<b>250</b>	<b>10</b>	<b>50</b>	<b>5</b>	
15		Inlet	7.3	244	165	440	26.4	29.6	8.2	Not meeting the standards w.r.t BOD.
		Outlet	7.5	48	36	104	4.4	13.6	2.8	
		OLMS*	7.55	71.16	25.46	87.30	-	1.65	-	
Total 15										

*N. Mitra*  
I/C LABORATORY  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Pooni* *Richa Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/223 /1596

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Vasant Kunj STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **11.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			7.6	50	30	250	10	50	5	
1	2.2	Inlet	7.6	196	120	360	24.4	27.9	7.6	Not meeting the Standards w.r.t BOD.
		Outlet	7.4	46	34	96	3.2	12.6	1.6	
		OLMS*	7.3	19.62	16.99	64.27	-	4.5	-	
	3	Inlet	7.5	320	260	720	32.4	34.6	8.1	Not Meeting the Standards w.r.t BOD & TSS.
		Outlet	7.7	52	46	120	4.0	16.4	2.4	
		OLMS*	7.54	11.62	7.93	23.47	-	6.60	-	
	Total 5.2									

*Maitra*

I/C LABORATORY

*For - Anha Sharma*  
SR. SCIENTIFIC ASSISTANT

Dr. NANDITA MOITRA  
Scientist 'C'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/211 | 1584

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Yamuna Vihar STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **02.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10	Inlet	7.4	50	30	250	10	50	5	Not Meeting the Standards w.r.t BOD & TSS.
		Outlet	7.3	248	160	480	23.2	25.4	7.5	
		OLMS*	7.25	52	36	96	4.8	11.6	2.4	
2	10	Inlet	7.25	68.94	29.47	127.55	-	7.25	-	Not Meeting the Standards w.r.t BOD & TSS.
		Outlet	8.0	404	240	644	30.4	33.6	7.6	
		OLMS*	7.3	64	42	120	4.8	13.4	2.6	
	Total 20									

I/C LABORATORY

*N. Mitra*  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/220 / 1593

21/1/20


## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit **Okhla STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **10.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l) 50	BOD (mg/l) 30	Parameters				Remarks
						COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P(mg/l) 5	
1	12	Inlet	7.9	288	175	520	32.8	35.2	8.4	Meeting the Standards
		Outlet	8.0	22	16	48	2.4	9.4	0.6	
	OLMS	7.22	26.35	17.32	42.01	-	6.70	-		
	16	Outlet	8.1	14	8	28	2.0	9.2	0.5	Meeting the Standards
		OLMS	7.78	32.58	25.26	53.03	-	2.75	-	
	37	Outlet	8.2	32	24	76	2.8	9.6	0.5	Meeting the Standards
		OLMS	6.45	31.25	19.35	51.96	-	2.02	-	
	45	Outlet	8.1	30	22	64	2.8	9.4	0.6	Meeting the Standards
OLMS		7.42	20.57	12.39	35.44	-	1.88	-		
Total 110										

*Nandita*  
I/C LABORATORY  
**Dr. NANDITA MOITRA**  
Scientist 'C'

*Fida Sharma*  
Sr. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/218 | 1591

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2019

1. Name & Address of Ind./Unit **DELHI GATE STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **10.12.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				<b>10</b>	<b>10</b>	<b>250</b>	<b>10</b>	<b>50</b>	<b>5</b>	
1	Phase-I,II(2.2)	Inlet	7.6	132	70	220	16.4	22.4	5.6	Meeting the Standards.
		Outlet	7.7	8	4	16	0.4	5.2	0.3	
		OLMS*	7.55	7.77	5.33	23.81	-	1.58	-	
	Total 2.2									

*N. Moitra*  
I/C LABORATORY

Dr. NANDITA MOITRA  
Scientist 'C'

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/230/1603

21/1/20

## ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER- 2019

1. Name & Address of Ind./Unit      **Oxidation pond STP**
2. Sampling location                      **Inlet and Outlet of STP**
3. Date of Inspection                        **04.12.19**
4. Samples collected by                      **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
				50	30	250	10	50	5	
6		Inlet	-	-	-	-	-	-	-	Non- operational due to under rehabilitation.
		Outlet	-	-	-	-	-	-	-	
		OLMS*	-	-	-	-	-	-	-	
Total 6										

*N. Moitra*  
I/C LABORATORY

Dr. NANDITA MOITRA  
Scientist 'C'

*Pooja Sharma*  
SR. SCIENTIFIC ASSISTANT