




DELHI POLLUTION CONTROL COMMITTEE
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/20-21/265-288

Date of Sampling- 16/03/2020

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	General Standards	5.5- 9.0	100	250	30
1	Najafgarh Drain	7.8	156	220	84
2	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3	Khyber Pass Drain	7.8	32	72	20
4	Sweeper Colony Drain	7.8	94	160	58
5	Magazine Road Drain	7.9	124	180	72
6	ISBT Drain	7.7	114	180	70
7	Tonga Stand Drain	7.9	110	100	62
8	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9	Civil Mill Drain	7.9	116	200	72
10	Power House Drain	7.7	112	192	68
11	Sen Nursing Home Drain	7.9	68	120	40
12	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13	Drain No. 14	8.0	82	160	54
14	Barapulla Drain	7.5	156	240	92
15	Maharani Bagh Drain	7.4	108	196	78
16	Kalkaji Drain	7.6	158	260	90
17	Sarita Vihar Drain (Mathura Road)	7.6	186	260	110
18	Tehkhand Drain	7.5	252	400	160
19	Tuglakabad Drain	7.8	212	340	120
20	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21	Drain Near Sarita Vihar Bridge	7.6	180	280	110
22	Shahdara Drain	7.8	262	420	160
23	Sahibabad Drain	7.4	408	620	220
24	Indrapuri Drain	7.6	320	420	180

SR. SCIENTIST



For SR. SCIENTIFIC ASSISTANT