



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/21-22/4393

Date: 11/11/2021 Date of Sampling: -04.10.2021

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)	Flow (m ³ /sec)
	Standards	5.5- 9.0	100	250	30	
1.	Najafgarh Drain	7.29	256	272	90	37.48
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	7.19	80	152	36	0.11
4.	Sweeper Colony Drain	7.06	224	384	80	0.06
5.	Magazine Road Drain	7.50	112	176	50	0.15
6.	ISBT Drain	7.27	108	224	56	0.49
7.	Tonga Stand Drain	7.45	140	240	60	0.08
8.	Civil Mill Drain	7.56	188	88	20	0.07
9.	Sen Nursing Home Drain	7.07	244	368	110	0.26
10.	Drain No. 14	7.04	260	320	77	0.06
11.	Power House Drain	7.54	92	192	50	1.28
12.	Indrapuri Drain	7.36	208	312	82	0.19
13.	Sonia Vihar Drain	7.27	268	408	88	3.19
14.	Kailash Nagar Drain	7.18	88	184	44	0.01
15.	Shastri Park Drain	7.26	248	344	86	0.13
16.	Barapulla Drain	7.18	164	184	52	1.74
17.	Maharani Bagh Drain	7.14	72	152	34	0.32
18.	Old Agra Canal Drain	7.23	84	176	44	0.17
19.	Jaitpur Drain	7.54	196	344	82	0.56
20.	Sarita Vihar Pool	7.24	76	152	38	2.65
21.	Tuglakabad Drain	7.18	172	416	97	0.49
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge	7.41	92	160	42	OVERFLOW
24.	Shahdara Drain	7.33	216	416	120	5.06
25.	Sahibabad Drain	7.52	204	480	133	0.52
26.	Molarband Drain	7.03	176	368	90	0.29
27.	Abul Fazal Drain	7.19	96	176	42	0.13

Mishra

I/C Water Lab

5981/2021
11/11/2021

Scientific