



DELHI POLLUTION CONTROL COMMITTEE  
4<sup>th</sup>FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06  
visit us at : <http://dpcc.delhigovt.nic.in>  
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/19-20/145-168

Date of Sampling- 4/10/19

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1	Najafgarh Drain	8.0	140	132	40
2	Metcalf House Drain	7.8	74	60	20
3	Khyber Pass Drain	8.0	110	96	30
4	Sweeper Colony Drain	8.0	200	144	35
5	Magazine Road Drain	7.9	188	156	46
6	ISBT Drain	7.9	298	128	40
7	Tonga Stand Drain	7.7	118	156	50
8	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9	Civil Mill Drain	7.8	212	224	70
10	Power House Drain	8.2	60	216	68
11	Sen Nursing Home Drain	8.1	244	248	76
12	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13	Drain No. 14	8.0	64	48	14
14	Barapulla Drain	7.4	48	76	26
15	Maharani Bagh Drain	7.6	72	160	52
16	Kalkaji Drain	7.7	44	136	34
17	Sarita Vihar Drain (Mathura Road)	7.9	68	132	40
18	Tekhhand Drain	7.9	92	120	38
19	Tuglakabad Drain	7.9	92	216	70
20	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21	Drain Near Sarita Vihar Bridge	7.9	22	64	20
22	Shahdara Drain	7.9	80	184	65
23	Sahibabad Drain	8.0	252	496	160
24	Indrapuri Drain	8.0	84	304	85

SR. SCIENTIST

SR. SCIENTIFIC ASSISTANT