

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**WASTE WATER QUALITY STATUS OF DRAIN**

REPORT NO: DPCC/W/D/2024/ 1027

Date of Sampling: -13.05.2024

Dated 14/06/2024

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
Standards		5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.1	136	272	60
2.	Metcalf House Drain	NO FLOW			
3.	Khyber Pass Drain				
4.	Sweeper Colony Drain	7.5	160	208	72
5.	Magazine Road Drain	NO FLOW			
6.	ISBT Drain	No Sample has been taken due to electric work.			
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain				
9.	SEN Nursing Home Drain	7.2	92	264	60
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	7	172	296	50
12.	Indrapuri Drain	7.4	116	288	50
13.	Sonia Vihar Drain	7.5	148	296	55
14.	Kailash Nagar Drain	No Sample has been taken. Road was blocked due to storm.			
15.	Shastri Park Drain	7.4	76	172	40
16.	Barapulla Drain	7.2	108	288	50
17.	Maharani Bagh Drain	7.1	84	272	50
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	7.5	112	292	55
20.	Sarita Vihar Pool	NO FLOW			
21.	Tuglakabad Drain	Sample obtainment not possible.			
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)				
24.	Shahdara Drain	7.5	156	360	80
25.	Sahibabad Drain	7.4	130	344	60
26.	Molarband Drain	TRAPPED			
27.	Abul Fazal Drain	7.6	96	264	70
28.	Supplementary Drain	Sample couldn't be obtained due to metro construction work.			

I/C WATER LAB

Dr. Nandita Moitra

Scientist 'D'

SSA/Analyst/SLA