



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/766/ 669

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 13.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	70 MGD	Inlet	7.6	255	205	384	13.2	20.1	25.2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.4	28	16	64	3.2	2.1	1.9	
	OLMS	6.5	-	5.6	44.8	-	1.8	-	TSS readings not shown in OLMS	
Total 70										

Signature

DPCC
LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <http://www.dpccomms.nctn.in>)



Report Number: DPCC/W/STP/23-24/2671 670

Dated 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Coronation Pillar
- Sampling location : Inlet and outlet of STP
- Date of inspection : 13.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-II (20)	Inlet	7.6	296	90	368	10.4	24.3	20.1	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	30	20	64	3.6	2.2	1.9	
		OLMS	7.5	13.9	7.9	47.8	-	6.0	-	
2	Ph-II (10)	Inlet	7.5	220	115	352	8.4	22.3	16.4	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.2	15	14	60	4	1.9	1.5	
		OLMS	-	-	-	-	-	-	-	
TOTAL 30										

Mandita

Dr. Mandita Mishra
Scientist 'D'
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/268/ 671

Dated 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Delhi Gate (New)
- Sampling location : Inlet and Outlet of STP
- Date of inspection : 09.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Private-EU(115)	Inlet	7.2	140	95	80	2	21.6	9.6	Meeting the Standards.
		Outlet	7.4	6	4	24	1.2	1.2	0.9	
		AUGS	7.7	6.9	5.0	23.9	-	3.9	-	
Total IS										

Alkshay
I/C LABORATORY

Dr. Nandita Mohi
Scientists 'B'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/269/ 672

Dated: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Delhi Gate (Old)
- Sampling location : Inlet and Outlet of STP
- Date of inspection : 09.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
Ph-1 & II (2,2)		Inlet	7.3	152	135	176	4	23.2	11.3	Meeting the Standard.
		Outlet	7.2	8	6	48	1.6	2	1.1	
		QUMS	7.2	5.0	2.0	15.3	-	11	-	
Total 2,2										

I/C LABORATORY

Mishra

Dr. Vandita Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccenmcs.nic.in>)



Report Number: DPCC/W/STP/23-24/270/ 673

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Keshopur STP (New)
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 13.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sf. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	12	Inlet	7.5	240	160	352	17.2	20.3	20.5	Not Meeting the standards wrt TSS, BOD & COD.	
		Outlet	7.2	18	12	52	1.6	1.3	1.1		
		OLMS	7.3	8.3	5.4	29.3	-	4.0	-		
Total 12											

Signature
I/C LABORATORY

Dr. Vandana Mohita
Deputy Director



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccommsnic.in>)



Report Number: DPCC/W/STP/23-24/221/ 694

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 09.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1 (2.2)	Phase-I,II	Inlet	7.4	240	165	240	4.4	20.2	19.5	Meeting the Standards
		Outlet	7.7	2	7	24	2	1.2	1.8	
		OU/S	6.7	5.8	6.7	25.0	-	0.9	-	
Total 2.2										

W/C LABORATORY

Signature

Dr. Vandita Mohita

Scientist D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/2721 675

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.2	164	120	384	13.6	11.5	10.7	Meeting the standards
		Outlet	7.4	10	7	36	2.8	1.8	1.4	
Total 20		OLMS	7.5	8.2	8.9	42.2	-	2.2	-	

Signature

I/C LABORATORY
Dr. Mandita Mohita
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommission.in>)



Report Number: DPCC/W/STP/23-24/773/ 676

Dated 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 16.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40	Inlet	7.5	206	100	336	15.6	21.8	25.8	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.7	34	25	72	3.6	2.9	1.6	
		OUMS	7.9	22.8	17.1	100.6	-	14.3	-	
Total 40										

I/C LABORATORY

M. Mittal

Dr. Mandita Moitra

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number DPCC/M/STP/23-24/274/ 677

Dated 07/03 2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 16.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results : 2

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.5	248	105	304	14	21.1	9.8	Not meeting the standards wrt TSS, BOD and COD
		Outlet	7.7	30	18	80	2.4	2.5	1.6	
		OUMS	8.2	21.9	16.7	102.6	-	12.8	-	
Total 5										

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.dcl.in>)



Report Number: DPCC/W/STP/23-24/275/ 678

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Rithala
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 20.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-1(40)	Inlet	6.5-9.0	10	10	50	10	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLWS	-	-	-	-	-	-	-	
2	Ph-1(40)	Inlet	7.2	204	130	320	10.8	10.8	5.4	Meeting the standards
		Outlet	7.5	8	7	28	3.2	2.6	1.12	
		OLWS	7.4	10.4	7.6	37.2	-	9.2	-	
Total BC										

M. Kishor



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctm.nic.in>)



Report Number: DPCC/W/STP/23-24/276/ **679**

Dated **07/03/2024**

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results : :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	23	Inlet	7.6	204	125	336	17.6	22.3	23.6	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.8	26	20	60	3.6	2.6	2.6	
		QUMS	7.6	18.5	14.7	100.8	-	10.9	-	
Total 20										

Mishra

I/C LABORATORY

Dr. Nandita Mishra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctmssr.in>)



Report Number: DPCC/W/STP/23-24/2771 680

Dated: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
20		Inlet	7.8	154	115	252	14.4	20.7	19.6	Meeting the Standards.
		Outlet	7.3	8	5	40	2	1.8	1.7	
Total 20		OLMS	7.6	6.5	5.1	30.2	-	1.4	-	

Mishra

I/C LABORATORY

Dr. Nandita Mishra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kushnere Gate, Delhi 110006
(Visit us at <http://www.dpccnctms.dcl.in>)



Report Number DPCC/W/STR/23-24/278/ 681

Dated 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.5	304	155	296	13.6	21.3	31.1	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.3	26	18	52	2.4	3.1	2.5	
Total 15		OLMS	7.7	23.6	13.7	54.0	-	17.8	-	

M. Mohan
I/C LABORATORY

Dr. Nandita Moitra
Scientist - D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccl.com.nic.in>)



Report Number: DPCC/W/STP/23-24/279/ 682

Dated 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.2	168	50	176	5.6	12.3	7.3	
		OLMS	7.6	26	18	60	1.2	1.3	1.1	
	Total 10		12.5	9.4	6.3	42.0	-	14.9	-	

Mishra

I/C LABORATORY

Dr. Nareeta Mohita

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccenmms.nic.in>)



Report Number: DPCC/W/STP/23-24/280/ **683**

Date: **07/03/2024**

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Okhla New
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 05.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	30	Inlet	7.4	188	50	240	8.8	14.3	21.5	Meeting the Standards.
		Outlet	7.7	10	7	40	1.5	1.3	1.4	
		OLMS	7.8	5.8	4.5	24.2	-	0.7	-	
Total 30										

M. Anshu
 WPC LABORATORY
 Dr. Mandita Mishra
 Scientist 'C'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110016
 (Visit us at <https://www.dpccocemc.nic.in>)



Report Number: DPCC/W/STP/23-24/281/ 684

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 09.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I (10)	Inlet	7.1	216	102	256	8.4	30.3	29.6	Meeting the standards.
		Outlet	7.4	8	6	32	2	2.2	1.5	
		QWS	7.7	6.4	6.9	31.3	-	2.3	-	
2	Ph-II (25)	Outlet	7.5	6	5	32	0.8	1.6	1	Meeting the standards
		QWS	-	-	-	-	-	-	-	
3	Ph-III (10)	Outlet	7.2	6	5	24	4	1.9	1.4	Meeting the standards.
		QWS	7.4	10.4	4.1	52.7	-	5.3	-	
Total 45										

Mishra

Dr. Mandita Mohita
 Scientist-III



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRF Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocemissnctn.in>)



Report Number: DPCCW/STP/23-24/292/ 685

Dated 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 09.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	Ph-IV (45)	Inlet	7.1	164	150	209	5.6	21.6	23.5	Not Meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.4	28	14	60	1.6	1.5	1.2	
Total 45		OLMS	-	-	-	-	-	-	OLMS was non-functional	

I/C LABORATORY

Mishra

Dr. Nandita Mohita

Scientist VI



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.in>)



Report Number: DPCC/W/STP/23 24/289/ 686

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Kapasahera
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 12.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.4	240	88	256	4.4	20.9	9.5	Meeting the standards.
		Outlet	7.5	8	6	32	1.6	2.4	1.3	
Total 5		OLWS	7.4	9.6	6.6	30.0	-	2.9	-	

Mishra
LABORATORY

Dr. Vandita Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number DPCC/W/STP/23-24/284/ 687

Dated 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Yamuna Vihar Ph-III
- Sampling location : Inlet and Outlet of STP
- Date of inspection : 14.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	25	Inlet	7.6	200	115	248	5.2	17.2	22.3	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.5	30	16	40	1.6	1.2	1.6	
		OLWS	7.9	23.3	14.3	57.2	-	16.4	-	
Total: 25										

M. Mishra

Dr. Manoj Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/285/ 688

Dated

07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	9	Inlet	7.3	215	70	192	6.8	22.5	14.3	Meeting the Standards.
		Outlet	7.7	10	7	48	2.8	1.9	1.5	
		OLWS	7.2	6.6	5.0	26.7	-	1.5		
Total										

Signature

I/C LABORATORY

Dr. Nandita Mishra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/286/ 689

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 09.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	1	Inlet	7.2	232	95	224	4.4	14.1	16.5	Meeting the Standards.
		Outlet	7.6	6	4	24	1.6	1.3	1.5	
Total 1		OLMS	7.6	0.7	1.3	5.7	-	0.1	-	

I/C LABORATORY

Dr. Nandita Moitra
Scientist - I



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommission.in>)



Report Number: DPCC/W/STP/23-24/257/ 690

Date: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 12.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
3	15	Inlet	7.6	116	110	272	15.6	11.3	21.2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.8	36	19	56	2	1.5	1.8	
		OLWS	7.3	15.6	9.0	51.9	-	6.6	-	
Total 15										

I/C LABORATORY

Dr. Manisha Motra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/288/ 691

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

Date:

- Name of STP : Vasant Kunj
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 12.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	2.2	Inlet	7.6	228	180	448	20	18.5	25.5	Not meeting the standards w.r.t TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	30	21	64	3.6	2.5	2.9	
2	3	OLMS	7.8	6.7	5.8	29.0	-	2.3	-	Not meeting the standards w.r.t TSS, BOD, COD & Dissolved Phosphate.
		Inlet	7.5	296	165	256	7.6	18.2	22.9	
		Outlet	7.7	36	26	56	2	12.3	2.2	
		OLMS	7.4	9.2	5.0	151.6	-	9.1	-	
Total S.2										

Mishra

I/C LABORATORY

Dr. Nandita Mishra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommission.in>)



Report Number: DPCC/W/STP/23-24/288/ 692

Dated

07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 14.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10 Pp-1	Inlet	7.4	168	100	164	2.8	13.3	21.2	Not meeting the standards w.r.t TSS.
		Outlet	7.3	22	8	36	0.8	2.1	2.2	
		OLMS	7.7	-	9.4	49.9	-	18.1	-	
2	10 Ph-2	Inlet	7.6	132	85	224	6.8	12.8	16.9	Not meeting the standard w.r.t TSS.
		Outlet	7.2	18	10	40	1.6	1.8	1.7	
		OLMS	-	-	-	-	-	-	-	
Total 20										

Mishra

I/C LABORATORY
Dr. Mandita Mishra
Senior Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommsnct.in>)



Report Number: DPCC/W/SI/P/23-24/11/ 693

Dated 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	0.65	Inlet	7.3	320	150	336	5.2	24.8	22.1	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.6	30	21	64	0.8	1.2	1.2	
Total Q.66		QUMS	7.6	30.5	20.7	126.3	-	13.6	-	

Mishra

V/C LABORATORY

Dr. NANDINI MONTA
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommission.in>)



Report Number: DPCC/W/STP/23-24/250/ 694

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

Date: 07/03/2024

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results : :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
12		Inlet	7.2	252	125	240	16.3	16.2	14.6	Not meeting the Standards wrt TSS.
		Outlet	7.3	16	10	48	1.6	1.8	1.5	
		CLMS	8.1	26.3	13.3	62.7	-	17.2	-	
16		Outlet	7.4	8	4	32	1.2	1.2	1.3	Meeting the Standards. CLMS was non functional
		CLMS	-	-	-	-	-	-	-	
		Outlet	7.7	38	18	40	2.8	1.1	2.4	
37		CLMS	7.6	9.6	6.7	27.8	-	2.3	-	Not meeting the Standards wrt TSS, BOD & COD
		Outlet	7.9	36	19	56	1.6	1.6	2.2	
		CLMS	7.5	20.5	9.7	56.1	-	8.4	-	
Total 110										

M. Mishra

I/C LABORATORY
Dr. Manjita Mishra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/291/ 695

Dated: 07/03/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

- Name of STP : Keshopur
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 13.02.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40	Inlet	7.1	184	115	224	19.2	25.2	19.6	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.7	36	21	64	2	1.4	1.6	
		OLWS	11.3	75	43	231	-	19.5	-	
2	20	Outlet	7.4	26	13	52	2.4	3.5	1.8	Not meeting the Standards wrt TSS, BOD & COD.
		OLWS	-	-	-	-	-	-	-	
Total 60										OLWS was Non functional

I/C LABORATORY

Dr. Vandana Wajira

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/2024

696

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2024

Dated

07/03/2024

1. Name of STP : Ghikoriani
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.02.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	5	Inlet	7.4	132	66	169	4.4	10.5	20.6	Not meeting the Standards w.r. TSS & BOD.
		Outlet	7.6	28	17	46	1.5	1.7	1.6	
Total 5		QUMS	7.3	21.1	13.6	27.1	-	6.4	-	

M. Mohan

Dr. Vandana Mohra

Scientist D