

	<b>DELHI POLLUTION CONTROL COMMITTEE</b> <b>WATER LABORATORY</b> <b>4<sup>th</sup>FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06</b> visit us at : <a href="http://dpcc.delhigovt.nic.in">http://dpcc.delhigovt.nic.in</a>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2023/ 287  
 Date of Sampling: -04.09.2023

*Dated: 21/09/2023*

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.4	88	208	44
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	7.5	80	196	40
7.	Tonga Stand Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
8.	Civil Mill Drain	7.1	94	248	42
9.	SEN Nursing Home Drain	7.3	96	234	46
10.	Drain No. 14	NO FLOW	NO FLOW	NO FLOW	NO FLOW
11.	Power House Drain	7.2	78	176	38
12.	Indrapuri Drain	6.7	50	266	45
13.	Sonia Vihar Drain	6.9	82	256	50
14.	Kalish Nagar Drain	7.0	68	168	34
15.	Shastri Park Drain	7.4	56	160	28
16.	Barapulla Drain	7.2	70	248	37
17.	Maharani Bagh Drain	7.1	84	236	47
18.	Old Agra Canal Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
19.	Jaitpur Drain	7.6	72	192	40
20.	Sarita Vihar Pool	7.2	60	170	35
21.	Tuglakabad Drain	7.0	68	176	37
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	7.5	56	144	29
24.	Shahdara Drain	7.4	102	296	56
25.	Sahibabad Drain	7.2	98	280	50
26.	Moharbanu Drain	7.0	60	170	35
27.	Abul Fazaal Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
28.	Supplementary Drain	7.3	74	186	40

*Mishra*  
 I/C Water Lab

Dr. Mandita Mishra  
 Scientist