



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T of Delhi)

4th Floor I.S.B.T. Building Kashmiri Gate Delhi-6

visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/20-21/409-432

2696

Date of Sampling- 02/11/20

11-11-20

S. No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1	Najafgarh Drain	7.6	60	96	35
2	Metcalf House Drain	No Flow	No Flow	No Flow	No Flow
3	Khyber Pass Drain	7.6	56	112	29
4	Sweeper Colony Drain	7.6	68	126	38
5	Magazine Road Drain	7.6	40	104	28
6	ISBT Drain	7.5	126	232	74
7	Tonga Stand Drain	7.4	74	108	32
8	Moat Drain	No Flow	No Flow	No Flow	No Flow
9	Civil Mill Drain	7.5	100	168	58
10	Power House Drain	7.4	76	156	48
11	Sen Nursing Home Drain	7.4	84	192	65
12	Drain No. 12A	No Flow	No Flow	No Flow	No Flow
13	Drain No. 14	7.3	96	112	34
14	Barapulla Drain	7.3	36	60	18
15	Maharani Bagh Drain	7.4	80	156	46
16	Kalkaji Drain	7.4	196	276	95
17	Sarita Vihar Drain (Mathura Road)	7.4	100	196	60
18	Tekhhand Drain	7.5	272	428	140
19	Tuglakabad Drain	7.5	72	108	64
20	Drain Near LPG Bottling Plant	No Flow	No Flow	No Flow	No Flow
21	Drain Near Sarita Vihar Bridge	7.5	96	152	52
22	Shahdara Drain	7.6	140	248	78
23	Sahibabad Drain	7.6	264	440	145
24	Indrapuri Drain	7.6	148	268	85

Nandita

SR. SCIENTIST

Dr. NANDITA MOITRA
Scientist 'C'

Arav

SR. SCIENTIFIC ASSISTANT