



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemns.nic.in>)



Report Number: DPCC/W/STP/23-24/185 / 448

Dated 04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

- 1. Name of STI : Coronation Pillar
- 2. Sampling location : Inlet and outlet of STP
- 3. Date of inspection : 17.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	70 MGD	Inlet	7.1	268	175	368	12	20.6	26.9	Meeting the standards.
		Outlet	7.5	8	5	28	3.2	2.5	1.6	
		OLTS	-	3.4	3.3	30.0	-	-	-	pH & Ammonical Nitrogen readings not shown in OLTS
Total 70										

*N. K. Singh*

I/C LABORATORY

Dr. Nand Lal Mittal

Signature

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
 Kashmere Gate, Delhi 110006  
 (Visit us at <https://www.dpccocmms.nic.in>)

Report Number: DPCC/W/STP/23-24/186 **1449**Dated **4/12/23****ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023**

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 17.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II (20)	Inlet	7.6	296	90	368	10.4	24.3	20.1	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	30	20	64	3.6	2.2	1.9	
		OLMS	7.5	20.6	13.7	73.3	-	7.1	-	
2	Ph-III (10)	Inlet	7.5	220	115	352	8.4	22.3	16.4	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.2	16	14	60	4	1.8	1.5	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 30										

*N. Mittal*

I/C LABORATORY

Dr. Nandita Mittal  
Scientist D



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/187/450

Dated 04/12/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I,II(15)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.7	144	85	112	7.6	19.9	9.5	
		OLMS	7.3	10	7	32	1.6	1.7	1.5	
Total 15		OLMS	-	-	-	-	-	-	-	OLMS was non functional

*N. Mohita*  
I/C LABORATORY

Dr. Nandita Mohita  
Scientist II

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/188 ) 451

Dated: 4/12/23

**ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023**

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
Phase-I,II(2.2)		Inlet	7.8	164	120	240	3.6	23.2	11.5	Meeting the Standard.
		Outlet	7.2	10	9	40	1.2	2.3	1.3	
		OLMS	7.3	5.0	2.0	15.0	-	1.1	-	
Total 2.2										

I/C LABORATORY

**Dr. Nandita Moitra**  
Scientist 'D'





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/189 1452

Dated: 04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P(mg/l)
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.6	244	170	384	13.6	21.8	21.1	Not Meeting the standards wrt TSS, BOD & COD.
		Outlet	7.9	26	17	64	4	1.6	1.8	
		OLMS	7.0	6.6	4.9	27.8	-	2.3	-	
Total 12										

*Nandita*  
I/C LABORATORY

Dr. Nandita Paultra  
Scientist 'B'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/23-24/190 **1453**

Dated **4/12/2023**

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	Phase-I,II (2.2)	Inlet	7.6	236	150	208	4.8	19.5	19.1	Meeting the Standards
		Outlet	7.3	6	5	24	1.5	1	1.3	
		OLMS	6.4	6.0	3.9	25.6	-	1.4	-	
Total 2.2										

*Nandita*  
I/C LABORATORY

Dr. Nandita Moitra  
Scientist II



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



**LiFE**  
Lifestyle for Environment

Report Number: DPCC/W/STP/23-24/191 / 454

Dated 4/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P (mg/l) 2
1	20	Inlet	7.2	164	120	384	13.6	11.5	10.7	Meeting the standards
		Outlet	7.4	10	7	36	2.8	1.8	1.4	
		OLMS	6.5	11.5	5.7	38.6	-	2.3	-	
Total 20										

*Nandita*  
I/C LABORATORY

Dr. Nandita Mohtra  
Scientist D

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
 Kashmere Gate, Delhi 110006  
 (Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/23-24/192 | 455

Dated 4/12/2023

**ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023**

1. Name of STP : Nilothi  
 2. Sampling location : Inlet and Outlet of STP  
 3. Date of Inspection : 22.11.2023  
 4. Samples collected by : DPCC Lab  
 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	40	Inlet	7.6	208	100	336	15.6	21.8	25.8	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.7	34	25	72	3.6	2.9	1.6	
		OLMS	-	-	-	-	-	-	-	-
Total 40										

*Nandita*  
 I/C LABORATORY

**Dr. Nandita Moitra**  
 Scientist D



**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/23-24/193 | 456

Dated 4/12/2023

**ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023**

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	5	Inlet	7.5	248	105	304	14	21.1	9.8	Not meeting the standards wrt TSS, BOD and COD
		Outlet	7.7	30	19	80	2.4	2.5	1.6	
		OLMS	7.6	21.0	14.8	80.0	-	15.3	-	
Total 5										

*N. Mitra*  
I/C LABORATORY

Dr. Nandita Mitra  
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
 Kashmere Gate, Delhi 110006  
 (Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/194 | 457

Dated: 04/12/2023

**ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023**

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-		
		OLMS	-	-	-	-	-	-		
2	Ph-II(40)	Inlet	7.2	204	130	320	10.8	10.5	6.4	Meeting the standards
		Outlet	7.5	8	7	28	3.2	2.6	1.2	
		OLMS	7.4	8.2	6.0	26.9	-	7.0	-	
Total 80										

*Mandita*  
 I/C LABORATORY Mandita Moitra

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
 Kashmere Gate, Delhi 110006  
 (Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/195 | 458

Dated 04/12/2023

**ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023**

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	20	Inlet	7.4	232	130	352	18.8	22.8	23.8	Not meeting the Standards wrt TSS, BOD COD & Dissolved Phosphate.
		Outlet	7.5	40	21	104	5.2	2.9	2.7	
		OLMS	7.5	24.7	18.8	109.0	-	14.1	-	
Total 20										

*N. Mittal*  
 I/C LABORATORY

**Dr. Nandita Moitra**  
 Scientist (B)



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/196 /459

Dated 04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

- 1. Name of STP : Pappankalan Ph-II (New)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 22.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.3	158	120	384	13.2	20.9	19.5	Meeting the Standards.
		Outlet	7.8	10	6	36	4	1.9	1.5	
		OLMS	7.3	6.6	4.9	26.1	-	1.3	-	
Total 20										

*Nandita*  
I/C LABORATORY

Dr. Nandita Motilal  
Scientist D





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/23-24/197/460

Dated 04/12/23

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 08.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	15	Inlet	7.7	308	170	312	9.2	21.5	11.5	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.8	28	13	60	5.6	3.8	1.7	
		OLMS	7.6	23.0	13.2	62.7	-	17.1	-	
Total 15										

*Nandita*

I/C LABORATORY

Dr. Nandita Moitra

Scientist (I)



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmns.nic.in>)



Report Number: DPCC/W/STP/23-24/198/461

Dated 04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	10	Inlet	7.3	188	75	128	8.4	15.6	9.6	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.7	26	11	52	2.4	1.1	1.3	
		OLMS	7.2	8.8	6.0	38.3	-	9.0	-	
Total 10										

*N. Moitra*  
I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/199 **1462**

Dated **04/12/2023**

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

- 1. Name of STP : Okhla New
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 03.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P (mg/l) 2
1	30	Inlet	7.4	188	90	248	8.8	14.3	21.5	Meeting the Standards.
		Outlet	7.7	10	7	40	1.6	1.3	1.4	
		OLMS	6.3	5.6	4.5	24.1	-	1.0	-	
Total 30										

*Nandita*  
I/C LABORATORY

**Dr. Nandita Moitra**  
Scientist II

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/200 | 463

Dated 04/12/2023

**ANALYSIS REPORT OF STP**

- |                                    |   |                         |
|------------------------------------|---|-------------------------|
| 1. Name of STP                     | : | Kondli                  |
| 2. Sampling location               | : | Inlet and Outlet of STP |
| 3. Date of Inspection              | : | 09.11.2023              |
| 4. Samples collected by            | : | DPCC Lab                |
| 5. Parameters analyzed and results | : |                         |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Faecal Coliform as FC (MPN/100ml)	
			6.5-9.0	10	10	50	10	5	2	100	
1	Ph-I (10)	Inlet	7.4	220	96	256	4.4	27.5	25.6	4 × 10 <sup>2</sup>	Meeting the standards.
		Outlet	7.6	8	5	32	2	2.5	1.9	27	
		OLMS	-	-	-	-	-	-	-	-	
2	Ph-II (25)	Outlet	7.8	10	5	32	1.2	1.8	1.1	80	Meeting the standards
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional
3	Ph-III (10)	Outlet	7.7	6	4	24	4.1	1.6	1.7	90	Meeting the standards.
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional
Total 45											

*N. Moitra*

I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/WSTP/23-24/201 /464

Dated 04/12/23

## ANALYSIS REPORT OF STP

- 1. Name of STP : Kondli New
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 09.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Feecal Coliform as FC (MPN/100ml)	
			6.5-9.0	10	10	50	10	5	2	100	
1	Ph-IV (45)	Inlet	7.5	216	185	256	6.8	20.6	24.6	5×10 <sup>2</sup>	Not Meeting the Standards wrt TSS, BOD COD & Feecal Coliform
		Outlet	7.3	36	19	76	3.6	1.9	1.5	170	
		OLMS	7.5	19.3	10.0	37.1	-	22.1	-	-	
Total 45											

*Nandita*  
 I/C LABORATORY  
 Dr. Nandita Mehta  
 Scientist D



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110906  
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/202 / 465

Dated 4/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	
1	5	Inlet	7.4	212	82	220	4.4	22.8	Not Meeting the standards wrt TSS & BOD.
		Outlet	7.6	10	5	48	2	2.1	
		OLMS	7.4	9.7	5.6	29.81	-	2.5	
Total 5									

*Nandita*  
Dr. Nandita Mahtia  
Scientist 'D'



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/23-24/203 | 466

Dated 04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	25	Inlet	7.3	200	125	184	5.6	16.3	24.2	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.8	28	15	48	2	1.2	1.9	
		OLMS	7.2	22.8	11.3	57.8	-	10.5	-	OLMS was non-functional
Total 25										

LABORATORY

*N. Mitra*  
Dr. Nandita Mohita  
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
 Kashmere Gate, Delhi 110006  
 (Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/204 /467

Dated 04/12/2023

**ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023**

1. Name of STP : Chilla  
 2. Sampling location : Inlet and Outlet of STP  
 3. Date of Inspection : 09.11.2023  
 4. Samples collected by : DPCC Lab  
 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.2	204	68	176	7.2	22.3	14.1	Meeting the Standards.
		Outlet	7.6	8	6	40	2	1.7	1.1	
		OLMS	7.0	5.3	3.0	22.2	-	1.2	-	
Total 9										

*N. Mittal*

I/C LABORATORY  
 Dr. Nandini Mittal  
 Scientist-I





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/205 / 468

Dated 04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	1	Inlet	7.2	232	95	224	4.4	14.1	16.5	Meeting the Standards.
		Outlet	7.6	6	4	24	1.6	1.3	15	
		OLMS	7.6	0.9	1.7	7.2	-	0.1	-	OLMS was non-functional
Total 1										

I/C LABORATORY

Dr. Nandita Moitra  
Scientist D



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/206 /469

Dated 04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

- 1. Name of STP : Mehrauli
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 03.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
1	15	Inlet	6.8-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.8	148	95	240	4.4	11.1	21.5	
		OLMS	7.6	30	20	56	1.2	1.8	1	
Total 15	7.4	24.0	7.4	49.1	-	8.5	-			

*Nandita*  
 I/C LABORATORY  
 Dr. Nandita



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/207 / 470

Dated 04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

- 1. Name of STP : Vasant Kunj
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 03.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	2.2	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.6	232	180	368	15.6	18.2	23.6	
		OLMS	7.0	6.0	4.4	23.1	2	1.6	2.8	
2	3	Inlet	7.5	280	145	304	4	17.1	22.5	Not meeting the standards wrt TSS & BOD.
		Outlet	7.8	34	13	40	1.6	2.1	1.4	
		OLMS	7.2	6.0	3.9	18.3	-	2.9	-	
Total 5.2										

*N. Mittal*

Dr. Nandita Mittal  
Scientist D



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/23-24/208 **1471**

Dated **04/12/2023**

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.5	184	95	104	4	13.9	23.7	Not meeting the standards wrt TSS & BOD .
		Outlet	7.4	26	11	48	1.6	2.9	1.9	
		OLMS	7.4	11.0	7.0	50.2	-	10.0	-	
2	10 Ph-2	Inlet	7.5	120	90	144	8	7.2	17.1	Not meeting the standard wrt TSS,BOD & Dissolved Phosphate..
		Outlet	7.7	18	11	48	1.6	1.2	7.3	
		OLMS	6.9	7.2	4.5	22.5	-	2.5	-	
Total 20										

*Mitra*

I/C LABORATORY

Dr. Nandita Mitra

SECRETARY





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/8 1472

Dated 4/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

- 1. Name of STP : Molarband (Mini STP)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 03.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P(mg/l) 2
1	0.66	Inlet	7.6	340	170	368	6.4	25.2	23.5	Not meeting the Standards wrt TSS, BOD, COD.
		Outlet	7.4	36	23	80	1.6	1.5	1.3	
		OLMS	7.0	29.5	14.9	11.0	-	9.8	-	
Total 0.66										

*N. Mittal*  
I/C LABORATORY

Dr. Nandita Mittal  
Scientist D



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/209 **1473**

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

Dated **04/12/2023**

- 1. Name of STP : Okhla
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 03.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks		
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P(mg/l) 2	
1	12	Inlet	7.1	232	120	224	4.8	15.6	12.6	Not meeting the Standards wrt TSS & BOD.	
		Outlet	7.5	24	11	40	1.2	1.1	1.2		
		OLMS	7.2	24.0	12.7	60.0	-	22.2	-		
	16	Outlet	7.4	8	4	28	0.8	1.8	1.4		Meeting the Standards.
		OLMS	7.2	7.8	5.3	22.2	-	3.0	-		
	37	Outlet	7.2	24	15	48	1.2	2.1	1.6		Not meeting the Standards wrt TSS & BOD .
		OLMS	6.7	24.1	15.1	72.99	-	6.9	-		
	43	Outlet	7.3	30	19	48	2.4	2.2	1.3	Not meeting the Standards wrt TSS & BOD .	
		OLMS	7.5	29.3	13.8	63.0	-	0.3	-		
	Total 110										

*Nandita*  
I/C LABORATORY

Dr. Nandita Moitra  
Scientist



# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/210 *1474*

Dated *04/12/2023*

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

- 1. Name of STP : Keshopur
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 17.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2		
1	40	Inlet	7.3	204	120	240	20	25.5	19.9	Not meeting the Standards wrt TSS, BOD & COD.	
		Outlet	7.5	40	22	68	2.8	1.3	1.9		
		OLMS	7.6	94	75	302	-	15.0	-		
2	20	Inlet	7.3	204	120	240	20	25.5	19.9		Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.6	30	22	68	2.8	1.3	1.9		
		OLMS	-	-	-	-	-	-	-		
Total 60										OLMS was non-functional	

*Maitra*

Dr. Nandita Maitra  
Scientist 'D'





# DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building  
Kashmere Gate, Delhi 110006  
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/211

1475

Dated

04/12/2023

## ANALYSIS REPORT OF STP FOR THE MONTH OF NOVEMBER-2023

- 1. Name of STP : Ghitorini
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 03.11.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.4	112	60	144	4	10.8	19.5	
		OLMS	7.8	34	21	40	1.6	1.3	1.4	
Total 5			7.5	15.5	12.3	36.3	-	9.4	-	

*Nandita*

I/C LABORATORY

Dr. Nandita Moitra  
Scientist 'D'