

WATER QUALITY STATUS OF DRAIN

Date - 11/08/2023

REPORT NO: DPCC/W/D/2023/182-195
 Date of Sampling: -03.08.2023

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
Standards		5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.5	78	186	42
2.	Metcalf House Drain	7.2	58	112	28
3.	Khyber Pass Drain	7.4	64	128	30
4.	Sweeper Colony Drain	7.6	78	176	40
5.	Magazine Road Drain	7.3	66	148	38
6.	ISBT Drain	7.2	72	192	36
7.	Tonga Stand Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
8.	Civil Mill Drain	7.1	98	260	52
9.	SEN Nursing Home Drain	7.3	86	234	44
10.	Drain No. 14	NO FLOW	NO FLOW	NO FLOW	NO FLOW
11.	Power House Drain	7.1	80	196	39
12.	Indrapuri Drain	7.0	94	272	51
13.	Sonia Vihar Drain	7.4	100	266	48
14.	Kailash Nagar Drain	7.5	70	170	36
15.	Shastri Park Drain	7.4	60	160	34
16.	Barapulla Drain	7.8	96	252	50
17.	Maharani Bagh Drain	7.3	94	224	46
18.	Old Agra Canal Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
19.	Jaitpur Drain	7.4	86	202	49
20.	Sarita Vihar Pool	7.6	60	154	36
21.	Tuglakabad Drain	7.2	82	234	47
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	NO FLOW	NO FLOW	NO FLOW	NO FLOW
24.	Shahdara Drain	7.2	102	256	53
25.	Sahibabad Drain	7.4	108	248	50
26.	Molarband Drain	7.0	64	168	38
27.	Abul Fazal Drain	7.6	88	240	45
28.	Supplementary Drain	7.2	72	176	40

N. Nandita
 I/C Water Lab

Dr. Nandita Moitra
 Scientist 'D'