



DELHI POLLUTION CONTROL COMMITTEE
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/20-21/433-457/2823

Dated: 30/12/2020
Date of Sampling- 01/12/2020

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.1	84	160	50
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	7.4	204	336	96
4.	Sweeper Colony Drain	7.2	76	124	40
5.	Magazine Road Drain	7.9	128	196	65
6.	ISBT Drain	7.7	292	360	150
7.	Tonga Stand Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
8.	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9.	Civil Mill Drain	6.8	108	220	82
10.	Power House Drain	7.1	280	412	142
11.	Sen Nursing Home Drain	6.9	144	236	76
12.	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13.	Drain No. 14	7.0	116	160	54
14.	Barapulla Drain	7.2	136	260	80
15.	Maharani Bagh Drain	7.2	256	396	140
16.	Kalkaji Drain	6.9	244	340	110
17.	Sarita Vihar Drain (Mathura Road)	7.2	176	292	92
18.	Tehkhand Drain	7.1	228	328	110
19.	Tuglakabad Drain	7.1	212	380	120
20.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21.	Drain Near Sarita Vihar Bridge	7.2	208	300	130
22.	Shahdara Drain	7.3	240	428	140
23.	Sahibabad Drain	7.2	324	460	170
24.	Indrapuri Drain	7.2	360	540	195

Nandita
SR.SCIENTIST
Dr. NANDITA MOITRA
Scientist 'C'

[Signature]
SR.SCIENTIFIC ASSISTANT