



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2023/5572
Date of Sampling: -05.04.2023

Dated: 19/04/2023

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
Standards		5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.1	112	272	60
2.	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	7.4	100	256	48
7.	Tonga Stand Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
8.	Civil Mill Drain	7.3	84	248	42
9.	SEN Nursing Home Drain	7.4	124	304	52
10.	Drain No. 14	NO FLOW	NO FLOW	NO FLOW	NO FLOW
11.	Power House Drain	7.0	120	293	55
12.	Indrapuri Drain	7.2	104	264	50
13.	Sonia Vihar Drain	7.4	128	373	62
14.	Kailash Nagar Drain	7.3	96	192	46
15.	Shastri Park Drain	7.0	56	160	38
16.	Barapulla Drain	7.2	92	288	45
17.	Maharani Bagh Drain	7.5	108	266	50
18.	Old Agra Canal Drain	7.2	104	256	43
19.	Jaitpur Drain	7.5	92	213	54
20.	Sarita Vihar Pool	7.3	88	224	40
21.	Tuglakabad Drain	7.2	116	293	56
22.	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	NO FLOW	NO FLOW	NO FLOW	NO FLOW
24.	Shahdara Drain	7.1	112	320	58
25.	Sahibabad Drain	7.0	128	336	63
26.	Molarband Drain	7.3	76	272	44
27.	Abul Fazal Drain	7.5	100	320	53
28.	Supplementary Drain	7.3	80	240	48

N. Mishra
Dr. N. Mishra
Water Lab
Scientist 'D'