



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110001
 Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 11.7.2023

Report Number: DPCC/W/STP/23-24/53 | 94

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

- | | | |
|------------------------------------|---|-------------------------|
| 1. Name of STP | : | Coronation Pillar |
| 2. Sampling location | : | Inlet and outlet of STP |
| 3. Date of inspection | : | 15.06.2023 |
| 4. Samples collected by | : | DPCC Lab |
| 5. Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II (20)	Inlet	7.5	276	135	400	14	25.2	12.4	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	40	24	56	3.2	2.6	2.1	OLMS was non-functional
		OLMS	-	-	-	-	-	-	-	-
2	Ph-III (70)	Inlet	7.4	308	200	256	16	23.2	34.5	Meeting the standards.
		Outlet	7.3	8	5	24	2.4	3.1	1.8	pH & Ammonical Nitrogen readings not shown in OLMS
		OLMS	-	7.93	3.79	31.59	-	-	-	-
Total 90										

Dr. Hand In Saini

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/54/95

dated: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 09.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.6	204	115	96	10.4	29.3	11.5	Meeting the Standards.
		Outlet	7.7	8	5	28	1.2	2.2	0.6	
		OLMS	7.1	5.88	4.95	29.99	-	2.23	-	
Total 15										

I/C LABORATORY

Dr. Nandita Moitra
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/55/96

Dated: 11-7-2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	7.2	248	130	288	16.4	27.2	14.1	Meeting the Standard.
		Cutlet	7.4	10	8	20	2.4	2.8	1	
		CLMS	7.5	4.99	2.62	15.05	-	1.83	-	
Total 2.2										

Nandita
I/C LABORATORY

Dr. Nandita Mishra
Scientist II



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006.

Website : <http://www.dpcc.delhigovt.nic.in>

dated: 11.7.2023

Report Number: DPCC/W/STP/23-24/56 /97

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

- Name of STP : Keshopur STP (New)
- Sampling location : Inlet and Outlet of STP
- Date of inspection : 15.06.2023
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12		6.5-9.0	10	10	50	10	5	2	Not Meeting the standards wrt TSS, BOD & COD
		Inlet	7.6	256	140	416	12	30.5	25.4	
		Outlet	7.2	22	16	60	2.4	2.6	1.2	
		OLMS	7.4	8.13	5.94	29.48	-	2.82		
Total 12										

Almita
I/C LABORATORY
Dr. Nand Lal
15/06/2023



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Date: 11.7.2023

Report Number: DPCC/W/STP/23-24/57/98

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 09.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.4	276	140	272	9.2	26.8	20.1	Meeting the Standards
		Outlet	7.1	8	6	28	2.4	2.5	1.1	
		OLMS	7.7	5.25	3.20	24.19	-	2.7	-	
Total 2.2										

Nandita
I/C LABORATORY

Dr. Nandita Mehta
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

dated: 11.7.2023

Report Number: DPCC/W/STP/23-24/58 / 77

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 21.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.5	252	94	252	11.2	19.4	18.4	Meeting the standards
		Outlet	7.3	8	5	28	3.2	2.6	1.2	
		OLMS	7.2	7.70	5.55	36.74	-	3.37	-	
Total 20										

Mishra
I/C LABORATORY

Dr. Nandita Mishra

Scientist II



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Date: 11.7.2023

Report Number: DPCC/W/STP/23-24/59/100

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.2	184	92	320	14.8	17.5	25.2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.4	36	23	64	3.6	2.3	1.6	
		OLMS	7.7	47.35	36.48	208.61	-	12.16	-	
Total 40										

N. Mittal
I/C LABORATORY

Dr. Namita Mittal
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/23-24/60 | 10 |

Date: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

- Name of STP : Najafgarh
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 21.06.2023
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.3	264	135	284	14.8	33.6	26.4	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.1	40	21	64	1.6	3.4	2.9	
		OLMS	9.3	19.0	14.40	76.30	-	14.45	-	
Total 5										

I/C LABORATORY

Dr. Nandini K.

11/7/23



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/61/107

Date: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

- Name of STP : Rithala
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 05.06.2023
- Samples collected by : DPCC Lab
- Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.3	296	135	304	16	9.4	15.4	Not Meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.1	26	16	48	3.2	3.1	1.8	
		OLMS	7.6	9.89	7.61	34.21	-	8.09	-	
Total 80										

I/C LABORATORY

Dr. Namita Jaisra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.C.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/62/103

Dated: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Pappankalan (Cid)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	20	Inlet	7.2	216	105	272	12	20.6	26.3	Not meeting the Standards wrt TSS, BOD COD & Dissolved Phosphate.
		Outlet	7.4	24	18	44	2.8	3.1	3.4	
		OLMS	8.1	7.46	5.18	32.71	-	1.81	-	
Total 20										

I/C LABORATORY

Dr. Nandita Malhotra

(Signature)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/63/104

Dated: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.2	216	105	272	12	20.6	26.3	Meeting the Standards.
		Outlet	7.5	6	5	24	1.6	1.5	1.1	
		OLMS	7.7	36.55	28.98	159.26	-	6.6	-	
Total 20										

Atulika
I/C LABORATORY

Dr. Nandini Mishra
Technical D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Date: 11.7.2023

Report Number DPCC/W/STP/23-24/64 (105)

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.5	292	130	288	14.8	24.2	15.2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	28	17	60	4.4	3.6	2.4	
		OLMS	7.5	29.70	16.99	222.55	-	8.59	-	
Total 15										

N. M. Jha
I/C LABORATORY
Dr. Nandita Bhatnagar
110006



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/65 /106

Date: 11.07.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10		6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS & BOD.
		Inlet	7.5	200	80	128	7.2	20.8	15.1	
		Outlet	7.4	28	18	36	4.2	1.4	1.8	
		OLMS	7.4	10.35	7.91	39.17	-	11.65	-	
Total 10										

N. Naudia
I/C LABORATORY
Dr. Naudia Naudia
In-charge STP



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, J.S.B.T. Building, Kashmere Gate, Delhi - 110006
 Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 11.7.2023

Report Number: DPCC/VI/STP/23-24/66 *110*

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP
2. Sampling location
3. Date of Inspection
4. Samples collected by
5. Parameters analyzed and results

Okhla New
 Inlet and Outlet of STP
 08.06.2023
 DPCC Lab

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.5	220	115	264	12.8	17.6	24.5	Meeting the Standards.
		Outlet	7.2	10	8	36	1.6	1.8	1.2	OLMS was non-functional
		OLMS	-	-	-	-	-	-	-	
Total 30										

AM
 I/C LABORATORY

Dr. Manjula



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Date: 11.7.2023

Report Number: DPCC/NI/STP/23-24/67/108

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

- Name of STP : Kondli
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 09.06.2023
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I (10)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards.
		Outlet	7.3	224	100	320	20	34.7	31.6	
		OLMS	7.2	6	4	24	1.6	3.5	1.2	
2	Ph-III (10)	Outlet	7.4	10.20	5.68	38.62	-	7.65	-	Meeting the standards.
		OLMS	7.1	8	5	32	3.6	2.3	1	OLMS was non-functional
		OLMS	-	-	-	-	-	-	-	
Total 20										

Nandita
I/C LABORATORY
Dr. Nandita Me...



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/68 1509

Dated: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

- | | | |
|------------------------------------|---|-------------------------|
| 1. Name of STP | : | Kondli New |
| 2. Sampling location | : | Inlet and Outlet of STP |
| 3. Date of inspection | : | 09.06.2023 |
| 4. Samples collected by | : | DPCC Lab |
| 5. Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.1	296	165	272	20	25.4	29.6	Not Meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.3	48	28	70	3.6	3.1	2.4	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 45										

N. Mittal
I/C LABORATORY

Dr. Nandini Mittal
General In-charge



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 11.7.2023

Report Number: DPCC/W/STP/23-24/72/110

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 09.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	1	Inlet	7.5	176	80	256	13.6	14.6	22.8	Meeting the Standards.
		Outlet	7.2	4	6	20	0.4	1.5	1.1	
		OLMS	7.5	0.93	1.1	6.8	-	0.03	-	
Total 1										

N. Mittal

I/C LABORATORY
Dr. Namita



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.C.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Date: 11.7.2023

Report Number: DPCC/W/STP/23-24/69/111

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.4	200	78	208	6.4	26.5	16.8	Meeting the standards
		Outlet	7.2	8	5	16	2.3	3.1	1.2	
		OLMS	7.6	8.16	7.91	44.07	-	1.73	-	
Total 5										

Nandini
VC LABORATORY
Dr. Nandini



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/70/112

Dated: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	Inlet	7.4	240	150	224	11.6	21.8	28.1	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.6	20	12	36	5.6	3.2	2.1	
		DLMS	7.7	21.05	13.19	77.31	-	12.64	-	
Total 25										

N. Mittal
I/C LABORATORY

Dr. Namita K. Singh

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, L.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 11.7.2023

Report Number: DPCC/W/STP/23-24/71 | 113

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.4	160	74	160	13.6	23.6	13.5	Meeting the Standards.
		Outlet	7.1	8	5	32	2.4	2.8	0.8	
		OLMS	7.3	8	5.57	33.92	-	3.79	-	
Total 9										

N. Mittal
I/C LABORATORY
Dr. Nandita Mittal
Director



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Date: 11-7-2023

Report Number: DPCC/W/STP/23-24/73/1114

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 07.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.3	172	110	304	6.4	14.9	27.5	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.0	30	15	56	1.6	2.8	2	
		OLMS	7.7	13.31	12.26	60.54	-	11.34	-	
Total 15										

Nandita
I/C LABORATORY

Dr. Nandita



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/74 /115

Dated: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	2.2	Inlet	7.3	236	120	320	11.6	23.1	30.1	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	42	18	56	3.2	2.8	4.4	
		OLMS	7.5	6.67	5.82	28.28	-	8.94	-	
2	3	Inlet	7.0	224	155	288	2.4	18.6	27.8	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.5	44	22	80	1.2	4.8	2.6	
		OLMS	7.5	8.11	8.28	25.12	-	9.55	-	
Total 5.2										

N. Mittal
I/C LABORATORY

Dr. Nandini Bhatia

2023



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/75 *1116*

dated: 11-7-2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

- | | | |
|------------------------------------|---|-------------------------|
| 1. Name of STP | : | Yamuna Vihar |
| 2. Sampling location | : | Inlet and Outlet of STP |
| 3. Date of inspection | : | 09.06.2023 |
| 4. Samples collected by | : | DPCC Lab |
| 5. Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.3	232	100	152	10.4	18.1	26.8	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	42	22	60	2.4	3.7	2.9	
		OLMS	7.8	15.43	10.03	66.08	-	17.70	-	
2	10 Ph-2	Inlet	7.4	224	105	224	10.8	19.5	22.3	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	22	11	32	1.6	2.1	2.8	
		OLMS	8.6	12.70	5.41	53.33	-	10.91	-	
Total 20										

N.M. Singh
 I/C LABORATORY
 Dr. Nandini Singh
 Group Chief



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmir Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/3 117

Dated: 11.7.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	0.66	Inlet	7.2	336	135	368	16.4	23.1	18.5	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.3	26	17	72	2.8	1.4	3.0	
		DLMS	7.7	24.15	15.8	102.6	-	11.25	-	
Total 0.66										

N. Maitra
I/C LABORATORY
Dr. Maitra

Date: 11.7.2023



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/76 III 8

08.06.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Oldha
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P(mg/l)
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.4	292	180	320	13.2	24.9	23.4	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.2	12	22	80	2	1.6	2	
		OLMS	7.4	6.40	5.23	21.59	-	9.19	-	
	16	Outlet	7.1	10	8	32	2.0	2.8	1.8	Meeting the Standards.
		OLMS	7.6	7.77	4.62	20.38	-	11.999	-	
	37	Outlet	7.3	28	18	64	2.6	3.1	1.4	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.5	46.58	26.39	152.15	-	24.84	-	
	45	Outlet	7.5	34	16	72	1.2	3.6	1.5	Not meeting the Standards wrt TSS, BOD & COD.
OLMS		7.3	23.92	13.45	62.79	-	4.46	-		
Total 110										

N. Mishra
I/C LABORATORY
Dr. Nandita Bhatia
Scientist II



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Date: 11/7/2023

Report Number: DPCC/W/STP/23-24/77/119

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2023

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.06.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.2	212	135	368	15.2	25.3	15.9	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.1	48	25	72	3.2	2.2	1.5	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
2	20	Inlet	7.3	212	135	368	15.2	25.3	15.9	Not meeting the Standards wrt TSS, BOD, COD, Ammonical nitrogen & Dissolved phosphate.
		Outlet	7.2	22	18	56	2.8	6.3	5.6	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 60										

1
V

Dr. Nandini Malhotra