



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocams.nic.in>)



Dated 29/11/2023

Report Number: DP/ C/W/STP/23-24/158 / 380

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 23.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I,II (20)	Inlet	7.4	280	85	320	9.6	24.6	19.3	Not meeting the standards wrt TSS, BOD & COD. OLMS was non-functional
		Outlet	7.7	28	18	60	3.2	1.9	1.7	
		OLMS	-	-	-	-	-	-	-	
2	Ph-III (10)	Inlet	7.5	216	120	288	7.6	21.9	16.9	Not meeting the standards wrt TSS & COD. OLMS was non-functional
		Outlet	7.2	14	10	56	3.6	1.5	1.4	
		OLMS	-	-	-	-	-	-	-	
Total 30										

Maita
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/159/381

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.6	136	80	96	4.2	19.6	9.1	Meeting the Standards.
		Outlet	7.3	8	6	28	0.8	1.1	1.3	
		OLMS	7.4	5.7	2.7	17.7	-	1.48	-	
Total 15										

Nandita
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/160 / 382

Dated: 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Delhi Gate (Old)
 2. Sampling location : Inlet and Outlet of STP
 3. Date of Inspection : 11.10.2023
 4. Samples collected by : DPCC Lab
 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	7.6	172	130	192	4.4	23.6	11.8	Meeting the Standard.
		Outlet	7.5	10	7	20	2	2.5	1.7	
		OLMS	7.4	7.6	4.2	26.7	-	1.5	-	
Total 2.2										

Nandita
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/161 | 383

Dated: 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : Keshopur STP (New)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 23.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.2	232	165	368	12.8	21.5	20.9	Not Meeting the standards wrt TSS, BOD & COD.
		Outlet	7.6	24	15	60	2.8	1.8	1.6	
		OLMS	7.7	7.3	5.3	31.1	-	2.5	-	
Total 12										

Nandita
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/162 **384**

Dated **09/11/2023**

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : SEN Nursing Home (SNH)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 11.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Phase-I,II (2.2)	Inlet	7.4	240	165	240	4.4	20.2	19.5	Meeting the Standards
		Outlet	7.7	8	7	24	2	1.2	1.8	
		OLMS	7.4	7.2	4.5	27.7	-	1.6	-	
Total 2.2										

N. Moitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/163/385

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Nilothi New
 2. Sampling location : Inlet and Outlet of STP
 3. Date of Inspection : 25.10.2023
 4. Samples collected by : DPCC Lab
 5. Parameter analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	20	Inlet	7.7	156	110	304	12.8	11.6	10.6	Meeting the standards
		Outlet	7.5	8	5	32	1.6	1.2	1.1	
		OLMS	7.8	6.7	5.2	35.7	-	2.6	-	
Total 20										

N. Moitra
 I/C LABORATORY

Dr. Nandita Moitra
 Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110006
 (Visit us at <https://www.dpccomms.nic.in>)



Dated 09/11/2023

Report Number DPCC/W/STP/23-24/164/386

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Nilothi
 2. Sampling location : Inlet and Outlet of STP
 3. Date of Inspection : 25.10.2023
 4. Samples collected by : DPCC Lab
 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.9	192	90	304	14.8	21.6	25.6	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.6	32	23	56	3.2	2.2	1.1	
		OLMS	7.4	35.8	26.0	151.4	-	9.7	-	
Total 40										

Nandita
 I/C LABORATORY

Dr. Nandita Moitra
 Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Dated 09/11/2023

Report Number DPCC/W/STP/23-24/165 | 387

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : Najafgarh
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 25.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.3	236	100	272	12.4	21.6	9.5	Not meeting the standards wrt TSS, BOD and COD
		Outlet	7.8	26	18	68	2	2.2	1.1	
		OLMS	6.3	19.1	14.7	77.0	-	12.0	-	
Total 5										

Nandita
I/C LABORATORY
Dr. Nandita Motra
Scientist D

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomras.nic.in>)



Report Number: DPCC/W/STP/23-24/166 | 388

Dated: 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	Ph-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.4	300	135	328	12.4	10.9	6.8	Meeting the standards
		Outlet	7.6	10	7	32	3.6	2.9	1.7	
		OLMS	7.5	9.8	7.5	34.2	-	8.1	-	
Total 80										

Mittra
 KC LAB
 Dr. Nandita Mittra
 Scientist B

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110006
 (Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/23-24/167 | 389

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	20	Inlet	7.6	240	125	336	17.6	22.3	23.6	Not meeting the Standards wrt TSS, BOD COD & Dissolved Phosphate.
		Outlet	7.8	26	20	72	4.4	2.6	2.6	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 20										

Nandita
 I/C LABORATORY
Dr. Nandita Moitra
 Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Dated 09/11/2023

Report Number: DPCC/W/STP/23-24/168 | 390

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : Pappankalan Ph-II (New)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 25.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.5	154	115	240	12.4	20.7	19.6	Meeting the Standards.
		Outlet	7.3	8	5	36	3.2	1.8	1.7	
		OLMS	6.8	7.0	5.8	44.6	-	1.5	-	
Total 20										

Nandita
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number DPCC/W/STP/23-24/169 | 391

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : Rohini
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 06.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.4	312	160	296	8	21.3	11.3	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.6	24	12	56	4.4	3.2	1.5	
		OLMS	7.6	23.0	13.7	63.8	-	15.8	-	
Total 15										

Nandita
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110006
 (Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/170 | 392

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : Narela
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 06.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.1	196	80	160	9.2	17.9	10.3	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	36	15	60	3.6	1.5	1.1	
		OLMS	7.3	8.9	6.0	38.95	-	3.0	-	
Total 10										

Nandita
 I/C LABORATORY

Dr. Nandita Moitra
 Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Dated 19/11/2023

Report Number: DPCC/W/STP/23-24/171/393

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 10.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		Dissolved Phosphate as P (mg/l)
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.7	212	110	264	9.2	14.5	21.2	Meeting the Standards.
		Outlet	7.8	8	5	36	1.2	1.1	1.5	
		OLMS	7.0	5.50	4.90	24.62	-	1.14	-	
Total 30										

N. Moitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/172 / 394

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Kondli
 2. Sampling location : Inlet and Outlet of STP
 3. Date of Inspection : 11.10.2023
 4. Samples collected by : DPCC Lab
 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	Ph-I (10)	Inlet	7.6	236	106	272	6.4	28.7	27.5	Meeting the standards.
		Outlet	7.3	10	7	40	2.4	2.6	2.1	
		OLMS	7.6	8.2	4.8	35.0	-	6.9	-	
2	Ph-II (25)	Outlet	7.4	6	4	16	1.6	1.8	1.2	Meeting the standards
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
3	Ph-III (10)	Outlet	7.8	8	6	32	5.2	1.5	1.9	Meeting the standards.
		OLMS	7.6	10.0	5.5	27.1	-	4.1	-	
Total 45										

Mitra
 Dr. Manoj Kumar Mitra
 Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110066
 (Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/173/395

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-IV (45)	Inlet	7.7	200	175	224	6.4	20.1	24.2	Not Meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.2	32	17	68	2.8	1.8	1.7	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 45										

Nandita
 I/C LABORATORY
Dr. Nandita Moitra
 Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110006
 (Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/174 | 396

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 20.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.3	188	70	192	2.8	22.3	10.2	Meeting the Standards
		Outlet	7.2	6	4	32	1.6	1.9	1.1	
		OLMS	7.5	9.7	6.2	31.27	-	2.8	-	
Total 5										

N. Moitra
 I/C LABORATORY
Dr. Nandita Moitra
 Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)

Report Number: DPCC/N/STP/23-24/175/397

Dated 09/11/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Yamuna Vihar Ph-III
 2. Sampling location : Inlet and Outlet of STP
 3. Date of Inspection : 12.10.2023
 4. Samples collected by : DPCC Lab
 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.5	184	125	176	3.6	17.3	25.6	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.2	24	15	44	1.6	1.3	1.4	
		OLMS	-	-	-	-	-	-	-	-
Total 25										

Nandita
Dr. Nandita Moitra
 Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Dated 09.11.2023

Report Number: DPCC/N/STP/23-24/176/398

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.5	212	66	144	6.8	25.1	14.2	Meeting the Standards.
		Outlet	7.3	10	5	36	1.2	2.1	1.6	
		OLMS	7.1	6.5	3.7	27.0	-	1.2	-	
Total 9										

Maitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Dated 09.11.2023

Report Number: DPCC/W/STP/23-24/177/399

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	1	Inlet	7.5	220	90	208	4	14.2	16.2	Meeting the Standards.
		Outlet	7.2	4	5	20	1.2	1.4	1.3	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 1										

W/ LABORATORY
Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110006
 (Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/178/400

Date: 09.11.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.2	188	110	256	5.2	11.8	22.1	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	38	25	72	1.6	2.1	1.3	
		OLMS	7.5	20.45	7.4	49.1	-	9.0	-	
Total 15										

Nandita
Dr. Nandita Moitra
 WPC LABORATORY
 Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate Delhi 110006
(Visit us at <https://www.dpccocmms.aic.in>)



Dated 09.11.2023

Report Number: DPCC/V./STP/23-24/179/401

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : Vasant Kunj
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 20.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.1	240	170	352	16	18.5	23.2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.4	40	25	56	2.8	1.5	2.6	
		OLMS	7.4	6.7	5.5	27.1	-	3.2	-	
2	3	Inlet	7.3	268	150	320	4.4	17.6	22.4	Not meeting the standards wrt TSS & BOD
		Outlet	7.2	38	22	48	2	2.3	1.5	
		OLMS	7.2	7.1	4.5	25.4	-	2.9	-	
Total 5.2										

Nandita Moitra
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCCL/W/STP/23-24/180/402

Dated 09.11.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : Yamuna Vihar
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 12.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.3	148	80	96	6	3.2	21.2	Not meeting the standards wrt TSS.
		Outlet	7.6	18	10	40	1.6	0.8	1.4	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
2	10 Ph-2	Inlet	7.4	124	95	60	8	8.8	17.6	Not meeting the standard wrt TSS, COD & Dissolved Phosphate..
		Outlet	7.5	16	9	56	1.6	0.8	2.8	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 20										

Mishra
Dr. Nandita Mishra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110006
 (Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/181/403

Dated 09-11-2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5		Dissolved Phosphate as P (mg/l) 2
1	12	Inlet	7.2	252	125	240	5.5	17.1	13.7	Not meeting the Standards wrt TSS.
		Outlet	7.3	16	10	48	1.5	1.1	1.2	
		OLMS	7.3	23.43	13.28	60.11	-	24.7	-	
	16	Outlet	7.4	10	5	32	1.2	2.3	1.1	Meeting the Standards.
		OLMS	7.4	8.85	6.05	25.13	-	3.43	-	
	37	Outlet	7.7	30	17	40	1.5	2.5	1.3	Not meeting the Standards wrt TSS & BOD.
		OLMS	6.9	27.30	17.08	82.35	-	10.06	-	
	45	Outlet	7.9	34	29	56	3.2	2.6	1.7	Not meeting the Standards wrt TSS, BOD & COD.
OLMS		8.2	33.08	15.64	70.98	-	5.27	-		
Total 110										

Maitra
 I/C LABORATORY
Dr. Nandita Moitra
 Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Dated 09.11.2023

Report Number: DPCC/W/STP/23-24/182 1404

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.1	184	115	224	19.2	25.2	19.6	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.7	36	21	64	2	1.4	1.6	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
2	20	Outlet	7.4	26	13	52	2.4	3.5	2.2	Not meeting the Standards wrt TSS, BOD COD & Dissolved Phosphate.
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 60										

Nandita
I/C LABORATORY
Dr. Nandita Moitra
Scientist D

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/183/405

Dated 09.11.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

- 1. Name of STP : Coronation Pillar
- 2. Sampling location : Inlet and outlet of STP
- 3. Date of inspection : 23.10.2023
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	70 MGD	Inlet	7.1	256	160	352	10	20.1	24.6	Meeting the standards.
		Outlet	7.5	6	4	24	2.4	2.1	1.2	
		OLMS	-	8.4	3.3	30.0	-	-	-	pH & Ammonical Nitrogen readings not shown in OLMS
Total 70										

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110006
 (Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/23-24/184/406

Dated 09.11.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.5	120	50	48	3.2	12.6	22.1	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.6	30	15	32	1.6	1	1.5	
		O.L.M.S	7.4	16.8	13.3	39.2	-	10.1	-	
Total 5										

Nandita
 I/C LABORATORY
 Dr. Nandita Moitra
 Scientist Tr.

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/7/407

Dated 09.11.2023

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.10.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	0.66	Inlet	7.2	328	175	400	7.2	25.6	26	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.5	44	24	96	3.2	1.7	1.0	
		OLMS	6.9	27.66	15.0	91.3	-	11.45	-	
Total 0.66										

Mitra
Dr. Nandita Moitra
Scientist 'B'