

STANDARDS FOR TREATED EFFLUENT OF SEWAGE TREATMENT PLANTS

SI. No.	Industry	Parameters	Standards for New STPs(Design After notification date)*
1.	Sewage Treatment Plant	pH	6.5-9.0
2.		BOD, mg/l	10
3.		COD, mg/l	50
4.		TSS, mg/l	10
5.		NH ₄ -N, mg/l	5
6.		N-total, mg/l	10
7.		Fecal Coliform, MPN/100ml	< 230
8.		PO ₄ -P, mg/l	2

Note: These standards will be applicable for discharge in water resources as well as for land disposal. The standards for Fecal Coliform may not be applied for use of treated sewage in industrial purposes.

- Achievements of Standards for existing STPs within 02 years i.e. by 26.04.2018.