



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.bic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/23-24/293/ 743

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Coronation Pillar
- 2. Sampling location : Inlet and outlet of STP
- 3. Date of inspection : 13.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	70 MGD	Inlet	7.3	188	55	352	14	19.3	2	Meeting the standards.
		Outlet	7.6	10	06	48	2.1	1.8	1.2	
		OLMS	-	5.7	10.0	49.3	-	-	-	
Total 70										

Mandita

V/C LABORATORY
Dr. Mandita Mohita

Scientist V



DELHI POLLUTION CONTROL COMMITTEE



(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccnms.nctc.in>)

Report Number: DPCC/W/STP/23-24/294/ 744

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Coronation Pillar
- 2. Sampling location : Inlet and outlet of STP
- 3. Date of inspection : 13.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II (20)	Inlet	7.7	296	95	368	10.5	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.6	26	17	64	3.6	2	1.4		
		OLMS	7.5	13.7	6.8	45.8	-	4.7	-		
2	Ph-III (10)	Inlet	7.4	212	105	352	8.4	22.1	16.1	Not meeting the standards wrt TSS & COD.	
		Outlet	7.5	12	9	60	4	1.6	1.2		
		OLMS	-	-	-	-	-	-	-		OLMS was non-functional
Total: 30											

Mishra

I/C LABORATORY
Dr. Anshu Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccnms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/SIP/23-24/295/ 745

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Delhi Gate (New)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 14.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Phase-I, II (15)	Inlet	6.5-9.0	10	10	50	10	5	2		
		Outlet	7.2	136	115	272	4	21.2	9.4		
		OLMS	7.4	8	5	32	1.6	1.1	1.2		Meeting the Standards.
Total 15			7.6	7.1	5.5	24.2	-	3.1	-		

Mohita

I/C LABORATORY

Dr. Nandita Moitra

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/23-24/296/746

Dated: 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Delhi Gate (Old)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 14.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
PH-1 & II (2,2)		Inlet	7.5	156	140	192	3.2	22.6	11.5	Meeting the Standard.
		Outlet	7.8	10	7	20	0.8	2.9	1.3	
		OUMS	7.3	5.1	2.0	15.3	-	1.1	-	
Total 2.2										

M. Mittal

I/C LABORATORY

Dr. Nandita Mohitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/SIP/23-24/297/ 747

Dated: 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.03.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	Not Meeting the standards wrt TSS & BOD.
		Outlet	7.2	232	125	336	16.4	20.1	20.2	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 12										

M. Mohita

I/C LABORATORY

Dr. Nandita Mohita

SCIENTIST D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/NI/STP/23 24/2987 748

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.03.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I,II (2.2)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards
		Outlet	7.7	248	100	256	5.2	20.5	19.6	
		CIMS	7.6	10	8	40	2.4	1.5	3.9	
Total 2.2			7.5	5.5	3.7	24.4	-	1.3	-	

I/C LABORATORY

Dr. Nandita Moitra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE

Lifestyle for Environment

Report Number: DPCC/W/STP/23-24/299/ 749

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Nilothi New
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 12.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			PH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.6	164	102	415	14	11.2	20.1	Meeting the standards
		Outlet	7.5	10	5	40	2	1.2	1.2	
		OLMS	7.8	22.9	17.6	122.9	-	18.9	-	
Total 20										

Mandita

I/C LABORATORY

Dr. Mandita Mohtra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE



(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)

Report Number: DPCC/W/STP/23-24/300/ 750

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Nilothi
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 12.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40	Inlet	7.8	216	110	368	14	21.1	25.2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.4	30	22	64	2.4	2.3	1.4	
		OLMS	7.7	6.8	4.2	35.5	-	1.8	-	
Total 40										

Nilothi

I/C LABORATORY

Dr. Nandita Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE



(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.ubc.in>)

Report Number DPCC/W/STP/23-24/30L/ 751

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Najafgarh
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 12.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	6.5-9.0	10	10	50	10	10	5	2	Not meeting the standards wrt TSS, BOD and COD
		Outlet	7.5	232	110	272	14.6	20.8	9.5		
		CLMS	7.5	28	17	72	1.6	2.3	1.3		
Total 5			7.8	22.4	16.5	101.9	-	14.9	-		

Nandita Moitra
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE



(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110046
(Visit us at <https://www.dpccocnms.nic.in>)

Report Number: DPCC/W/STP/23-24/302/ 752

Date: 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- Name of STP : Rithala
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 15.03.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-1(40)	Inlet	6.5-9.0	10	10	50	10	5	2		
		Outlet	-	-	-	-	-	-	-		
		OLMS	-	-	-	-	-	-	-		
2	Ph-2(40)	Inlet	7.6	195	140	328	11.6	10.8	16.5		
		Outlet	7.7	10	6	32	4.8	2.8	1.5		
		GLMS	7.7	10.6	7.2	40.1	-	4.8	-		Meeting the standards
Total 80											

Plant was under Rehabilitation

Meeting the standards

M. Mittal

M/C LABORATORY
Dr. Nandita Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/23-24/303/ 753

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- Name of STP : Pappankalan (Old)
- Sampling location : Inlet and Outlet of STP
- Date of inspection : 12.03.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	20	Inlet	6.5-9.0	10	10	50	10	19.2	5	2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.5	226	130	368	3.2	22.3	25.5		
		OLMS	7.9	17	12	52	-	2.6	2.2		
Total 20			7.6	24.4	15.5	107.3		12.6			

N. Mittal

I/C LABORATORY

Dr. Nandita Maity
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/23-24/304/754

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Pappankalan Ph-II (New)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 12.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
	20	Inlet	6.5-9.0	10	10	50	10	5	2		
		Outlet	7.2	148	110	272	16	22.8	19.7		
		OLMS	7.6	10	8	36	1.4	1.6	1.5		Meeting the Standards.
		Total 20	7.7	6.5	5.3	37.0	-	1.5	-		

Nandita
/C LABORATORY

Dr. Nandita Maitra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE
 (Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
 Kashmere Gate, Delhi 110006
 (Visit us at <https://www.dpccenvis.nic.in>)

Report Number DPC/W/S/P/23-24/305/ 755
 Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Rohini
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 15.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.6	196	140	328	11.6	10.8	6.5	Not meeting the standards w.r.t TSS, BOD & COD.
		Outlet	7.7	22	17	56	4.8	2.8	1.5	
		OLMS	7.6	26.4	14.4	80.1	-	14.8	-	
Total 15										

Almita
 I/C LABORATORY
Dr. Nandita Moitra
 Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE



(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)

Dated 16/04/2024

Report Number: DPCC/W/STP/23-24/306/ 756

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Narela
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 18.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD, COD & Ammonical Nitrogen.
		Outlet	7.5	338	142	480	16.2	34.2	26.6	
		OLMS	7.5	20	18	80	2	5.5	3.1	
Total 10			6.6	11.2	7.5	49.8	-	7.9	-	

M. K. Gupta

I/C LABORATORY
Dr. Nandita Mishra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccenmms.nic.in>)



Report Number: DPCC/W/STP/23-24/307/ 757

Dated

16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- Name of STP : Okhla New
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 04.03.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.5	180	95	256	8	14.1	21.3	
		QIMS	7.2	5.8	3.7	23.5	-	0.7	1.2	
Total 30										

Mishra

I/C LABORATORY

Dr. Manoj Mishra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



LIFE
Lifestyles for
Environment

Report Number: DPCC/W/STP/23-24/308/ 758

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- Name of STP : Kondli
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 14-03-2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I (10)	Inlet	6.5-9.0	10	10	50	10	5	2		
		Outlet	7.4	120	96	272	6.8	30.1	29.5		Meeting the standards.
		OLMS	7.6	10	7	40	1.8	1.8	1.3		
2	Ph-II & III (25-10)	Outlet	7.9	6.4	5.2	19.6	-	1.5	-		
		CLMS	7.3	8	6	32	1.2	1.9	1.1		Meeting the standards
Total 45			7.6	7.1	8.1	36.1	-	2.0	-		

N. Mittal

W/C LABORATORY

Dr. Nandita Moitra
Scientist, Jr.



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/WSTP/23-24/309/ 759

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Kondli New
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 14.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-IV (45)	Inlet	6.5-9.0	10	10	50	10	5	2	Not Meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.5	136	100	182	6.0	21.1	23.2	
		QUMS	7.6	22	12	52	0.8	1.4	1.1	
Total 45										QUMS was non-functional

M. Mittal
 VC LABORATORY
 Dr. Nandita Mishra
 Scientist-IV



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/23-24/310/ 760

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- Name of STP : Kapsahera
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 07.03.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5	Inlet	7.7	256	86	272	4.8	20.1	9.4	Meeting the standards.
		Outlet	7.6	10	8	40	2	2.3	1.1	
		OLMS	7.6	9.1	6.6	43.8	-	5.4	-	
Total		5								

M. Mishra

V/C LABORATORY

Dr. Nandita Ghotra

Scientist-III



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/23-24/311/ 76)

Date: 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 15.03.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	Inlet	7.3	204	55	232	4	17.1	22.5	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.7	28	14	32	1.6	1.1	1.5	
		OUMS	7.8	22.59	15.10	59.08	-	18.41	-	
Total 25										

M. Moitra

10/11/2024

Dr. Nandita Moitra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/23-24/312/ 762

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Chilla
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 14.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	9	Inlet	6.5-9.0	10	10	50	10	3.5	5	2	Meeting the Standards.
		Outlet	7.8	200	64	160	2	22.1	14.1		
		OUMS	7.7	6	5	40	2	1.5	3.2		
Total		9	7.4	9.0	6.7	36.0	-	2.2	-		

M. Mittal

I/C LABORATORY
Dr. Harshita Mittal
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/23-24/313/ 763

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- Name of STP : Akshardham
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 14.03.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	1	Inlet	6.5-9.0	10	10	50	10	5	2	
		Outlet	7.6	236	100	240	2.8	14.3	16.7	
		OLMS	7.8	6	5	32	0.8	1.5	1.8	
			7.4	0.7	1.4	6.1	-	0.2	-	Meeting the Standards.
Total 1										

Maitra
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nctdelhi.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/23-24/314/ 764

Dated: 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Mehrauli
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 07.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards w.r.t TSS, BOD & COD.
			7.5	140	115	304	35.6	11.8	21.6	
		Outlet	7.5	40	20	64	3.6	1.9	1.9	
Total 15		OUMS	7.3	15.4	9.8	56.7	-	4.0	-	

Alkington

I/C LABORATORY
Dr. Hardita Dhotra
SCIENTIST 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccnms.nic.in>)



Report Number: DPCC/W/STP/23-24/315/ 765

Dated: 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.03.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters										Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)				
1	2.2	Inlet	6.5-9.0	10	10	50	10	19.2	5	2			
		Outlet	7.7	220	145	416	2.4	16.1	23.5				
		OLPS	7.4	16	10	40	2.4	2.1	1.5				Not meeting the standards wrt TSS.
2	3	Inlet	7.3	5.0	4.2	22.6	-	2.4	-				
		Outlet	7.8	288	125	224	6.8	18	22.4				
		OLMS	7.6	18	11	48	1.2	2.1	2.1				Not meeting the standards wrt TSS, BOD.
Total S.2													

M. Nandita

Dr. Nandita Moitra
Scientist C



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomcns.nic.in>)



Report Number: DPCC/W/STP/23-24/516/ 766

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- Name of STP : Yamuna Vihar
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 15.03.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS.
		Outlet	7.6	176	85	56	3.2	13.6	21.8	
		OLMS	7.8	26	10	32	1.6	2.4	2.6	
2	10 Ph-2	Inlet	8.4	-	6.5	35.6	-	15.2	-	TSS reading not shown in OLMS
		Outlet	7.8	144	90	240	7.2	12.7	15.5	
		OLMS	7.6	20	11	48	2.4	1.6	1.6	
Total 20			8.2	17.9	9.9	50.3	-	6.6	-	Not meeting the standard wrt TSS & BOD

M. Nandita

I/C LABORATORY

Dr. Nandita Mohita

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/12/ 767

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Molarband (Mini STP)
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of inspection : 04.03.2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	0.65	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standard wrt TSS, BOD, COD.
		Outlet	7.6	312	130	352	6.4	24.1	24.7	
		OLMS	7.7	28	22	56	1.2	1.1	1.4	OLMS was non functional.
Total 0.65										

M. Mittal

I/C LABORATORY

Dr. Nandita Mittal
Scientist 'F'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110016

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/23-24/3171 768

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

Date

16/04/2024

- Name of STP : Okhla
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 04.03.2024
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH	Parameters							Remarks
				TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
12		Inlet	6.5-9.0	10	10	50	10	5	2		
		Outlet		240	140	256	6	18.7	14.1		Plant was non-functional due to under maintenance
		C.M.S		-	-	-	-	-	-	-	
16		Outlet	7.7	10	5	35	10.8	1.5	1.3		Meeting the Standards.
		C.M.S	7.3	10.7	7.5	31.0	-	2.6	-		OLMS was non functional
		Outlet	7.5	32	19	48	2	2.4	3.5		Not meeting the Standards wrt TSS, BOD.
37		C.M.S	7.7	33.3	22.2	55.5	-	13.3	-		
		Outlet	7.6	42	21	64	1.2	2.1	3.5		Not meeting the Standards wrt TSS, BOD& COD
		OLMS	7.3	23.5	11.1	63.9	-	5.6	-		
Total 110											

Maitra

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmuns.nic.in>)



Report Number: DPCC/W/STP/23-24/318/ 769

Dated: 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

- 1. Name of STP : Keshopur
- 2. Sampling location : Inlet and Outlet of STP
- 3. Date of Inspection : 13-03-2024
- 4. Samples collected by : DPCC Lab
- 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & DISSOLVED OXYGEN
			7.5	200	120	240	25.4	19.5		
		Outlet	7.3	24	12	48	3.2	3.3	2.1	
		OLMS	-	-	-	-	-	-	-	OLMS was Non functional
2	20	Outlet	7.5	35	23	68	2.4	1.3	1.4	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	-	-	-	-	-	-	-	
Total 60										

M. Dr. Nandita
Scientist
LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccorpnms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/23-24/319/ 77D

Dated 16/04/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2024

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 07.03.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS & BOD.
		Outlet	7.5	128	62	224	3.2	10.1	20.3	
		QUMS	7.7	24	15	48	1.6	1.4	1.4	
Total 5			7.5	17.6	13.2	35.2	-	7.2	-	

Nandita
Nandita
Scientist 'D'