

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/101/4991

Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022


1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 17.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	Ph-I,II(20)	Inlet	7.1	196	140	300	34.4	26.8	23.6	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.4	16	12	38	5.6	4.2	2.6	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10) (now upgrade with 70 MGD)	Inlet	7.2	248	110	284	19.6	44.8	32.2	Meeting the standards.
		Outlet	7.5	10	8	28	7.2	3.8	1.8	
		OLMS	-	-	-	-	-	-	-	
Total 30										

*Remarks: OLMS (Ph-I & II) was stolen. FIR has been filed as informed by Plant In-charge & OLMS (Ph-III) found non-functional.

Mintia
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/102/4992


Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.2	280	155	180	28.4	23.6	14.8	Meeting the Standards.
		Outlet	7.4	8	6	44	2.0	4.2	1.8	
		OLMS	7.02	3.97	4.19	26.02	-	7.99	-	
Total 15										

Mishra
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/103/4993


Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
Phase-I,II(2.2)		Inlet	7.1	264	125	260	24.8	28.2	14.4	Meeting the Standards
		Outlet	7.3	10	6	48	2.4	4.6	1.4	
		OLMS	6.89	5.65	3.71	18.45	-	4.02	-	
Total 2.2										

Mishra
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/104/4994

Dated: 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.2	284	125	282	34.8	19.2	28.4	Meeting the standards.
		Outlet	7.5	10	8	32	2.4	1.2	0.8	
		OLMS	7.52	7.14	4.98	33.80	-	-	-	
Total 12										

*Remarks: In OLMS, Ammonical Nitrogen reading was not reflected.

Mishra
I/C LABORATORY
Dr. Anil Kumar I.C. Iy.,
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/105/4995


Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.3	260	128	204	34.4	35.3	24.8	Meeting the Standards
		Outlet	7.5	6	3	24	2.8	4.2	1.4	
		OLMS	7.41	6.09	5.14	24.48	-	3.90	-	
Total 2.2										

Mita
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 06/09/2022

Report Number: DPCC/W/STP/22-23/107/4996

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022


1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	6.9	182	120	184	23.2	24.8	28.6	Not meeting the standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved phosphate.
		Outlet	7.5	52	34	96	5.6	7.3	6.4	
		OLMS	7.49	52.58	33.18	168.22	-	16.99	-	
Total 40										

Mitra

I/C LABORATORY

Dr. Parulna Mittal
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/108/4997

Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022


1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.4	276	175	204	26.8	25.2	25.4	Not meeting the standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.2	48	28	78	6.4	4.4	4.9	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

*Remarks: OLMS was Stolen informed by Plant Incharge.

Mita
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/109/4998


Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.3	184	108	200	38.8	26.4	24.2	Meeting the standards.
		Outlet	7.5	10	8	36	2.4	4.8	1.2	
		OLMS	7.53	12.80	9.04	38.52	-	8.02	-	
Total 80										

Mittra
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/110/4999

Date: 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : .08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	20	Inlet	7.2	192	108	284	26.8	19.8	23.4	Not meeting the Standards wrt TSS, BOD COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.1	42	26	80	8.4	6.2	4.8	
		OLMS	7.41	37.76	28.37	171.31	-	17.8	-	
Total 20										

Mitra
I/C LABORATORY

Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/111/5000

Date: 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.4	128	96	276	24.8	28.4	20.6	Not meeting the Standards w.r.t. TSS & BOD.
		Outlet	7.1	16	12	32	2.4	1.8	1.4	
		OLMS	7.318	5.56	4.02	28.45	-	0.95	-	
Total 20										

Mitra
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/112 /5001

Date: 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	15	Inlet	7.1	160	102		30.8	32.6	20.4	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.4	24	18	68	4.4	5.8	3.6	
		OLMS*	7.54	18.46	9.79	56.00	-	18.46	-	
Total 15										

Mitra
I/C LABORATORY

Dr. PARUL K. MITRA
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/113/5002


Date: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10	Inlet	7.1	148	68	184	4.8	36.8	23.4	Not Meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.3	36	22	52	2.4	3.6	4.2	
		OLMS	7.62	46.35	22.12	87.63	-	24.13	-	
Total 10										

M. Mitta
I/C LABORATORY
Dr. Mahendra Mohan,
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/114/5003

Dated: 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.2	152	88	284	26.4	34.2	19.6	Meeting the Standards.
		Outlet	7.4	8	6	40	2.8	4.6	1.2	
		OLMS	7.32	7.53	5.68	39.51	-	1.52	-	
Total 30										

Mishra
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/115/5004

Date: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-I (10)	Inlet	7.2	248	145	284	28.4	46.2	34.6	Not meeting the standards wrt TSS & Dissolved phosphate.
		Outlet	7.5	14	10	44	1.6	4.2	2.6	
		OLMS*	7.60	13.12	9.27	38.88	-	6.66	-	
Total 10										

Mitra
I/C LABORATORY

Dr. Anurag Mishra
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/116/5005

Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022


1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	By-pass	7.1	288	165	348	26.8	44.5	38.0	Not Meeting the Standards wrt TSS, BOD, COD, Oil & Grease, Ammonical nitrogen & Dissolved Phosphate.
		OLMS*	-	-	-	-	-	-	-	
Total 45										

*Remarks: During the monitoring, the OLMS was not found installed at the site.

Mitra

Dr. I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/117/5006

Dated: 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5	Inlet	6.8	144	82	264	6.4	35.4	22.2	Meeting the standards
		Outlet	7.2	10	6	48	2.8	4.2	1.8	
		OLMS	7.23	7.27	5.19	34.60	-	5.16	-	
Total 5										

Mitra
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/118/5007

Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022


1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	25	Inlet	7.1	232	130	284	20.8	28.2	19.4	Not meeting the Standards wrt TSS, BOD, COD & Ammonical Nitrogen.
		Outlet	7.4	30	24	92	7.2	6.0	1.8	
		OLMS	7.28	10.37	7.26	34.02	-	-	-	
Total 25										

*Remarks: In OLMS, Ammonical Nitrogen reading was not reflected.

M. Mita
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/119/5008

Dated: 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	9	Inlet	7.3	224	108	204	20.8	32.4	24.6	Meeting the Standards.
		Outlet	7.5	10	8	24	2.8	4.8	2.0	
		OLMS	7.4	9.39	6.17	53.10	-	2.07	-	
Total 9										

N. Mitra
I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/120/5009

Date: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022


1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	1	Inlet	7.25	164	96	160	26.4	20.2	19.8	Meeting the Standards.
		Outlet	7.6	4	2	18	1.0	2.4	1.4	
		OLMS	7.1	0.60	1.99	9.51	-	0.31	-	
Total 1										

M. Mitta

I/C LABORATORY

Dr. Ramesh Chandra
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/121/5010


Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.3	180	112	252	16.4	22.8	30.2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	42	30	64	4.4	4.4	3.8	
		OLMS	7.43	27.82	13.46	98.59	-	5.23	-	
Total 15										

N. Mehta
I/C LABORATORY
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/122/S011

Dated : 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02 .08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.6	272	145	248	36.4	22.8	45.2	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.3	32	20	62	5.6	4.4	3.8	
		OLMS	7.00	7.67	0.21	20.11	-	0.35	-	
2	3	Inlet	7.1	240	125	204	12.8	24.4	34.6	Not Meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	6.9	38	26	64	3.2	4.2	3.5	
		OLMS	7.00	5.45	4.29	14.67	-	4.38	-	
Total 5.2										

M. K. S.
I/C-LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/123/5012


Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	10 Ph-1	Inlet	7.2	152	84	204	20.8	38.8	24.6	Not meeting the standards wrt TSS & BOD.
		Outlet	7.4	24	20	32	3.2	4.0	1.4	
		OLMS	7.40	8.21	6.38	36.48	-	13.96	-	
2	10 Ph-2	Inlet	6.9	360	225	424	26.4	33.4	18.8	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.1	26	20	60	5.6	4.6	3.4	
		OLMS	7.51	23.12	14.40	75.14	-	8.71	-	
Total 20										

N. Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/124/5013

Dated: 06/09/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	12	Inlet	7.1	260	112	284	26.4	35.4	24.8	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.4	36	28	52	5.2	4.8	2.6	
		OLMS	7.27	40.56	18.27	46.80	-	7.30	-	
	16	Outlet	7.2	24	20	32	3.6	5.4	2.2	Not meeting the Standards wrt TSS, BOD, Ammonical Nitrogen & Dissolved Phosphate
		OLMS	7.34	5.99	4.49	14.97	-	2.99	-	
	37	Outlet	7.5	20	18	56	2.8	4.0	1.6	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS*	-	-	-	-	-	-	-	
	45	Outlet	7.3	16	12	60	3.2	3.6	2.0	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.26	24.48	13.77	64.26	-	6.55	-	
	Total 110									

*Remarks: OLMS (37 MGD) was found non-operational at the time of Monitoring (informed by JE, DJB).

N. Mitta
I/C LABORATORY
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 06/09/2022

Report Number: DPCC/W/STP/22-23/125/5014

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022


1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	40	Inlet	7.3	248	115	296	20.8	26.8	22.4	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.5	18	14	36	2.4	3.0	1.8	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.3	248	115	296	20.8	26.8	22.4	Not meeting the Standards wrt TSS, COD & BOD.
		Outlet	7.1	44	28	52	6.8	4.6	1.2	
		OLMS	-	-	-	-	-	-	-	
Total 60										

*Remarks: OLMS of 20 MGD was found non-operational and of 40 MGD , display was not working at the time of monitoring.

Mitra

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/05 / 50 15

Date: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 05.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	7.1	212	114	280	26.4	22.8	20.4	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.4	28	20	60	9.2	2.6	3.2	
		OLMS	-	-	-	-	-	-	-	
Total 0.66										

*Remarks: During the monitoring, the OLMS was found non-operational.

N. Mitta
I/C LABORATORY
Dr. ...
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/106/5029

Dated: 06/09/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF AUGUST-2022

1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.08.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	20	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.1	136	72	292	38.4	35.8	13.2	
		OLMS	7.4	8	5	20	2.8	3.2	1.8	
Total 20	7.56	6.01	4.06	34.12	-	2.16	-			
I-Increase & D-Decrease										

N. Mitra
I/C LABORATORY
Dr. NANDIYA MOITRA
Scientist 'C'