



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/281/SS46

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 22.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	Ph-I,II (20)	Inlet	7.2	304	150	448	17.6	21.8	11.6	Not meeting the standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.5	30	20	56	2.4	4.3	2.5	
		OLMS	7.4	28.18	11.57	74.45	-	9.11	-	
2	Ph-III (70)	Inlet	7.4	272	145	368	13.2	33.4	29.6	Meeting the standards.
		Outlet	7.5	10	8	32	2.4	3	1.2	
		OLMS	7.5	7.87	7.09	17.07	-	1.10	-	
Total 90										

Nandita

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/282/SS41

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I,II(15)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.2	228	110	288	20.4	31.3	12.8	
		OLMS	7.5	8	5	28	2	3.1	1	
Total 15			7.2	6.23	4.16	19.56	-	5.92	-	

N. Moitra

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/283/SS42

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
Phase-I, II(2.2)		Inlet	7.1	236	127	304	19.2	25.4	14.8	Meeting the Standard.
		Outlet	7.3	8	6	24	2.8	4	1.2	
		OLMS	7.4	3.46	3.55	15.94	-	1.84	-	
Total 2.2										

M. Mohita
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/284/SS43

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

- Name of STP : Keshopur STP (New)
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 23.03.2023
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	Not Meeting the standards wrt TSS & BOD.
		Outlet	7.4	312	130	384	12.8	37.8	27.6	
		OLMS	7.2	24	14	48	2.8	2.4	1.3	
Total 12			7.5	8.16	5.91	29.84	-	4.08	-	

Mishra

Dr. V. K. SHARMA
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmir Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/285/SS44

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	Phase-I,II (2.2)	Inlet	7.3	256	130	304	17.6	29.7	22.4	Meeting the Standards
		Outlet	7.5	10	8	32	2.8	2.6	1.2	
		OLMS	8.3	5.06	2.85	24.65	-	2.10	-	
Total 2.2										

N. Mishra
D.V. LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/286/SS45

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	20	Inlet	7.4	192	86	288	12	15.3	18.7	Meeting the standards
		Outlet	7.1	10	7	32	1.6	3.1	1	
		OLMS	7.6	10.0	7.5	42.8	-	3.19	-	
Total 20										

M. Mehta
D/C LABORATORY
Scientist 'E'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/287/SS 46

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	
1	40	Inlet	7.1	184	72	256	10.8	16.4	28.4	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.4	42	22	64	2.8	3.1	1.4	
		OLMS	7.5	117.2	52.24	270.83	-	15.57	-	
Total 40										


Dr. Nandita Moitra
SCIENTIST I
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
 Website : <http://www.dpcc.delhigovt.nic.in>

Date: 12/04/2023

Report Number DPCC/W/STP/22-23/288 [SS 617]

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Dissolved Phosphate as P (mg/l)	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.5	264	135	416	17.6	42.5	20.7	
		OLMS	7.2	48	28	80	1.2	3.7	5	
Total 5			7.5	23.90	15.20	91.60	-	15.96	-	

Mishra
 Dr. N. K. Mishra
 LABORATORY
 Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/289/SS 48

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I(40)	Inlet	-	-	-	50	10	5	2	Plant was under Rehabilitation.
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.2	268	120	288	9.6	11.6	18.9	Not Meeting the Standards wrt TSS & BOD.
		Outlet	7.4	32	23	48	1.2	2.8	1.6	
		OLMS	7.3	12.34	8.71	30	-	10.25	-	
Total 80										

Dr. Nandita Moitra
SCIENTIST D
W/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/290/SS 49

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammoniacal Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	20	Inlet	7.4	204	134	368	16	14.6	29.4	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.2	40	20	56	3.2	3.4	2	
		OLMS	7.5	58.66	24.82	125.38	-	8.0	-	
Total 20										

Mishra
I/C LABORATORY
Dr. Nandana Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/22-23/291/SS 50

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
	20	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.4	204	134	368	16	14.6	29.4	
		OLMS	7.1	8	6	40	0.8	2.3	0.7	
	Total 20		7.8	7.27	5	29.50	-	1.39	-	


Dr. Nandita Moitra
SCIENTIST
LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/292/SSS1

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD & Dissolved phosphate.
		Outlet	7.5	336	165	352	11.6	26.7	20.6	
		OLMS	7.3	30	14	43	2.8	4.9	2.1	
Total 15			7.5	18.16	9.49	58.39	-	10.95	-	


Dr. Nalini Bhatnagar
LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/293/SSS2

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS & BOD.
		Outlet	7.5	240	95	200	10.4	19.6	14.8	
		OLMS	7.3	30	16	40	3.2	1.2	1.8	
Total 10			7.5	20.89	15.50	85.79	-	7.46	-	


Dr. Narela
SCIENTIST 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
 Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/294/SSS3

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.5	196	115	256	12.4	22.1	17.4	
		OLMS	7.2	10	7	28	1.2	2.1	0.9	
Total 30	7.9	7.38	5.26	35.49	-	1.58	-			

Maitra
 Dr. Maitra
 LABORATORY
 Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 12/04/2023

Report Number: DPCC/W/STP/22-23/295/SSSU

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I (10)	Inlet	7.2	216	94	256	22.8	44.8	31.4	Meeting the standards.
		Outlet	7.1	8	6	32	2	2.8	1.2	
		OLMS	-	-	-	-	-	-	-	
2	Ph-III (10)	Outlet	7.4	10	8	40	1.6	3	1	OLMS was found non-operational
		OLMS	-	-	-	-	-	-	-	Meeting the standards.
Total 20										OLMS was found locked

I/C LABORATORY

Dr. Mondita...



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/296 / SSSS

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.1	264	115	320	21.2	34.6	28.4	Not meeting the standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved phosphate.
		Outlet	7.3	124	60	168	4.4	11.7	6.8	
		OLMS	6.7	107	42.85	275.13	-	23.78	-	
Total 45										

Meha
Dr. Meha Mehta
I/C LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/297/SSSG

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.1	152	88	256	4.2	24.3	19.4	Meeting the standards.
		Outlet	7.3	10	8	24	2.4	3.6	1.2	
		OLMS	7.6	9.12	4.49	35.49	-	2.19	-	
Total 5										

I/C LABORATORY
Dr. Nandita Moltra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/298/SSS7

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	25	Inlet	7.2	324	180	288	16.8	24.6	27.3	Not meeting the Standards wrt TSS BOD & Dissolved phosphate.
		Outlet	7.5	22	16	48	2.8	3.8	2.8	
		OLMS	8.7	17.38	6.55	27.80	-	13.54	-	
Total 25										

N. Mishra
Dr. N. Mishra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/299/SSS8

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.5	192	74	208	10.8	24.3	16.9	Meeting the Standards.
		Outlet	7.4	6	4	24	2.8	2.9	0.9	
		OLMS	7.3	6.25	4.35	26.5	-	3.54	-	
Total 9										

Mita
Dr. Nandini
LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/300/SSS9

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 10.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	1	Inlet	7.4	144	67	192	15.2	15.8	19.5	Meeting the Standards.
		Outlet	7.2	2	4	16	0.8	1.2	0.6	
		OLMS	8.0	0.76	2.4	8.3	-	0.03	-	
Total 1										

N. Mittal
Dr. N. MITTAL
LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/301/SS60

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.1	192	105	336	9.6	15.7	30.4	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.3	36	22	56	2.4	3.8	1.1	
		OLMS	7.4	21.32	11.92	63.66	-	10.64	-	
Total 15										


Dr. Navin Kumar
SCIENTIST 'D'
VGLABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/302/SS61

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	2.2	Inlet	7.2	260	120	320	14	21.2	25.4	Not meeting the standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.4	34	13	56	2.8	3.1	2.8	
		OLMS	8.1	6.58	4.13	22.06	-	13.38	-	
2	3	Inlet	7.3	208	110	272	6.8	18.5	28.6	
		Outlet	7.2	44	25	96	0.8	3.9	2.4	
		OLMS	8.0	7.97	4.20	16.75	-	11.76	-	
Total 5.2										

Maitra
Dr. Maitra
LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/303/SS62

Dated : 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2		
1	10 Ph-1	Inlet	7.1	188	90	304	8.4	10.7	29.2	Not meeting the standards wrt TSS, BOD & Dissolved phosphate.	
		Outlet	7.4	32	12	48	2.4	3.5	3.1		
		OLMS	8.1	9.03	7.32	43.92	-	10.25	-		
2	10 Ph-2	Inlet	7.3	232	120	272	9.6	20.6	24.6		Not meeting the standard wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.5	36	18	64	3.2	1.9	3.5		
		OLMS	7.8	14.85	11.60	48.72	-	12.06	-		
Total 20											

I/C LABORATORY
Dr. Nandita Mohita
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
 Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/304/SS63

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Dissolved Phosphate as P (mg/l)	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
			6.5-9.0	10	10	50	10	5	2	
1.	12	Inlet	7.3	264	140	368	13.6	26.4	19.8	Not meeting the Standards wrt TSS & BOD.
		Outlet	7.6	40	20	48	2.8	2.4	1.4	
		OLMS	7.4	17.22	13.53	59.4	-	2.36	-	
	16	Outlet	7.3	42	18	64	4.8	4.1	2.3	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		OLMS	7.0	24.34	10.17	55.0	-	11.73	-	
	37	Outlet	7.5	48	26	72	2.4	3.9	2.1	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		OLMS	-	-	-	-	-	-	-	
	45	Outlet	7.2	50	31	88	3.6	2.8	1.4	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	6.6	19.36	10.89	58.80	-	8.16	-	
	Total 110									

Mishra
 Dr. Sandhya Moitra
 I/O LABORATORY
 Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/305/SS64

Dated: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 23.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Dissolved Phosphate as P(mg/l)	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
1	40	Inlet	7.5	188	97	368	13.2	21.6	18.6	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.2	68	38	128	4.4	3.8	1.1	
		OLMS	7.6	79	71	265	-	15.34	-	
2	20	Inlet	7.5	188	97	368	13.2	21.6	18.6	
		Outlet	7.1	56	32	104	4.8	18.9	13.5	
		OLMS	7.2	94.64	67.23	276.94	-	21.61	-	
Total 60										


Dr. Nandita Moitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 12/04/2023

Report Number: DPCC/W/STP/22-23/306/SS65

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Dissolved Phosphate as P(mg/l)	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.2	128	66	192	4.4	24.6	31.6	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.1	46	20	64	2	1.8	2.7	
		OLMS	7.7	15.12	12.0	43.20	-	16.80	-	
Total 5										

Mishra
Dr. Nandita Mishra
SCIENTIST 'D'
LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/12/SS 66

Date: 12/04/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.03.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Dissolved Phosphate as P(mg/l)	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)		
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	7.6	288	135	416	19.2	18.7	19.4	Not meeting the Standards wrt TSS, BOD & Dissolved phosphate.
		Outlet	7.2	34	15	48	3.6	3.1	3	
		OLMS	8.3	23.84	10.7	88.7	-	14.99	-	
Total 0.66										


Dr. Nandita Mohita
I/C LABORATORY
Scientist 'D'