



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/2024/ 1147
Date of Sampling: -05.07.2024

Dated: 29/07/2024

S.No.	Sampling location	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1.	Najafgarh Drain	6.9	132	140	45
2.	Metcalf House Drain	7.1	48	68	26
3.	Khyber Pass Drain	NO FLOW			
4.	Sweeper Colony Drain	7	102	116	42
5.	Magazine Road Drain	7.2	72	108	32
6.	ISBT Drain	6.8	82	244	40
7.	Tonga Stand Drain	NO FLOW			
8.	Civil Mill Drain	NO FLOW			
9.	SEN Nursing Home Drain	7.2	120	212	60
10.	Drain No. 14	NO FLOW			
11.	Power House Drain	7.9	112	292	60
12.	Indrapuri Drain	7.5	105	232	45
13.	Sonia Vihar Drain	Sample collection not possible because of slippery area caused by rain			
14.	Kailash Nagar Drain	NO FLOW			
15.	Shastri Park Drain	7.8	65	172	35
16.	Barapulla Drain	7.3	97	224	39
17.	Maharani Bagh Drain	7.4	91	216	52
18.	Old Agra Canal Drain	NO FLOW			
19.	Jaitpur Drain	7.7	103	204	55
20.	Sarita Vihar Pool	6.9	54	148	46
21.	Tuglakabad Drain	7.8	78	144	52
22.	Drain Near LPG Bottling Plant	NO FLOW			
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	NO FLOW			
24.	Shahdara Drain	7.3	101	272	80
25.	Sahibabad Drain	7.9	109	236	70
26.	Molarband Drain	TRAPPED			
27.	Abul Fazal Drain	7.2	102	256	65

Maitra
I/C WATER LAB
Dr. Nandita Moitra
Scientist 'D'

Saha
SSA/Analyst/SLA