



DELHI POLLUTION CONTROL COMMITTEE
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF RIVER YAMUNA

Report No : DPCC/W/Y/19-20/01-09/93

Date 06/05/2019

Date of Sampling 23.04.19

S.No	Locations	pH	COD (mg/l)	BOD (mg/l)	DO (mg/l)	Total Coliform (MPN/100ml)
Water Quality Criteria ('C' Class)		6.0- 9.0	-	3(max)	4(min)	5000
1	Palla	7.6	8	1.7	8.5	-
2	Surghat (Down stream of Wazirabad Barrage)	7.4	12	2.8	5.8	-
3	Khajori Paltoon Pool (Downstream Najafgarh Drain)	7.5	64	19	NIL	-
4	Kudesia Ghat	7.2	76	24	NIL	-
5	ITO Bridge	7.0	88	28	NIL	-
6	Nizamudin Bridge	7.0	68	20	NIL	-
7	Agra Canal (Okhla)	7.3	68	24	NIL	-
8	After meeting Shahdara Drain (Downstream Okhla Barrage)	7.4	96	28	NIL	-
9	Agra Canal (Jaitpur)	7.4	64	23	NIL	-

(Dr. M.P. GEORGE)
I/c WATER LAB

SCIENTIFIC ASSISTANT