

AVON FOOD LAB PVT. LTD.

28/5/2020

2080
1 Name & Address of Ind./Unit :

Delhi Pollution Control Committee

2 Name of STP Plant :

Rohini Sec-25 (15 MGD) & Rithala Phase-I (40 MGD)

3 Date of Sampling :

09/05/2020

4 Time of Sampling :

13:20 - 13:30 to 12:20 PM - 12:30 PM

5 Sampling Done by :

Mr. Navneet Srivastav

6 Sample Quantity :

(5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Rohini Sector-25 (15 MGD)	Inlet	7.32	191.4	170.0	416.0	28.2	60.3	5.8	1100	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.75	15.2	18.0	52.0	BDL (DL-4.0)	17.3	1.6	580	
		OLMS*	7.48	95.17	13.04	85.59	-	13.19	-	-	
2	Rithala Phase-I,II (40 MGD)	Inlet	6.98	250.8	180.0	468.0	32.6	31.0	6.2	700	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Dissolved Phosphate
		Outlet	7.08	98.0	80.0	240.0	6.0	20.0	2.6	210	
		OLMS*	Not Working								

N. Moitra
Dr. NANDITA MOITRA
Scientist 'C'

AVON FOOD LAB PVT. LTD.

2081

28/5/2020

- 1 Name & Address of Ind./Unit :
- 2 Name of STP Plant :
- 3 Date of Sampling :
- 4 Time of Sampling :
- 5 Sampling Done by :
- 6 Sample Quantity :

Delhi Pollution Control Committee
 Rithala Phase-II (40 MGD)
 09/05/2020
 12:40 PM
 Mr. Navneet Srivastav
 5 Ltr. + 1 Ltr.

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Rithala Phase-II (40 MGD)	Inlet	6.98	250.8	180.0	468.0	32.6	31.0	6.2	700	Not meeting the standards w.r.t. TSS, BOD, Ammonical Nitrogen
		Outlet	7.35	13.8	12.0	48.0	BDL (DL-4.0)	5.8	0.8	170	
		OLMS*	Not Working								

N. Moitra
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

28/5/2020

2082

1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Okhla (16 & 37MGD)
 3 Date of Sampling : 11/05/2020
 4 Time of Sampling : 11:50 AM & 12:10 PM
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Okhla (16 MGD)	Inlet	7.87	216.0	180.0	480.0	18.6	22.0	5.2	2200	Not meeting the standards w.r.t. TSS, BOD, COD, Faecal Coliform
		Outlet	7.32	46.0	14.0	52.0	BDL (DL-4.0)	4.2	0.3	430	
		OLMS*	6.57	30.90	18.49	48.63	-	1.09	-	-	
2	Okhla (37 MGD)	Inlet	7.87	216.0	180.0	480.0	18.6	22.0	5.2	2200	Not meeting the standards w.r.t. TSS, BOD, COD, Faecal Coliform
		Outlet	7.15	32.0	20.0	60.0	BDL (DL-4.0)	3.7	0.4	580	
		OLMS*	Not Working								

N. Moitra
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

2183

28/5/2020

1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Okhla (45 & 12 MGD)
 3 Date of Sampling : 11/05/2020
 4 Time of Sampling : 12:30 PM to 12:45 PM
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Okhla (45 MGD)	Inlet	7.87	216.0	180.0	480.0	18.6	22.0	5.2	2200	Not meeting the standards w.r.t. TSS, BOD, COD, Faecal Coliform
		Outlet	7.71	13.8	12.0	52.0	BDL (DL-4.0)	4.4	0.4	250	
		OLMS*	7.82	25.23	11.68	17.77	-	1.05	-	-	
2	Okhla (12 MGD)	Inlet	7.87	216.0	180.0	480.0	18.6	22.0	5.2	2200	Not meeting the standards w.r.t. TSS, BOD, COD, Faecal Coliform
		Outlet	7.76	34.2	22.0	72.0	BDL (DL-4.0)	3.8	0.3	380	
		OLMS*	4.57	32.86	19.98	66.25	-	5.0	-	-	

Nandita
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

2084

28/5/2020

1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Molarband (3 MLD) & Okhla New (30 MGD)
 3 Date of Sampling : 11/05/2020
 4 Time of Sampling : 15:10 - 15:20 & 13:30 - 13:40
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Molarband (3 MLD)	Inlet	7.02	406.0	380.0	1128.0	36.8	50.0	7.8	1700	Not meeting the standards w.r.t. Ammonical Nitrogen, Faecal Coliform
		Outlet	7.51	8.2	9.0	24.0	BDL (DL-4.0)	12.8	0.4	270	
		OLMS*	Not Working								
2	Okhla New (30 MGD)	Inlet	7.31	203.6	160.0	452.0	30.0	33.0	5.2	380	Meeting the standards
		Outlet	7.37	2.6	2.9	8.0	BDL (DL-4.0)	3.8	0.2	210	
		OLMS*	7.60	29.55	24.60	65.56	-	0.68	-	-	

N. Mitra
 Dr. NANDITA MOITRA
 Scientist 'C'

2085

AVON FOOD LAB PVT. LTD.

28/5/2020

1 Name & Address of Ind./Unit :

Delhi Pollution Control Committee

2 Name of STP Plant :

Coronation I & II(10 MGD) & Delhi Gate I (10 MLD)

3 Date of Sampling :

12/05/2020

4 Time of Sampling :

14:50 - 15:00 & 12:15 PM to 12:25 PM

5 Sampling Done by :

Mr. Navneet Srivastav

6 Sample Quantity :

(5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Coronation I & II (10 MGD)	Inlet	6.89	127.8	180.0	500.0	26.4	28.5	6.2	5400	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.13	57.6	25.0	72.0	BDL (DL-4.0)	8.6	0.8	380	
		OLMS*	Not Working								
2	Delhi Gate I (10 MLD)	Inlet	7.17	42.4	46.0	144.0	8.6	24.0	4.8	7000	Not meeting the standards w.r.t. Ammonical Nitrogen, Faecal Coliform
		Outlet	7.29	6.0	3.5	8.0	BDL (DL-4.0)	6.6	0.2	400	
		OLMS*	Not Working								

N. Moitra
Dr. NANDITA MOITRA
Scientist 'C'

AVON FOOD LAB PVT. LTD.

2086

28/5/2020

- 1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Coronation III (10 MGD) & Sen Nursing Home (10 MLD)
 3 Date of Sampling : 12/05/2020
 4 Time of Sampling : 14:30 - 14:40 & 12:50 PM to 13:00
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Coronation III (10 MGD)	Inlet	6.93	226.0	94.0	272.0	26.4	22.0	6.3	3300	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.41	56.4	32.0	88.0	5.2	11.8	0.8	480	
		OLMS*	7.06	54.88	41.48	115.89	-	19.29	-	-	
2	Sen Nursing Home (10 MLD)	Inlet	7.24	89.6	56.0	148.0	14.2	18.2	4.6	8400	Not meeting the standards w.r.t. TSS, Faecal Coliform
		Outlet	7.32	13.6	3.2	8.0	BDL (DL-4.0)	4.2	0.2	310	
		OLMS*	7.92	7.115	1.9	11.7	-	3.95	-	-	

N. Mitra
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

2087

28/5/2020

1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Delhi Gate II (15 MGD)
 3 Date of Sampling : 12/05/2020
 4 Time of Sampling : 11:50 to 12:00 PM
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Delhi Gate II (15 MGD)	Inlet	7.18	46.8	36.0	100.0	8.6	28.2	5.2	2800	Not meeting the standards w.r.t. TSS, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.47	12.4	10.0	28.0	BDL (DL-4.0)	5.8	0.2	250	
		OLMS*	7.40	5.05	4.80	36.88	-	94.70	-	-	

N. Moha
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

2089

28/5/2020

1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Kondli (45 & 25 MGD)
 3 Date of Sampling : 13/05/2020
 4 Time of Sampling : 13:00 to 13:10 & 12:30 PM to 12:40 PM
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Kondli (45 MGD)	Inlet	6.82	180.0	140.0	392.0	24.0	35.0	6.5	1500	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.17	28.0	30.0	88.0	BDL (DL-4.0)	13.0	0.6	380	
		OLMS*	Not Working								
2	Kondli (25 MGD)	Inlet	6.93	206.0	120.0	344.0	22.6	52.0	7.5	1100	Not meeting the standards w.r.t. TSS, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.47	20.2	9.0	32.0	BDL (DL-4.0)	6.2	0.4	260	
		OLMS*	7.71	24.80	8.49	27.04	-	7.54	-	-	

N. Mitra
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

2090

28/5/2020

1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Yamuna Vihar I & II (10 MGD)
 3 Date of Sampling : 14/05/2020
 4 Time of Sampling : 14:40 to 14:50 & 15:05 to 15:10
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Yamuna Vihar I (10 MGD)	Inlet	7.14	260.0	180.0	504.0	26.6	43.5	6.8	3500	Not meeting the standards w.r.t. TSS, BOD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.66	19.0	14.0	36.0	BDL (DL-4.0)	11.8	0.3	270	
		OLMS*	6.75	3076.0	222.24	1249.70	-	6.47	-	-	
2	Yamuna Vihar II (10 MGD)	Inlet	6.93	208.0	186.0	512.0	25.2	35.0	7.2	4300	Not meeting the standards w.r.t. TSS, BOD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.11	12.0	12.0	32.0	BDL (DL-4.0)	9.5	0.5	470	
		OLMS*	Not Working								

N. Moitra
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

28/5/2020

- 209,
 1 Name & Address of Ind./Unit :
 2 Name of STP Plant :
 3 Date of Sampling :
 4 Time of Sampling :
 5 Sampling Done by :
 6 Sample Quantity :

Delhi Pollution Control Committee
 Yamuna Vihar III (25 MGD)
 14/05/2020
 15:30 to 15:45
 Mr. Navneet Srivastav
 (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Yamuna Vihar III (25 MGD)	Inlet	7.11	220.0	196.0	488.0	27.0	38.0	7.2	2400	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.57	66.0	38.0	120.0	5.8	21.0	1.3	380	
		OLMS*	Not Working								

Nandita
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

28/5/2020

- 2092
- 1 Name & Address of Ind./Unit :
 - 2 Name of STP Plant :
 - 3 Date of Sampling :
 - 4 Time of Sampling :
 - 5 Sampling Done by :
 - 6 Sample Quantity :

Delhi Pollution Control Committee
 Narela (10 MGD)
 15/05/2020
 13:20 to 13:30
 Mr. Navneet Srivastav
 (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Narela (10 MGD)	Inlet	7.35	225.0	130.0	368.0	27.6	32.8	5.7	2800	Not meeting the standards w.r.t. TSS, & Faecal Coliform
		Outlet	8.11	15.0	10.0	28.0	BDL (DL-4.0)	4.8	0.3	310	
		OLMS*	7.76	1131.16	260.10	801.03	-	-	-	-	

N. Mitra
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

28/5/2020

2093

- 1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Nilothi Phase-II (8.46 MGD) & Keshopur (12,20 & 40 MGD)
 3 Date of Sampling : 16/05/2020
 4 Time of Sampling : 13:40 to 13:50 & 11:05 AM
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Nilothi Phase-II (8.46 MGD)	Inlet	6.93	225.0	130.0	348.0	18.6	22.0	5.2	1200	Not meeting the standards w.r.t. Faecal Coliform
		Outlet	7.49	5.0	7.0	24.0	BDL (DL-4.0)	4.5	0.2	330	
		OLMS*	Not Working								
2	Keshopur (12,20 & 40 MGD)	Inlet	7.15	306.0	240.0	720.0	30.6	33.0	7.3	4300	
		Outlet	-	-	-	-	-	-	-	-	
		OLMS*	Not Working								

Nandita
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

28/5/2020

- 2094
- 1 Name & Address of Ind./Unit :
 - 2 Name of STP Plant :
 - 3 Date of Sampling :
 - 4 Time of Sampling :
 - 5 Sampling Done by :
 - 6 Sample Quantity :

Delhi Pollution Control Committee
 Keshopur (12,20 & 40 MGD)
 16/05/2020
 11:20 AM to 11:40 AM
 Mr. Navneet Srivastav
 (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Keshopur (12 MGD)	Inlet	7.15	306.0	240.0	720.0	30.6	33.0	7.3	4300	Not meeting the standards w.r.t. Faecal Coliform
		Outlet	7.93	8.6	4.6	16.0	BDL (DL-4.0)	4.8	0.6	330	
		OLMS*	Not Working								
2	Keshopur (20 MGD)	Inlet	7.15	306.0	240.0	720.0	30.6	33.0	7.3	4300	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.35	102.0	90.0	276.0	6.2	12.5	1.8	410	
		OLMS*	Not Working								
3	Keshopur (40 MGD)	Inlet	7.15	306.0	240.0	720.0	30.6	33.0	7.3	4300	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.04	92.6	46.0	120.0	5.4	11.8	1.3	320	
		OLMS*	Not Working								

N. Mitra
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

- 2095
- 1 Name & Address of Ind./Unit :
 - 2 Name of STP Plant :
 - 3 Date of Sampling :
 - 4 Time of Sampling :
 - 5 Sampling Done by :
 - 6 Sample Quantity :

28/5/2020
 Delhi Pollution Control Committee
 Kapashera & Mahrauli (5 MGD)
 20/05/2020
 12:10 PM to 12:50 PM & 13:40 to 13:50
 Mr. Navneet Srivastav
 (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Kapashera	Inlet	7.42	212.0	180.0	572.0	22.6	24.0	6.2	2800	Not meeting the standards w.r.t. TSS, BOD, COD & Faecal Coliform
		Outlet	8.51	13.8	15.0	56.0	BDL (DL-4.0)	3.8	0.3	250	
		OLMS*	7.79	16.85	6.85	50.67	-	4.30	-	-	
2	Mahrauli (5 MGD)	Inlet	7.35	234.0	186.0	528.0	24.8	28.0	6.8	2200	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen & Faecal Coliform
		Outlet	7.94	30.2	18.0	52.0	BDL (DL-4.0)	8.4	0.6	260	
		OLMS*	7.72	38.30	18.01	83.57	-	14.98	-	-	

Nandita
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

2096

28/5/2020

- 1 Name & Address of Ind./Unit :
- 2 Name of STP Plant :
- 3 Date of Sampling :
- 4 Time of Sampling :
- 5 Sampling Done by :
- 6 Sample Quantity :

Delhi Pollution Control Committee
 Papan Kalan Phase I & II (20 MGD)
 20/05/2020
 15:10 to 15:20 & 15:30 to 15:40
 Mr. Navneet Srivastav
 (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Papan Kalan Phase I (20 MGD)	Inlet	7.31	168.0	160.0	476.0	19.8	30.0	5.2	5400	Not meeting the standards w.r.t. TSS, BOD, COD, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.59	84.2	50.0	148.0	5.6	20.2	0.5	380	
		OLMS*	Not Working								
2	Papan Kalan Phase II (20 MGD)	Inlet	7.21	326.0	230.0	648.0	28.6	35.0	7.6	7000	Not meeting the standards w.r.t. TSS, Ammonical Nitrogen, Faecal Coliform
		Outlet	7.66	12.4	5.0	20.0	BDL (DL-4.0)	6.2	0.8	270	
		OLMS*	11.67	527.42	80.19	377.35	-	-	-	-	

Nandita
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

28/5/2020

2097
 1 Name & Address of Ind./Unit : Delhi Pollution Control Committee
 2 Name of STP Plant : Najafgarh (5 MGD)
 3 Date of Sampling : 21/05/2020
 4 Time of Sampling : 15:30 to 15:40
 5 Sampling Done by : Mr. Navneet Srivastav
 6 Sample Quantity : (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Najafgarh (5 MGD)	Inlet	7.27	218.0	140.0	400.0	21.2	32.5	5.8	7900	Not meeting the standards w.r.t. TSS, BOD, Ammonical Nitrogen.
		Outlet	7.64	26.5	12.0	44.0	BDL (DL-4.0)	12.0	0.8	220	
		OLMS*	Not Working								

N. Moitra
 Dr. NANDITA MOITRA
 Scientist 'C'

AVON FOOD LAB PVT. LTD.

2088

28/5/2020

- 1 Name & Address of Ind./Unit :
- 2 Name of STP Plant :
- 3 Date of Sampling :
- 4 Time of Sampling :
- 5 Sampling Done by :
- 6 Sample Quantity :

Delhi Pollution Control Committee
 Akshardham (1 MGD) & Chilla (9 MGD)
 13/05/2020
 14:40 to 14:50 & 11:25 AM to 11:35 AM
 Mr. Navneet Srivastav
 (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230	Remarks
1	Akshardham (1 MGD)	Inlet	6.90	242.0	136.0	408.0	18.2	17.0	6.5	2100	Not meeting the standards w.r.t. Faecal Coliform
		Outlet	7.90	3.0	3.2	12.0	BDL (DL-4.0)	BDL (DL-0.5)	0.1	430	
		OLMS*	7.92	0.64	0.14	3.74	-	0.40	-	-	
2	Chilla (9 MGD)	Inlet	7.28	188.0	140.0	384.0	24.0	30.6	6.8	2800	Not meeting the standards w.r.t. Ammonical Nitrogen, Faecal Coliform
		Outlet	7.45	8.0	8.0	36.0	BDL (DL-4.0)	6.8	0.3	330	
		OLMS*	Not Working								

N. Moitra
 Dr. NANDITA MOITRA
 Scientist 'C'

2157 AVON FOOD LAB PVT. LTD. 17/6/20

- 1 Name & Address of Ind./Unit :
- 2 Name of STP Plant :
- 3 Date of Sampling :
- 4 Time of Sampling :
- 5 Sampling Done by :
- 6 Sample Quantity :

Delhi Pollution Control Committee
 Nilothi Phase-I (40 MGD)
 29/05/2020
 12:20 to 12:30
 Mr. Prabhat Jha
 (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230
1	Nilothi Phase-I (40 MGD)	Inlet	7.39	182.0	85.0	252.0	18.6	40.0	5.8	5400
		Outlet	7.69	42.0	34.0	116.0	4.8	26.0	1.2	410
		OLMS*	6.72	58.79	266.0	229.59	-	51.47		

N. Moitra
 Dr. NANDITA MOITRA
 Scientist 'C'

2097/A

AVON FOOD LAB PVT. LTD.

28/5/20

- 1 Name & Address of Ind./Unit :
 2 Name of STP Plant :
 3 Date of Sampling :
 4 Time of Sampling :
 5 Sampling Done by :
 6 Sample Quantity :

Delhi Pollution Control Committee
 Vasant Kunj (3 MGD & 2.2 MGD)
 01/06/2020
 11:40 to 12:20
 Mr. Suneshwar Singh
 (5 Ltr. + 1 Ltr.) Each

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P (mg/l) 2	Faecal Coliform MPN/100ml < 230
1	Vasant Kunj (3 MGD)	Inlet	7.11	158.0	104.0	328.0	20.4	24.0	5.2	8400
		Outlet	7.83	15.0	5.0	16.0	BDL (DL-3.0)	8.0	0.3	480
		OLMS*	7.59	17.58	4.54	43.78	-	9.10		
1	Vasant Kunj (2.2 MGD)	Inlet	7.16	296.0	200.0	592.0	28.2	26.0	7.2	7000
		Outlet	7.87	20.8	25.0	80.0	BDL (DL-3.0)	5.0	1.8	410
		OLMS*	7.24	29.95	21.28	82.74	-	4.52		

Nandita
 Dr. NANDITA MOITRA
 Scientist 'C'