



DELHI POLLUTION CONTROL COMMITTEE
4th FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>
WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/19-20/217-240
Date of Sampling- 6/01/20

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
	Standards	5.5- 9.0	100	250	30
1	Najafgarh Drain	7.4	136	220	72
2	Metcalf House Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
3	Khyber Pass Drain	7.7	26	52	16
4	Sweeper Colony Drain	7.9	124	184	65
5	Magazine Road Drain	7.4	284	420	180
6	ISBT Drain	7.9	180	390	132
7	Tonga Stand Drain	7.2	128	240	90
8	Moat Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
9	Civil Mill Drain	7.3	190	360	120
10	Power House Drain	7.3	180	340	120
11	Sen Nursing Home Drain	7.2	102	260	84
12	Drain No. 12A	NO FLOW	NO FLOW	NO FLOW	NO FLOW
13	Drain No. 14	7.3	104	220	72
14	Barapulla Drain	7.5	104	210	78
15	Maharani Bagh Drain	7.6	172	340	120
16	Kalkaji Drain	7.6	132	210	80
17	Sarita Vihar Drain (Mathura Road)	7.6	280	480	180
18	Tekhhand Drain	7.7	218	392	130
19	Tuglakabad Drain	7.8	396	672	230
20	Drain Near LPG Bottling Plant	NO FLOW	NO FLOW	NO FLOW	NO FLOW
21	Drain Near Sarita Vihar Bridge	7.8	364	636	210
22	Shahdara Drain	8.0	392	724	240
23	Sahibabad Drain	8.0	360	576	190
24	Indrapuri Drain	8.2	280	488	160

N. Mishra
SR. SCIENTIST

A. D. Sharma
SSA/JLA/ANALYST