



DELHI POLLUTION CONTROL COMMITTEE
WATER LABORATORY
4thFLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-06
visit us at : <http://dpcc.delhigovt.nic.in>

WATER QUALITY STATUS OF DRAIN

REPORT NO: DPCC/W/D/22-23/4841
Date of Sampling: -01.06.2022

Dated: 24/06/2022

S.No.	Name of Sample	pH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)
Standards		5.5- 9.0	100	250	30
1.	Najafgarh Drain	7.46	172	346	70
2.	Metcalf House Drain	7.25	48	88	29
3.	Khyber Pass Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
4.	Sweeper Colony Drain	7.42	164	266	60
5.	Magazine Road Drain	NO FLOW	NO FLOW	NO FLOW	NO FLOW
6.	ISBT Drain	7.34	156	288	68
7.	Tonga Stand Drain	7.39	58	101	33
8.	Civil Mill Drain	7.44	120	240	54
9.	Sen Nursing Home Drain	7.22	152	304	73
10.	Drain No. 14	7.56	42	80	22
11.	Power House Drain	7.48	140	293	63
12.	Indrapuri Drain	7.36	144	320	72
13.	Sonia Vihar Drain	6.90	216	426	96
14.	Kailash Nagar Drain	7.40	176	320	76
15.	Shastri Park Drain	7.28	112	224	65
16.	Barapulla Drain	7.55	124	300	67
17.	Maharani Bagh Drain	7.77	108	256	53
18.	Old Agra Canal Drain	7.53	116	272	60
19.	Jaitpur Drain	7.37	92	224	48
20.	SaritaVihar Pool	7.68	100	240	54
21.	Tuglakabad Drain	7.44	76	160	45
22.	Drain Near LPG Bottling Plant	4.67	72	213	34
23.	Drain Near Sarita Vihar Bridge (Mathura Road)	NO FLOW	NO FLOW	NO FLOW	NO FLOW
24.	Shahdara Drain	7.21	128	368	75
25.	Sahibabad Drain	7.57	132	336	80
26.	Molarband Drain	7.39	96	248	52
27.	Abul Fazal Drain	6.89	108	280	68
28.	Supplementary Drain	7.30	104	253	64

Maitra

I/C Water Lab

DR. NANDITA MOITRA
Scientist 'C'